



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2021/ 994-1016

Dt: 16 June, 2022

सेवा में / To,

संलग्न सूची के अनुसार
As per list enclosed.

Sub: Revised Reactive Energy under ABT regime-for the period 05.04.2021 to 25.04.2021
(3 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Revised Reactive Energy account (Rev-1) giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 05.04.2021 to 25.04.2021 (3 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 15.5 Paise/KVARH w.e.f from 1st April 2021, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल / S. M. Aimol)


निदेशक / Director

अधीक्षक अभियंता / Superintending Engineer
वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.

भवदीय / Yours faithfully,



(एस. एम. आइमोल / S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता / Superintending Engineer

वाणिज्य / Commercial

**Reactive Energy (VArH) Charge Statement
for the period 05-04-2021 to 11-04-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	33,975	0
ASSAM	0	3,32,911
MANIPUR	17,794	0
MEGHALAYA	0	5,50,615
MIZORAM	18,860	0
NAGALAND	0	15,730
TRIPURA	0	94,235

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	17,462
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	280


 (J. A. Anand) / J. A. Anand
 Director / Director
 NEERC / NEERC
 Ministry of Power / Min. of Power
 Govt. of India / Govt. of India
 Dispur / Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 05-04-2021 to 11-04-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	88500.8	25.5	89367	25.5	155.92	0.00	24,167	0	24,167
	132kV Khupi-Balipara	NP-9606-A	AS-55	56051.2	79.9	55644.2	79.9	-146.52	0.00	22,711	0	22,711
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	659.8	25710	692.6	25711.1	23.62	0.79	3,660	-123	3,538
	Nirjuli-TRF 1	NP-9661-A	AR-01	440.7	2041.7	441	2058.9	0.11	6.19	-17	960	943
	Nirjuli-TRF 2	NP-9662-A	AR-02	500.3	1958.8	500.8	1974.3	0.18	5.58	-28	865	837
	132kV Lekhi-Pare	NP-9607-A	PA-01	47330.9	166.3	47569.2	167.2	114.38	0.43	-17,730	67	-17,663
	132kV Chimpur-Pare	NP-9411-A	PA-05	839.4	7	899.2	7.3	28.70	0.14	-4,449	22	-4,427
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	14.6	99999.9	37.8	0	22.27	0.10	3,452	-15	3,437
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	0.9	0.2	3.8	0.2	2.78	0.00	432	0	432
TOTAL												33,975
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42864.4	75.7	43045.1	75.7	289.12	0.00	-44,814	0	-44,814
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	71560.4	6862.5	72397.9	6862.5	1,340.00	0.00	-2,07,700	0	-2,07,700
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	71212	98617.3	71431.3	98617.3	219.30	0.00	33,992	0	33,992
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	71364.6	99217.8	71814.2	99217.8	449.60	0.00	69,688	0	69,688
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28375.1	63.9	28099.9	63.9	-440.32	0.00	68,250	0	68,250
	220kV MARIANI - MISA	NP-9700-A	AS-04	8616.1	99921.3	8623.7	99921.3	12.16	0.00	1,885	0	1,885
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	47754.2	82268	46949.1	82268	-579.67	0.00	-89,849	0	-89,849
	132kV P*pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7634.4	1563.1	7686.9	1.08	37.80	-167	5,859	5,692
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99440.6	94454.6	99430.4	94363.6	-3.67	-32.76	-569	5,078	4,509
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	20125.1	3240.6	20187.1	3240.6	11.16	0.00	-1,730	0	-1,730
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	86642.8	91178.2	86461.3	91178.1	-65.34	-0.04	-10,128	6	-10,122
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	90936	99935.2	90761.3	99935.2	-62.89	0.00	-9,748	0	-9,748
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	92992.7	99981.2	92744.5	99981.2	-89.35	0.00	-13,850	0	-13,850
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	87968.2	99986.8	87632.2	99986.7	-120.96	-0.04	-18,749	6	-18,743
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28938.9	99053.4	28998.7	99055.4	21.53	0.72	-3,337	112	-3,225
	400kV AZARA-BONGAIGAOON	NP-9983-A	AM-01	5.5	99912.7	5.5	99907.6	0.00	-37.09	0	5,749	5,749
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1580.8	0.1	1278	0.00	-2,202.18	0	3,41,338	3,41,338
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82288.6	96430.9	82308.6	96179.5	7.20	-90.50	1,116	14,028	15,144
	220kV Mariani-AGBPP	NP-6888-A	AS-03	22436.6	96335.5	20445.2	96335.5	-3,186.24	0.00	-4,93,867	0	-4,93,867
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	98712.7	3.2	98628.1	2.9	-60.91	-0.22	-9,441	33	-9,408
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1039.7	99999.7	1174.7	99997.1	97.20	-1.87	15,066	290	15,356
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	13705.4	93901	13756.3	93866.6	18.32	-12.38	2,840	1,920	4,760
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	48845.9	91400.2	48873.5	91360	9.94	-14.47	1,540	2,243	3,783
TOTAL												-3,32,911
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95849.9	99121.2	95866.8	99121.2	12.17	0.00	1,886	0	1,886
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	548.5	99940.7	551.3	99940.7	1.34	0.00	208	0	208
	JIRIBAM-TRF	NP-8501-A	MN-04	24534.6	12307	24535.2	12307.3	0.04	0.02	-6	3	-3
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98958	99898.5	98962.5	99898.5	1.62	0.00	-251	0	-251
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19680.3	382.2	19737.9	382.2	20.74	0.00	-3,214	0	-3,214
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17271.3	381.6	17328.6	381.6	20.63	0.00	-3,197	0	-3,197
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	50805.5	99428.2	50508.9	99428.2	-106.78	0.00	16,550	0	16,550
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	95824.8	21.7	95772.7	21.7	-37.51	0.00	5,814	0	5,814
TOTAL												17,794


(ए.एम.आनंद/ S.K. Anand)
निदेशक/Director
उत्प्रेक्षित/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95781.6	81174.6	95858.2	81174.5	55.15	-0.07	8,549	11	8,560
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99992.3	20011.8	99919.2	20013.2	-52.63	1.01	8,158	156	8,314
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88489.9	90862.4	88410	0.00	-127.84	0	-19,815	-19,815
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87363.5	96034.5	87332.4	96033.9	-49.76	-0.96	7,713	-149	7,564
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	64277	99954	63352.8	99954	-3,360.73	0.00	-5,20,913	0	-5,20,913
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	5134.8	99864	5073.9	99864	-221.45	0.00	-34,325	0	-34,325
TOTAL												-5,50,615
MIZORAM	132kV LAUNGUAL-AIZWAL PG	NP-8504-A	MZ-02	35592.2	77608.6	35629.5	77778.1	13.43	61.02	-2,081	9,458	7,377
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78960.9	49646.1	78896.5	49661.9	-23.18	5.69	3,594	882	4,475
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69086.9	86510.3	69055.6	86506.6	-11.27	-1.33	-1,747	206	-1,540
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97224.3	31644.4	97302	31645.5	55.94	0.79	8,671	-123	8,549
TOTAL												18,860
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15328.8	7160.6	15430.1	7165.1	36.47	1.62	-5,653	251	-5,401
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70531.4	1712.8	70700.3	1713.7	121.61	0.65	-18,849	100	-18,749
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9306.2	98896.7	9167.4	98896.5	-49.97	-0.07	7,745	-11	7,734
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	97	44152.1	101.3	4.07	1.55	631	-240	391
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	92.1	43606.4	96.4	3.46	1.55	536	-240	296
TOTAL												-15,730
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97125.9	84659.8	97122.6	84659.8	-2.38	0.00	368	0	368
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10409.2	99635.7	10376.3	99635.7	-31.58	0.00	-4,896	0	-4,896
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49225.8	93757.3	49224.5	93757.1	-1.25	-0.19	-193	30	-164
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68609.7	72397.2	68609.7	72384.7	0.00	-15.00	0	2,325	2,325
	132kV BUDHJUNG NAGAR (STERLITE)	NP-9893-A	TR-28	6794.1	99998.5	6834.7	99993	38.98	-5.28	-6,041	-818	-6,860
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13487.8	0.1	13577.8	1.6	86.40	1.44	-13,392	223	-13,169
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	5099.5	99996.2	5505.7	99994.5	389.95	-1.63	-60,443	-253	-60,696
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	2232.1	99999.9	2400.4	99999.6	161.57	-0.29	-25,043	-45	-25,088
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	637.9	99999.8	689.3	99999.6	49.34	-0.19	7,648	30	7,678
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	555.2	99999.6	597	99999.3	40.13	-0.29	6,220	45	6,264
TOTAL												-94,235

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आदिमोल/S.M. Alimol)
 निदेशक/Director
 उ.पु.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 05-04-2021 to 11-04-2021 REV-01


									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	99244	99984.8	99244	99984.8	0	0	0	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	99244	99984.8	99244	99984.8	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95292	99821.6	95221.7	99821.6	-33.744	0	-5,230	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	96206.1	99796.1	96135.9	99796.1	-33.696	0	-5,223	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90505.1	99993.6	90485	99993.6	-9.648	0	-1,495	0	0
			NP-8384-A	ME-01	95631.2	68543.2	95601.8	68537.4	-14.112	-2.784	-2,187	432	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	1588.9	5483.2	1213.2	5483.2	-180.336	0	-27,952	0	-17,462
			NP-9071-A	ME-16	77169.3	28043.1	77404	28006.9	112.656	-17.376	17,462	2,693	
TOTAL													-17,462
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	3889.5	0.1	4155	0.1	127.44	0	19,753	0	280
			NP-6892-B	TR-06	76519.6	3370.5	76500.8	3360.2	-1.8048	-0.9888	-280	153	
TOTAL													280
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94703.3	99373.9	94594.1	99373.9	-52.416	0	-8,124	0	0
			NP-9947-A	NG-02	99693	99868.1	99613.3	99868.2	-23.91	0.03	-3,706	-5	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. अल्मोली/S.M. Almoli)
 निदेशक/Director
 उ.पु.के.वि.प्र./NERPC
 बिजुल मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 12-04-2021 to 18-04-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	56,715	0
ASSAM	0	3,92,782
MANIPUR	10,263	0
MEGHALAYA	0	7,51,170
MIZORAM	19,089	0
NAGALAND	0	5,519
TRIPURA	0	1,73,955

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	17,982
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	1,454


 (Signature/Stamp)
 Director/Director
 of Power
 Deptt. of Power
 Govt. of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 12-04-2021 to 18-04-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	89367	25.5	90693.3	25.6	238.73	0.02	37,004	-3	37,001
	132kV Khupi-Balipara	NP-9606-A	AS-55	55644.2	79.9	55252.3	79.9	-141.08	0.00	21,868	0	21,868
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	692.6	25711.1	713.9	25711.1	15.34	0.00	2,377	0	2,377
	Nirjuli-TRF 1	NP-9661-A	AR-01	441	2058.9	441	2093.3	0.00	12.38	0	1,920	1,920
	Nirjuli-TRF 2	NP-9662-A	AR-02	500.8	1974.3	500.8	2007.1	0.00	11.81	0	1,830	1,830
	132kV Lekhi-Pare	NP-9607-A	PA-01	47569.2	167.2	47697.5	167.2	61.58	0.00	-9,546	0	-9,546
	132kV Chimpur-Pare	NP-9411-A	PA-05	899.2	7.3	942	7.3	20.54	0.00	-3,184	0	-3,184
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	37.8	0	58.5	0	19.87	0.00	3,080	0	3,080
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	3.8	0.2	13	0.2	8.83	0.00	1,369	0	1,369
TOTAL												56,715
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43045.1	75.7	43152.3	75.8	171.52	0.16	-26,586	25	-26,561
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	72397.9	6862.5	73257.4	6862.5	1,375.20	0.00	-2,13,156	0	-2,13,156
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	71431.3	98617.3	71674.3	98617.3	243.00	0.00	37,665	0	37,665
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	71814.2	99217.8	72200.6	99217.9	386.40	0.10	59,892	-16	59,877
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	28099.9	63.9	27937.2	63.9	-260.32	0.00	40,350	0	40,350
	220kV MARIANI - MISA	NP-9700-A	AS-04	8623.7	99921.3	8623.7	99921.3	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	46949.1	82268	46280.9	82268	-481.10	0.00	-74,571	0	-74,571
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1563.1	7686.9	1654	7689.9	65.45	2.16	-10,144	335	-9,810
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99430.4	94363.6	99430	94327.5	-0.14	-13.00	-22	2,014	1,992
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	20187.1	3240.6	20285.8	3240.6	17.77	0.00	-2,754	0	-2,754
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	86461.3	91178.1	86312.6	91178.1	-53.53	0.00	-8,297	0	-8,297
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	90761.3	99935.2	90618.7	99935.2	-51.34	0.00	-7,957	0	-7,957
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	92744.5	99981.2	92322.4	99981.2	-151.96	0.00	-23,553	0	-23,553
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	87632.2	99986.7	87105.2	99986.7	-189.72	0.00	-29,407	0	-29,407
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28998.7	99055.4	29040.9	99078.3	15.19	8.24	-2,355	1,278	-1,077
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99907.6	5.5	99905.7	0.00	-13.82	0	2,142	2,142
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1278	0.1	971.5	0.00	-2,229.09	0	3,45,509	3,45,509
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82308.6	96179.5	82276	95724.3	-11.74	-163.87	-1,819	25,400	23,581
	220kV Mariani-AGBPP	NP-6888-A	AS-03	20445.2	96335.5	18414.3	96335.5	-3,249.44	0.00	-5,03,663	0	-5,03,663
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	98628.1	2.9	98528.7	2.9	-71.57	0.00	-11,093	0	-11,093
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1174.7	99997.1	1228	99997.3	38.38	0.14	5,948	-22	5,926
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	13756.3	93866.6	13777.6	93866.4	7.67	-0.07	1,189	11	1,200
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	48873.5	91360	48888.9	91359.7	5.54	-0.11	859	17	876
TOTAL												-3,92,782
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95866.8	99121.2	95873.7	99122	4.97	0.58	770	-89	681
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	551.3	99940.7	549	99940.7	-1.10	0.00	-171	0	-171
	JIRIBAM-TRF	NP-8501-A	MN-04	24535.2	12307.3	24536	12307.5	0.05	0.01	-7	2	-6
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98962.5	99898.5	98972.8	99898.5	3.71	0.00	-575	0	-575
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19737.9	382.2	19782.1	382.4	15.91	0.07	-2,466	11	-2,455
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17328.6	381.6	17372.5	381.7	15.80	0.04	-2,450	6	-2,444
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	50508.9	99428.2	50291.3	99427	-78.34	-0.43	12,142	-67	12,075
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	95772.7	21.7	95743.9	21.2	-20.74	-0.36	3,214	-56	3,158
TOTAL												10,263

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95858.2	81174.5	95910.1	81174.4	37.37	-0.07	5,792	11	5,803
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99919.2	20013.2	99852.9	20013.2	-47.74	0.00	7,399	0	7,399
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88410	90862.4	88197.4	0.00	-340.16	0	-52,725	-52,725
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87332.4	96033.9	87332.4	96033.9	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	63352.8	99954	62373.8	99954	-3,560.00	0.00	-5,51,800	0	-5,51,800
400kV BYRNIHAT-SILCHAR		NP-8371-A	ME-15	5073.9	99864	4790.3	99864	-1,031.27	0.00	-1,59,847	0	-1,59,847
TOTAL												-7,51,170
MIZORAM	132kV LAUNGQUAL-AIZWAL PG	NP-8504-A	MZ-02	35629.5	77778.1	35694.2	77971.4	23.29	69.59	-3,610	10,786	7,176
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78896.5	49661.9	78833.2	49713.2	-22.79	18.47	3,532	2,863	6,395
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69055.6	86506.6	68988.8	86493.1	-24.05	-4.86	-3,727	753	-2,974
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97302	31645.5	97382.9	31650.3	58.25	3.46	9,028	-536	8,493
TOTAL												19,089
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15430.1	7165.1	15552.8	7207.5	44.17	15.26	-6,847	2,366	-4,481
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70700.3	1713.7	70841.5	1726.6	101.66	9.29	-15,758	1,440	-14,318
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9167.4	98896.5	9071.9	98898.8	-34.38	0.83	5,329	128	5,457
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44152.1	101.3	44152.1	34.6	0.00	-24.01	0	3,722	3,722
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43606.4	96.4	43606.4	22.9	0.00	-26.46	0	4,101	4,101
TOTAL												-5,519
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97122.6	84659.8	97059.3	84659.7	-45.58	-0.07	7,064	-11	7,053
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10376.3	99635.7	10344.3	99635.6	-30.72	-0.10	-4,762	15	-4,747
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49224.5	93757.1	49209.7	93757.1	-14.21	0.00	-2,202	0	-2,202
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68609.7	72384.7	68640.8	72370.4	37.32	-17.16	5,785	2,660	8,444
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6834.7	99993	6869.5	99990.4	33.41	-2.50	-5,178	-387	-5,565
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13577.8	1.6	13722.1	5.3	138.53	3.55	-21,472	551	-20,921
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	5505.7	99994.5	6419.5	99994.6	877.25	0.10	-1,35,973	15	-1,35,959
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	2400.4	99999.6	2730	99999.6	316.42	0.00	-49,044	0	-49,044
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	689.3	99999.6	790.2	99999.6	96.86	0.00	15,014	0	15,014
132kV PK BARI (TSECL) - AGTCCPP CKT II		NP-9932-A	TR-22	597	99999.3	690.9	99999.3	90.14	0.00	13,972	0	13,972
TOTAL												-1,73,955

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल / S.M. Aimal)
 निदेशक/Director
 उप क्षेत्र वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 12-04-2021 to 18-04-2021 REV-01

for the period 12-04-2021 to 18-04-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76325	96291.1	76291.9	96290.3	-15.888	-0.384	-2,463	60	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94561.1	99200.2	94511.4	99199	-23.856	-0.576	-3,698	89	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95221.7	99821.6	95162.9	99821.6	-28.224	0	-4,375	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	96135.9	99796.1	96077.2	99796	-28.176	-0.048	-4,367	7	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90485	99993.6	90438.3	99993.6	-22.416	0	-3,474	0	0
			NP-8384-A	ME-01	95601.8	68537.4	95583	68537.4	-9.024	0	-1,399	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	1213.2	5483.2	818	5483.2	-189.696	0	-29,403	0	-17,982
			NP-9071-A	ME-16	77404	28006.9	77645.7	27938.8	116.016	-32.688	17,982	5,067	
TOTAL													-17,982
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	4155	0.1	4333.2	0.1	85.536	0	13,258	0	1,454
TOTAL			NP-6892-B	TR-06	76500.8	3360.2	76403.1	3360.2	-9.3792	0	-1,454	0	
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94594.1	99373.9	94468.9	99371.5	-60.096	-1.152	-9,315	179	0
TOTAL			NP-9947-A	NG-02	99613.3	99868.2	99397.2	99865.2	-64.83	-0.9	-10,049	140	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एच.एस.आइमोल/S.M.Aimol)
 निदेशक/Director
 उ.पु.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 19-04-2021 to 25-04-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	33,814	0
ASSAM	0	1,54,805
MANIPUR	11,650	0
MEGHALAYA	0	7,56,354
MIZORAM	30,768	0
NAGALAND	0	787
TRIPURA	0	1,95,776

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	11,844
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	530
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	1,085


 (Signature/Stamp)
 Director/Min. of Power
 Govt. of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 19-04-2021 to 25-04-2021 REV-01

								Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	90693.3	25.6	91813.6	25.6	201.65	0.00	31,256	0	31,256
	132kV Khupi-Balipara	NP-9606-A	AS-55	55252.3	79.9	54961.1	79.9	-104.83	0.00	16,249	0	16,249
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	713.9	25711.1	710.3	25711.2	-2.59	0.07	-402	-11	-413
	Nirjuli-TRF 1	NP-9661-A	AR-01	441	2093.3	441.1	2093.5	0.04	0.07	-6	11	6
	Nirjuli-TRF 2	NP-9662-A	AR-02	500.8	2007.1	500.8	2007.3	0.00	0.07	0	11	11
	132kV Lekhi-Pare	NP-9607-A	PA-01	47697.5	167.2	47907.5	167.2	100.80	0.00	-15,624	0	-15,624
	132kV Chimpu-Pare	NP-9411-A	PA-05	942	7.3	1003.1	7.3	29.33	0.00	-4,546	0	-4,546
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	58.5	0	89.6	0	29.86	0.00	4,628	0	4,628
132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	13	0.2	28.1	0.2	14.50	0.00	2,247	0	2,247	
TOTAL												33,814

[illegible]

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95873.7	99122	95883.5	99122	7.06	0.00	1,094	0	1,094
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	549	99940.7	550	99940.7	0.48	0.00	74	0	74
	JIRIBAM-TRF	NP-8501-A	MN-04	24536	12307.5	24537.3	12307.9	0.08	0.02	-12	4	-8
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98972.8	99898.5	98981.7	99898.5	3.20	0.00	-497	0	-497
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19782.1	382.4	19831.3	382.4	17.71	0.00	-2,745	0	-2,745
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17372.5	381.7	17421.7	381.7	17.71	0.00	-2,745	0	-2,745
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	50291.3	99427	50048.6	99427	-87.37	0.00	13,543	0	13,543
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	95743.9	21.2	95717.6	21.2	-18.94	0.00	2,935	0	2,935
TOTAL												11,650


(एच.एम.आइमल/S.M.Aimal)
निदेशक/Director
उपू.के.वि.स./NERPC
बिजुत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95910.1	81174.4	95914	81174.4	2.81	0.00	435	0	435
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99852.9	20013.2	99811.6	20013.4	-29.74	0.14	4,609	22	4,631
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88197.4	90862.4	88062.4	0.00	-216.00	0	-33,480	-33,480
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87332.4	96033.9	87328.1	96033.9	-6.88	0.00	1,066	0	1,066
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	62373.8	99954	61458.3	99954	-3,329.09	0.00	-5,16,009	0	-5,16,009
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	4790.3	99864	4412.4	99864	-1,374.18	0.00	-2,12,998	0	-2,12,998
TOTAL												-7,56,354
MIZORAM	132kV LAUNGQUAL-AIZWAL PG	NP-8504-A	MZ-02	35694.2	77971.4	35756.5	78324.8	22.43	127.22	-3,476	19,720	16,243
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78833.2	49713.2	78780	49799.8	-19.15	31.18	2,969	4,832	7,801
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68988.8	86493.1	68935.7	86473.1	-19.12	-7.20	-2,963	1,116	-1,847
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97382.9	31650.3	97468	31658.6	61.27	5.98	9,497	-926	8,571
TOTAL												30,768
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15552.8	7207.5	15557.7	7226	1.76	6.66	-273	1,032	759
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70841.5	1726.6	70872.1	1732.6	22.03	4.32	-3,415	670	-2,745
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9071.9	98898.8	9036.2	98897.1	-12.85	-0.61	1,992	-95	1,897
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44152.1	34.6	44152.1	40.1	0.00	1.98	0	-307	-307
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43606.4	22.9	43606.4	29.9	0.00	2.52	0	-391	-391
TOTAL												-787
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97059.3	84659.7	97058.2	84659.5	-0.79	-0.14	123	-22	100
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10344.3	99635.6	10311.7	99635.6	-31.30	0.00	-4,851	0	-4,851
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49209.7	93757.1	49200.3	93757.1	-9.02	0.00	-1,399	0	-1,399
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68640.8	72370.4	68639.2	72314.3	-1.92	-67.32	-298	10,435	10,137
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6869.5	99990.4	6946.2	99970.5	73.63	-19.10	-11,413	-2,961	-14,374
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13722.1	5.3	13893.8	25.5	164.83	19.39	-25,549	3,006	-22,543
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	6419.5	99994.6	7326.9	99994.6	871.10	0.00	-1,35,021	0	-1,35,021
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	2730	99999.6	3063.9	99999.6	320.54	0.00	-49,684	0	-49,684
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	790.2	99999.6	866.3	99999.6	73.06	0.00	11,324	0	11,324
TOTAL												-1,95,776

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एक एक) (एक एक) (एक एक)
 निदेश/Order
 राज्य/State/NEERC
 बिजली मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 19-04-2021 to 25-04-2021 REV-01

for the period 19-04-2021 to 25-04-2021 REV-07									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76325.4	96291.1	76298.7	96290.3	-12.816	-0.384	-1,986	60	0	
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94561.8	99200.2	94521.6	99199	-19.296	-0.576	-2,991	89	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	95162.9	99821.6	95097.9	99821.6	-31.2	0	-4,836	0		
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0	
			NP-8491-A	ME-05	96077.2	99796	96012	99796	-31.296	0	-4,851	0		
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90438.3	99993.6	90555.8	99993.6	56.4	0	8,742	0	7,061	
			NP-8384-A	ME-01	95583	68537.4	95488.1	68534	-45.552	-1.632	-7,061	253		
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	818	5483.2	516.6	5567.3	5567.3	-144.672	40.368	-22,424	-6,257	-18,905
			NP-9071-A	ME-16	77645.7	27938.8	77815.7	27744.1	81.6	-93.456	12,648	14,486		
TOTAL													-11,844	
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	4333.2	0.1	4489.3	0.1	74.928	0	11,614	0	1,085	
TOTAL			NP-6892-B	TR-06	76403.1	3360.2	76330.2	3360.4	-6.9984	0.0192	-1,085	-3		1,085
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94468.9	99371.5	94451.6	99371.5	-8.304	0	-1,287	0	-530	
TOTAL			NP-9947-A	NG-02	99397.2	99865.2	99408.6	99865.6	3.42	0.12	530	-19		-530

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन.एम.आइमल/J.M.Aimal)
 निदेशक/Director
 उ.पु.के.वि.अ./NUPC
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिल्लॉंग/Shillong