



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022 /7064-7086

Dt: 13th September 2022

सेवामें / To,

संलग्नसूचीके अनुसार
As per list enclosed.

**Sub: Reactive Energy under ABT regime-for the period 22.11.2021 to 19.12.2021
(4 weeks)- Reg.**

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy accountgiving details of payables/receivables with the pool and between beneficiaries in rupees for the period 22.11.2021 to 19.12.2021 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 15.5 Paise/KVARH w.e.f from 1st April 2021, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtiah Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtiah, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.

भवदीय / Yours faithfully,



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

वाणिज्य / Commercial


**Reactive Energy (VArH) Charge Statement
for the period 22-11-2021 to 28-11-2021**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	5,705	0
ASSAM	0	4,89,597
MANIPUR	0	12,820
MEGHALAYA	0	7,88,816
MIZORAM	2,796	0
NAGALAND	0	1,998
TRIPURA	0	4,152

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	4,062
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
MIZORAM	MIZORAM	0
MIZORAM	MIZORAM	0
NAGALAND	MANIPUR	28
TRIPURA	ASSAM	0



 (एस.एम.अलम/ S. M. Alam)
 डायरेक्टर/Director
 उ.पु.वि.म./NERPC
 विद्युत विभाग/Min. of Power
 शारंग शिलांग/Secy. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 22-11-2021 to 28-11-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	2683.9	25.8	3835.3	25.8	207.25	0.00	32,124	0	32,124
	132kV Khupi-Balipara	NP-9606-A	AS-55	55308.1	79.9	55466.4	79.9	56.99	0.00	-8,833	0	-8,833
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	923.4	25711.3	934	25711.3	7.63	0.00	1,183	0	1,183
	Nirjuli-TRF 1	NP-9661-A	AR-01	449.7	2220.1	449.7	2231.6	0.00	4.14	0	642	642
	Nirjuli-TRF 2	NP-9662-A	AR-02	523.2	2123.3	523.2	2143.7	0.00	7.34	0	1,138	1,138
	132kV Lekhi-Pare	NP-9607-A	PA-01	49712	167.3	49976.4	167.3	126.91	0.00	-19,671	0	-19,671
	132kV Chimpu-Pare	NP-9411-A	PA-05	1467.4	7.4	1523.6	7.4	26.98	0.00	-4,181	0	-4,181
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	272.1	0	285.8	0	13.15	0.00	2,039	0	2,039
132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	108.8	0.1	117.3	0.1	8.16	0.00	1,265	0	1,265	
TOTAL												5,705

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43863	80.2	44068.1	80.2	328.16	0.00	-50,865	0	-50,865	
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	87690.4	6862.6	88375.4	6862.6	1,096.00	0.00	-1,69,880	0	-1,69,880	
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	74892	98616.3	75050	98616.3	158.00	0.00	24,490	0	24,490	
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	77200.5	99217.6	77929.1	99217.6	728.60	0.00	1,12,933	0	1,12,933	
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	30353.6	63.9	30304.3	63.9	-78.88	0.00	12,226	0	12,226	
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	29490.6	82263.3	28976	82263.3	-370.51	0.00	-57,429	0	-57,429	
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	1706.9	2.3	1906.4	2.3	143.64	0.00	-22,264	0	-22,264	
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99421.2	88729.6	99421.1	88681.8	-0.04	-17.21	-6	2,667	2,662	
	HAF LONG CONSUMPTION	NP-8494-A	AS-11	21713.9	3240.7	21716.5	3240.7	0.47	0.00	-73	0	-73	
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	83058.8	91177.7	82933.6	91177.7	-45.07	0.00	-6,986	0	-6,986	
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	87550.4	99934.9	87438.5	99934.9	-40.28	0.00	-6,244	0	-6,244	
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0	
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0	
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	87604	99980.8	87528.2	99980.8	-27.29	0.00	-4,230	0	-4,230	
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	80432.7	99986.3	80306.2	99986.3	-45.54	0.00	-7,059	0	-7,059	
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59797.4	97571.1	59790.4	97565.1	-5.04	-4.32	-781	670	-112	
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99551.9	99838.4	99537.6	99838.4	-104.00	0.00	-16,120	0	-16,120	
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	99953.8	97928.3	99974.1	97928.3	147.64	0.00	22,884	0	22,884	
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84049	94041.7	84066	93961.1	6.12	-29.02	949	4,497	5,446	
	220kV Mariani-AGBPP	NP-6888-A	AS-03	81584.3	96335.4	80514.4	96335.4	-1,711.84	0.00	-2,65,335	0	-2,65,335	
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97084.1	1.5	96905.4	1.5	-128.66	0.00	-19,943	0	-19,943	
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	2310	606.2	2320.3	1012.4	7.42	292.46	1,149	-45,332	-44,182	
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	69411.1	98805.8	69599.4	98805.8	90.38	0.00	14,010	0	14,010	
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	91529	99969.8	91347.2	99969.8	-87.26	0.00	-13,526	0	-13,526	
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	14015.9	86158.6	14015.9	86158.6	0.00	0.00	0	0	0	
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	49028.1	82517.7	49028.1	82517.7	0.00	0.00	0	0	0	
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	6.1	2.5	6.1	2.5	0.00	0.00	0	0	0	
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	2.4	2.2	2.4	2.2	0.00	0.00	0	0	0	
	SONABIL END OF 220kV BALIPARA-1 FDR	NE-0035-A	AS-19	0	0	0	0	0.00	0.00	0	0	0	
	TOTAL												-4,89,597

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96225.6	99122.5	96227.2	99122.5	1.15	0.00	179	0	179
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	558	99939.6	553.6	99939.5	-2.11	-0.05	-327	7	-320
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	97373.5	99898.5	97089.8	99898.5	-102.13	0.00	15,830	0	15,830
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20901	384.2	20915.9	384.2	5.36	0.00	-831	0	-831
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18435.6	383.7	18449.9	383.7	5.15	0.00	-798	0	-798
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46246.8	99422.2	46167.5	99422.2	-28.55	0.00	4,425	0	4,425
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94767.4	20.3	94757	20.3	-7.49	0.00	1,161	0	1,161
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	99872	0	99900.8	0	209.45	0.00	-32,465	0	-32,465
TOTAL												-12,820


 Director
 ৰূপায়িত/Min. of Power
 ৰূপায়িত/Min. of Power
 ৰূপায়িত/Govt. of India
 ৰূপায়িত/Shillong


	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG II	NP-6880-A	ME-09	99961.8	20042	99961.8	20047.2	0.00	3.74	0	580	580
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86184.1	90862.4	86175.6	0.00	-13.60	0	-2,108	-2,108
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	86486	96033.6	86475.5	96033.6	-16.80	0.00	2,604	0	2,604
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	22114.4	99953.8	20471.3	99953.8	-5,974.91	0.00	-9,26,111	0	-9,26,111
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	5764.6	99864	6006.1	99864	878.18	0.00	1,36,118	0	1,36,118
TOTAL												-7,88,816
MIZORAM	132kV LAUNGMUAL-AIZWAL PG	NP-8504-A	MZ-02	36909.6	80658.7	36924.2	80692.9	5.26	12.31	-815	1,908	1,094
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	77492.4	50130.7	77481.2	50137.1	-4.03	2.30	625	357	982
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68685.6	86427.8	68685.9	86427.8	0.11	0.00	17	0	17
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97875.2	31664.7	97881.5	31664.7	4.54	0.00	703	0	703
TOTAL												2,796
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96111.9	82344.1	96112	82340.4	0.07	-2.66	11	413	424
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71286.3	3288	71309.6	3297.4	16.78	6.77	-2,600	1,049	-1,551
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8926.2	98534.7	8922.3	98535.1	-1.40	0.14	218	22	240
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44171.7	316.4	44171.7	326	0.00	3.46	0	-536	-536
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43621.1	317	43621.1	327.3	0.00	3.71	0	-575	-575
TOTAL												-1,998
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.8	84659.1	97040.8	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10200.1	99635	10180	99635	-19.30	0.00	-2,991	0	-2,991
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.9	72313.5	68681.9	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.6	7203.6	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26.1	14455.8	26.1	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9405.9	99994.7	9410.6	99994.8	4.51	0.10	-699	15	-684
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3836.6	99999.7	3841.9	99999.7	5.09	0.00	-789	0	-789
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1045.4	99999.6	1046.9	99999.6	1.44	0.00	223	0	223
132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	912.1	99999.3	912.7	99999.3	0.58	0.00	89	0	89	
TOTAL												-4,152

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S. M. Amini) / S. M. Amini
 निदेशक/Director
 उ.पु.रे.वि.ए./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 22-11-2021 to 28-11-2021

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75480.5	96259.4	75385.6	96259.4	-45.552	0	-7,061	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	93411.9	99149.1	93274.6	99149.1	-65.904	0	-10,215	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94422.2	99821.3	94392.7	99821.3	-14.16	0	-2,195	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95306.7	99795.8	95277.4	99795.8	-14.064	0	-2,180	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92267.3	99994.6	92246.3	99994.6	-10.08	0	-1,562	0	0
			NP-8384-A	ME-01	94344.4	68413.6	94344.4	68372.8	0	-19.584	0	3,036	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98158.8	5989.8	97967.2	5989.8	-91.968	0	-14,255	0	-4,062
			NP-9071-A	ME-16	78626.5	25044	78681.1	25044	26.208	0	4,062	0	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	0	0	0	0	0	0	0	0	0
			NP-9945-A	ME-17	99999.8	0	99935.8	99993.3	-30.72	-3.216	-4,762	498	
TOTAL													-4,062
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	7983.4	99982.9	8284.6	99982.9	144.576	0	22,409	0	0
			NP-6892-B	TR-06	76321.8	96138.5	76321.8	96138	0	-0.048	0	7	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94015.4	99333.1	94014.1	99325.8	-0.624	-3.504	-97	543	28
			NP-9947-A	NG-02	99263	99948.3	99259.9	99948.9	-0.93	0.18	-144	-28	
TOTAL													28
MIZORAM	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9496-A	MZ-18	0	0	0	0	0.00	0.00	0	0	0
	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9493-A	MZ-17	0	0	0	0	0.00	0.00	0	0	0
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Almo) / (S.M. Almo)
 Director / Director
 NEERC / NEERC
 Ministry of Power / Min. of Power
 Govt. of India / Govt. of India
 Shillong / Shillong


**Reactive Energy (VArH) Charge Statement
for the period 29-11-2021 to 05-12-2021**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	15,586	0
ASSAM	0	4,86,518
MANIPUR	0	3,248
MEGHALAYA	0	7,98,661
MIZORAM	8,409	0
NAGALAND	4,347	0
TRIPURA	0	2,053

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	6,666
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
MIZORAM	MIZORAM	0
MIZORAM	MIZORAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0



 (S.M.Ahmed) / Director
 NEERC
 Ministry of Power / Govt. of India
 Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 29-11-2021 to 05-12-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	3835.3	25.8	4776.2	25.8	169.36	0.00	26,251	0	26,251
	132kV Khupi-Balipara	NP-9606-A	AS-55	55466.4	79.9	55643.8	79.9	63.86	0.00	-9,899	0	-9,899
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	934	25711.3	934	25711.3	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	449.7	2231.6	449.7	2231.6	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	523.2	2143.7	523.2	2144.1	0.00	0.14	0	22	22
	132kV Lekhi-Pare	NP-9607-A	PA-01	49976.4	167.3	49987	167.3	5.09	0.00	-789	0	-789
	132kV Chimpu-Pare	NP-9411-A	PA-05	1523.6	7.4	1523.6	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	285.8	0	285.8	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	117.3	0.1	117.3	0.1	0.00	0.00	0	0	0
TOTAL												15,586

ASSAM	220kV BTSS-II - SALAKATI	NP-9435-A	AS-31	44068.1	80.2	44243	80.2	279.84	0.00	-43,375	0	-43,375	
	220kV BTSS-I - SALAKATI	NP-9434-A	AS-30	88375.4	6862.6	88985.8	6862.6	976.64	0.00	-1,51,379	0	-1,51,379	
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	75050	98616.3	75207.7	98616.3	157.70	0.00	24,444	0	24,444	
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	77929.1	99217.6	78255.7	99217.6	326.60	0.00	50,623	0	50,623	
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	30304.3	63.9	30364.8	63.9	96.80	0.00	-15,004	0	-15,004	
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	28976	82263.3	28791.5	82263.3	-132.84	0.00	-20,590	0	-20,590	
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	1906.4	2.3	2000.3	2.3	67.61	0.00	-10,479	0	-10,479	
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99421.1	88681.8	99421.1	88635.5	0.00	-16.67	0	2,584	2,584	
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21716.5	3240.7	21717.3	3240.7	0.14	0.00	-22	0	-22	
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	82933.6	91177.7	82887.4	91177.7	-16.63	0.00	-2,578	0	-2,578	
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	87438.5	99934.9	87398.5	99934.9	-14.40	0.00	-2,232	0	-2,232	
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0	
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0	
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	87528.2	99980.8	87509.8	99980.8	-6.62	0.00	-1,027	0	-1,027	
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	80306.2	99986.3	80256.7	99986.3	-17.82	0.00	-2,762	0	-2,762	
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59790.4	97565.1	59790.4	97545.2	0.00	-14.33	0	2,221	2,221	
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99537.6	99838.4	99520.6	99838.4	-123.64	0.00	-19,164	0	-19,164	
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	99974.1	97928.3	99987.8	97928.3	99.64	0.00	15,444	0	15,444	
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84066	93961.1	84067.7	93896.7	0.61	-23.18	95	3,594	3,688	
	220kV Mariani-AGBPP	NP-6888-A	AS-03	80514.4	96335.4	79335.1	96335.4	-1,886.88	0.00	-2,92,466	0	-2,92,466	
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	96905.4	1.5	96905.3	1.5	-0.07	0.00	-11	0	-11	
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	2320.3	1012.4	2340.2	1257.4	14.33	176.40	2,221	-27,342	-25,121	
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	69599.4	98805.8	69648.4	98805.8	23.52	0.00	3,646	0	3,646	
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	91347.2	99969.8	91306.5	99969.8	-19.54	0.00	-3,028	0	-3,028	
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	14015.9	86158.6	14015.9	86158.6	0.00	0.00	0	0	0	
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	49028.1	82517.7	49028.1	82516.4	0.00	-0.47	0	73	73	
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	6.1	2.5	6.1	2.5	0.00	0.00	0	0	0	
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	2.4	2.2	2.4	2.2	0.00	0.00	0	0	0	
	SONABIL END OF 220kV BALIPARA-1 FDR	NE-0035-A	AS-19	0	0	0	0	0.00	0.00	0	0	0	
	TOTAL												-4,86,518

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96227.2	99122.5	96227.2	99122.4	0.00	-0.07	0	11	11
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	553.6	99939.5	553.6	99939.3	0.00	-0.10	0	15	15
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	97089.8	99898.5	96983.1	99898.5	-38.41	0.00	5,954	0	5,954
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20915.9	384.2	20917.1	384.2	0.43	0.00	-67	0	-67
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18449.9	383.7	18451	383.7	0.40	0.00	-61	0	-61
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46167.5	99422.2	46164.5	99422.2	-1.08	0.00	167	0	167
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94757	20.3	94756.2	20.3	-0.58	0.00	89	0	89
	400kV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
400kV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	99900.8	0	99909.1	0	60.36	0.00	-9,356	0	-9,356	
TOTAL												-3,248


 Director/Director
 उद्योग विभाग/Min. of Power
 भारत सरकार/Govt. of India
 Shillong

	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG II	NP-6880-A	ME-09	99961.8	20047.2	99961.8	20054.1	0.00	4.97	0	770	770
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86175.6	90862.4	86129	0.00	-74.56	0	-11,557	-11,557
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	86475.5	96033.6	86475.5	96033.6	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	20471.3	99953.8	18832.4	99953.8	-5,959.64	0.00	-9,23,744	0	-9,23,744
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	6006.1	99864	6247.1	99864	876.36	0.00	1,35,836	0	1,35,836
TOTAL												-7,98,661
MIZORAM	132kV LAUNGMAAL-AIZWAL PG	NP-8504-A	MZ-02	36924.2	80692.9	36924.2	80811.8	0.00	42.80	0	6,635	6,635
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	77481.2	50137.1	77481.1	50147.7	-0.04	3.82	6	591	597
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68685.9	86427.8	68685.2	86427.8	-0.25	0.00	-39	0	-39
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97881.5	31664.7	97892.4	31664.7	7.85	0.00	1,216	0	1,216
	TOTAL											8,409
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96112	82340.4	96112	82337.8	0.00	-1.87	0	290	290
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71309.6	3297.4	71309.6	3356.7	0.00	42.70	0	6,618	6,618
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8922.3	98535.1	8922.2	98543.2	-0.04	2.92	6	452	458
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44171.7	326	44171.7	352.6	0.00	9.58	0	-1,484	-1,484
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43621.1	327.3	43621.1	354.8	0.00	9.90	0	-1,535	-1,535
TOTAL												4,347
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.8	84659.1	97040.8	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10180	99635	10169	99635	-10.56	0.00	-1,637	0	-1,637
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49179.4	93755.2	-3.36	0.00	-521	0	-521
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.9	72313.5	68681.9	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR - SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.6	7203.6	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26.1	14455.8	26.1	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9410.6	99994.8	9410.2	99994.8	-0.38	0.00	60	0	60
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3841.9	99999.7	3842.4	99999.7	0.48	0.00	-74	0	-74
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1046.9	99999.6	1047.3	99999.6	0.38	0.00	60	0	60
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	912.7	99999.3	913.1	99999.3	0.38	0.00	60	0	60
TOTAL												-2,053

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Sd/Dr. M. A. A. A. A.)
 Director
 J.S. & P. S. /NERPC
 Ministry of Power
 New Delhi, Govt. of India
 Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 29-11-2021 to 05-12-2021


Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75385.6	96259.4	75301.8	96259.4	-40.224	0	-6.235	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	0
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	93274.6	99149.1	93152.7	99149.1	-58.512	0	-9.069	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94392.7	99821.3	94378.6	99821.3	-6.768	0	-1.049	0	0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95277.4	99795.8	95263.4	99795.8	-6.72	0	-1.042	0	0
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92246.3	99994.6	92147.7	99994.6	-47.328	0	-7.336	0	0
			NP-8384-A	ME-01	94344.4	68372.8	94344.4	68355	0	-8.544	0	1,324	0
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	97967.2	5989.8	97699.9	5989.8	-128.304	0	-19.887	0	0
			NP-9071-A	ME-16	78681.1	25044	78770.7	25044	43.008	0	6,666	0	0
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	99809.4	99999.6	99345.1	99999.6	-167.148	0	-25,908	0	0
			NP-9945-A	ME-17	99935.8	99993.3	99855.2	99971.9	-38.688	-10.272	-5.997	1,592	0
TOTAL													-6,666
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	8284.6	99982.9	8415.1	99982.9	62.64	0	9,709	0	0
			NP-6892-B	TR-06	76321.8	96138	76321.8	96137.6	0	-0.0384	0	6	0
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94014.1	99325.8	94014.1	99323.3	0	-1.2	0	186	0
			NP-9947-A	NG-02	99259.9	99948.9	99259.9	99936.5	0	-3.72	0	577	0
TOTAL													0
MIZORAM	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9496-A	MZ-18	0	0	0	0	0.00	0.00	0	0	0
	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9493-A	MZ-17	0	0	0	0	0.00	0.00	0	0	0
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Aisoo) S.M. Aisoo
 Director
 J.S. R. P. M. /NERPC
 बिहार नगर/Min. of Power
 बिहार राज्य/Govt. of India
 बिहार/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 06-12-2021 to 12-12-2021**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	20,680	0
ASSAM	0	4,59,818
MANIPUR	0	39,753
MEGHALAYA	0	8,14,521
MIZORAM	14,011	0
NAGALAND	0	9,921
TRIPURA	0	26,196

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	6,971
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
MIZORAM	MIZORAM	0
MIZORAM	MIZORAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0



 (ए.एम.शर्मा/S.M.Ahmed)
 निदेशक/Director
 उ.पु.वे.वि.न./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 06-12-2021 to 12-12-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	4776.2	25.8	6071.5	25.8	233.15	0.00	36,139	0	36,139
	132kV Khupi-Balipara	NP-9606-A	AS-55	55643.8	79.9	55814	79.9	61.27	0.00	-9,497	0	-9,497
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	934	25711.3	934.2	25711.3	0.14	0.00	22	0	22
	Nirjuli-TRF 1	NP-9661-A	AR-01	449.7	2231.6	449.7	2231.6	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	523.2	2144.1	523.2	2144.2	0.00	0.04	0	6	6
	132kV Lekhi-Pare	NP-9607-A	PA-01	49987	167.3	50068.9	167.3	39.31	0.00	-6,093	0	-6,093
	132kV Chimpu-Pare	NP-9411-A	PA-05	1523.6	7.4	1535	7.4	5.47	0.00	-848	0	-848
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	285.8	0	290	0	4.03	0.00	625	0	625
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	117.3	0.1	119.5	0.1	2.11	0.00	327	0	327
TOTAL												20,680

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	44243	80.2	44462.1	80.2	350.56	0.00	-54,337	0	-54,337	
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	88985.8	6862.6	89469.7	6862.6	774.24	0.00	-1,20,007	0	-1,20,007	
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	75207.7	98616.3	75508.3	98616.3	300.60	0.00	46,593	0	46,593	
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	78255.7	99217.6	78952.3	99217.6	696.60	0.00	1,07,973	0	1,07,973	
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	30364.8	63.9	30290.6	63.9	-118.72	0.00	18,402	0	18,402	
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	28791.5	82263.3	28138.8	82263.3	-469.94	0.00	-72,841	0	-72,841	
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	2000.3	2.3	2149.4	2.3	107.35	0.00	-16,640	0	-16,640	
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99421.1	88635.5	99422.6	88592	0.54	-15.66	84	2,427	2,511	
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21717.3	3240.7	21719.3	3240.7	0.36	0.00	-56	0	-56	
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	82887.4	91177.7	82698.8	91177.7	-67.90	0.00	-10,524	0	-10,524	
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	87398.5	99934.9	87216.8	99934.9	-65.41	0.00	-10,139	0	-10,139	
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0	
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0	
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	87509.8	99980.8	87379.9	99980.8	-46.76	0.00	-7,248	0	-7,248	
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	80256.7	99986.3	80084.9	99986.3	-61.85	0.00	-9,586	0	-9,586	
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59790.4	97545.2	59759.7	97534.1	-22.10	-7.99	-3,426	1,239	-2,187	
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99520.6	99838.4	99503.7	99838.4	-122.91	0.00	-19,051	0	-19,051	
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	99987.8	97928.3	13.2	97928.3	184.73	0.00	28,633	0	28,633	
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84067.7	93896.7	84067.6	93859	-0.04	-13.57	-6	2,104	2,098	
	220kV Mariani-AGBPP	NP-6888-A	AS-03	79335.1	96335.4	77998.7	96335.4	-2,138.24	0.00	-3,31,427	0	-3,31,427	
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	96905.3	1.5	96885.7	1.5	-14.11	0.00	-2,187	0	-2,187	
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	2340.2	1257.4	2340.5	2277.7	0.22	734.62	33	-1,13,865	-1,13,832	
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	69648.4	98805.8	69718	98805.8	33.41	0.00	5,178	0	5,178	
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	91306.5	99969.8	91293.3	99784.6	-6.34	-88.90	-982	13,779	12,797	
	132kV PavoI - BNC Ckt I	NP-9680-A	AM-12	14015.9	86158.6	14017.6	86158.6	0.61	0.00	95	0	95	
	132kV PavoI - BNC Ckt II	NP-8801-A	AM-13	49028.1	82516.4	49028.3	82516.4	0.07	0.00	11	0	11	
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	6.1	2.5	98861.7	2.5	-525.09	0.00	81,389	0	81,389	
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	2.4	2.2	99994.3	2.2	-29.45	0.00	4,565	0	4,565	
	SONABIL END OF 220kV BALIPARA-1 FDR	NE-0035-A	AS-19	0	0	0	0	0.00	0.00	0	0	0	
	TOTAL												-4,59,818

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96227.2	99122.4	96228.6	99122.4	1.01	0.00	156	0	156
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	553.6	99939.3	548.8	99939.3	-2.30	0.00	-357	0	-357
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	96983.1	99898.5	97110.5	99898.5	45.86	0.00	-7,109	0	-7,109
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20917.1	384.2	20933.4	384.2	5.87	0.00	-910	0	-910
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18451	383.7	18466	383.7	5.40	0.00	-837	0	-837
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46164.5	99422.2	46100.3	99422.2	-23.11	0.00	3,582	0	3,582
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94756.2	20.3	94747.2	20.3	-6.48	0.00	1,004	0	1,004
	400kV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
400kV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	99909.1	0	99940.4	0	227.64	0.00	-35,284	0	-35,284	
TOTAL												-39,753


 Director/ Director
 उ.सू.नि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 New Delhi/शुआलिंग

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95464.8	81162.3	95464.7	81162.1	-0.07	-0.14	-11	22	11
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99961.8	20054.1	99961.8	20064.7	0.00	7.63	0	1,183	1,183
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86129	90862.4	86104.1	0.00	-39.84	0	-6,175	-6,175
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	86475.5	96033.6	86450	96033.6	-40.80	0.00	6,324	0	6,324
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	18832.4	99953.8	17132.9	99953.8	-6,180.00	0.00	-9,57,900	0	-9,57,900
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	6247.1	99864	6499.1	99864	916.36	0.00	1,42,036	0	1,42,036
TOTAL												-8,14,521
MIZORAM	132kV LAUNGMJAL-AIZWAL PG	NP-8504-A	MZ-02	36924.2	80811.8	36980	80824	20.09	4.39	-3,114	681	-2,433
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	77481.1	50147.7	77209.5	50149.6	-97.78	0.68	15,155	106	15,261
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68685.2	86427.8	68697.8	86427.8	4.54	0.00	703	0	703
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97892.4	31664.7	97896.7	31664.7	3.10	0.00	480	0	480
TOTAL												14,011
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96112	82337.8	96112.2	82334.8	0.14	-2.16	22	335	357
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71309.6	3356.7	71370.5	3360.9	43.85	3.02	-6,796	469	-6,328
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8922.2	98543.2	8917.1	98543.4	-1.84	0.07	285	11	296
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44171.7	352.6	44171.7	390.2	0.00	13.54	0	-2,098	-2,098
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43621.1	354.8	43621.1	393.3	0.00	13.86	0	-2,148	-2,148
TOTAL												-9,921
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.8	84659.1	97040.6	84659.1	-0.14	0.00	22	0	22
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10169	99635	10047.2	99635	-116.93	0.00	-18,124	0	-18,124
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49179.4	93755.2	49167.4	93755.2	-11.52	0.00	-1,786	0	-1,786
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.9	72313.5	68681.9	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR - SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.6	7203.6	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26.1	14455.8	26.1	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9410.2	99994.8	9443.9	99994.8	32.35	0.00	-5,015	0	-5,015
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3842.4	99999.7	3859.7	99999.7	16.61	0.00	-2,574	0	-2,574
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1047.3	99999.6	1048.9	99999.6	1.54	0.00	238	0	238
132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	913.1	99999.3	920.1	99999.3	6.72	0.00	1,042	0	1,042	
TOTAL												-26,196

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director/Min. of Power
 Assam/NERPC
 Director/Min. of Power
 Assam/NERPC
 Director/Min. of Power
 Assam/NERPC

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 06-12-2021 to 12-12-2021


Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75301.8	96259.4	75226.1	96259.4	-36.336	0	-5.632	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	93152.7	99149.1	93048	99149.1	-50.256	0	-7.790	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94378.6	99821.3	94347.7	99821.3	-14.832	0	-2.299	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95263.4	99795.8	95232.6	99795.8	-14.784	0	-2.292	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92147.7	99994.6	92208.8	99994.6	29.328	0	4.546	0	0
			NP-8384-A	ME-01	94344.4	68355	94344.4	68159.7	0	-93.744	0	14,530	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	97699.9	5989.8	97437.1	5989.8	-126.144	0	-19,552	0	-6,971
			NP-9071-A	ME-16	78770.7	25044	78864.4	25042.8	44.976	-0.576	6,971	89	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	99345.1	99999.6	98857.3	99999.6	-175.608	0	-27,219	0	0
			NP-9945-A	ME-17	99855.2	99971.9	99739.5	99959	-55.536	-6.192	-8.608	960	
TOTAL													-6,971
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	8415.1	99982.9	8786.3	99982.9	178.176	0	27,617	0	0
			NP-6892-B	TR-06	76321.8	96137.6	76321.8	96131.2	0	-0.6144	0	95	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94014.1	99323.3	94011.3	99321.6	-1.344	-0.816	-208	126	0
			NP-9947-A	NG-02	99259.9	99936.5	99253.9	99935.6	-1.8	-0.27	-279	42	
TOTAL													0
MIZORAM	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9496-A	MZ-18	1.9	99999.9	99970.8	99999.7	-11.196	-0.072	-1,735	11	0
			NP-9565-A	MZ-15	99979.5	98668.7	99979.5	98668.7	0	0	0	0	
	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9493-A	MZ-17	99994.6	99979.6	99979.3	99979.5	-5.508	-0.036	-854	6	0
			NP-9497-A	MZ-16	99969.5	98713.4	99967.8	98713.3	-0.612	-0.036	-95	6	
TOTAL												0	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Anand) / S.M. Anand
 Director / Director
 J.P. & P. / J.P. & P.
 Director / Min. of Power
 Govt. of India
 Shillong / Shillong


**Reactive Energy (VArH) Charge Statement
for the period 13-12-2021 to 19-12-2021**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	13,943	0
ASSAM	0	4,23,359
MANIPUR	0	43,002
MEGHALAYA	0	7,26,666
MIZORAM	16,852	0
NAGALAND	30,244	0
TRIPURA	0	5,595

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	13,377
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	1,168
MEGHALAYA	ASSAM	0
MIZORAM	MIZORAM	0
MIZORAM	MIZORAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0



 (J.M. Abno) J.M. Abno
 Director/Director
 उद्योग विभाग/NERPC
 बिजली विभाग/Min. of Power
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 13-12-2021 to 19-12-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	6071.5	25.8	7259.7	25.8	213.88	0.00	33,151	0	33,151
	132kV Khupi-Balipara	NP-9606-A	AS-55	55814	79.9	56055.4	79.9	86.90	0.00	-13,470	0	-13,470
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	934.2	25711.3	945.3	25711.3	7.99	0.00	1,239	0	1,239
	Nirjuli-TRF 1	NP-9661-A	AR-01	449.7	2231.6	449.7	2237.5	0.00	2.12	0	329	329
	Nirjuli-TRF 2	NP-9662-A	AR-02	523.2	2144.2	523.2	2159.4	0.00	5.47	0	848	848
	132kV Lekhi-Pare	NP-9607-A	PA-01	50068.9	167.3	50186.9	167.3	56.64	0.00	-8,779	0	-8,779
	132kV Chimpu-Pare	NP-9411-A	PA-05	1535	7.4	1564.2	7.4	14.02	0.00	-2,172	0	-2,172
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	290	0	303.1	0	12.58	0.00	1,949	0	1,949
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	119.5	0.1	125.2	0.1	5.47	0.00	848	0	848
TOTAL												13,943

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	44462.1	80.2	44650.5	80.2	301.44	0.00	-46,723	0	-46,723	
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	89469.7	6862.6	89786	6862.6	506.08	0.00	-78,442	0	-78,442	
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	75508.3	98616.3	75717.3	98616.3	209.00	0.00	32,395	0	32,395	
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	78952.3	99217.6	79473.8	99217.6	521.50	0.00	80,833	0	80,833	
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	30290.6	63.9	30402.9	63.9	179.68	0.00	-27,850	0	-27,850	
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	28138.8	82263.3	27774.8	82263.3	-262.08	0.00	-40,622	0	-40,622	
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	2149.4	2.3	2246.3	2.3	69.77	0.00	-10,814	0	-10,814	
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99422.6	88592	99420.5	88547.4	-0.76	-16.06	-117	2,489	2,372	
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21719.3	3240.7	21720.6	3240.7	0.23	0.00	-36	0	-36	
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	82698.8	91177.7	82596.7	91177.7	-36.76	0.00	-5,697	0	-5,697	
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	87216.8	99934.9	87118.1	99934.9	-35.53	0.00	-5,507	0	-5,507	
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0	
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0	
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	87379.9	99980.8	87316.2	99980.8	-22.93	0.00	-3,554	0	-3,554	
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	80084.9	99986.3	79996.2	99986.3	-31.93	0.00	-4,949	0	-4,949	
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59759.7	97534.1	59750.6	97496	-6.55	-27.43	-1,016	4,252	3,236	
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99503.7	99838.4	99477.2	99838.4	-192.73	0.00	-29,873	0	-29,873	
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	13.2	97928.3	39.9	97928.3	194.18	0.00	30,098	0	30,098	
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84067.6	93859	84036.9	93821.3	-11.05	-13.57	-1,713	2,104	391	
	220kV Mariani-AGBPP	NP-6888-A	AS-03	77998.7	96335.4	76526.4	96335.4	-2,355.68	0.00	-3,65,130	0	-3,65,130	
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	96885.7	1.5	96872.5	1.5	-9.50	0.00	-1,473	0	-1,473	
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	2340.5	2277.7	2358.2	2804.3	12.74	379.15	1,975	-58,769	-56,793	
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	0	0	0	0	0.00	0.00	0	0	0	
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	0	0	0	0	0.00	0.00	0	0	0	
	132kV PavoI - BNC Ckt I	NP-9680-A	AM-12	14017.6	86158.6	14039	86158.6	7.70	0.00	1,194	0	1,194	
	132kV PavoI - BNC Ckt II	NP-8801-A	AM-13	49028.3	82516.4	49041.3	82516.4	4.68	0.00	725	0	725	
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	99861.7	2.5	99745.9	2.5	-421.09	0.00	65,269	0	65,269	
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	99994.3	2.2	99927.6	2.2	-242.55	0.00	37,595	0	37,595	
	SONABIL END OF 220kV BALIPARA-1 FDR	NE-0035-A	AS-19	5.7	99998.7	0	0	0.00	0.00	0	0	0	
	TOTAL												-4,23,359

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96228.6	99122.4	96230.6	99122.4	1.44	0.00	223	0	223
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	548.8	99939.3	543.8	99939.3	-2.40	0.00	-372	0	-372
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	97110.5	99898.5	97185.6	99898.5	27.04	0.00	-4,191	0	-4,191
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20933.4	384.2	20947	384.2	4.90	0.00	-759	0	-759
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18466	383.7	18478.7	383.7	4.57	0.00	-709	0	-709
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46100.3	99422.2	46061.6	99422.2	-13.93	0.00	2,159	0	2,159
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94747.2	20.3	94736.2	20.3	-7.92	0.00	1,228	0	1,228
	400kV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
400kV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	99940.4	0	99976.4	0	261.82	0.00	-40,582	0	-40,582	
TOTAL												-43,002


 M. M. Ahmed / S.M.Ahmed
 Director/Director
 NEERC
 Director/Director
 NEERC
 Director/Director
 NEERC
 Director/Director
 NEERC


Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95464.7	81162.1	95464.5	81154.5	-0.14	-5.47	-22	848	826
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99961.8	20064.7	99961.8	20102.6	0.00	27.29	0	4,230	4,230
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86104.1	90862.4	86044.8	0.00	-94.88	0	-14,706	-14,706
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	86450	96033.6	86407.1	96033.6	-68.64	0.00	10,639	0	10,639
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	17132.9	99953.8	15571.2	99953.8	-5,678.91	0.00	-8,80,231	0	-8,80,231
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	6499.1	99864	6769.8	99864	984.36	0.00	1,52,576	0	1,52,576
TOTAL												-7,26,666
MIZORAM	132kV LAUNGMJAL-AIZWAL PG	NP-8504-A	MZ-02	36980	80824	37026.7	80929.1	16.81	37.84	-2,606	5,865	3,259
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	77209.5	50149.6	77002.1	50169.3	-74.66	7.09	11,573	1,099	12,672
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68697.8	86427.8	68728.1	86427.8	10.91	0.00	1,691	0	1,691
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97896.7	31664.7	97889.8	31664.7	-4.97	0.00	-770	0	-770
TOTAL												16,852
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96112.2	82334.8	96112.2	82113.2	0.00	-159.55	0	24,731	24,731
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71370.5	3360.9	71382.7	3543.2	8.78	131.26	-1,362	20,345	18,983
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8917.1	98543.4	8911.8	98427.2	-1.91	-41.83	296	-6,484	-6,188
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44171.7	390.2	44171.7	455.6	0.00	23.54	0	-3,649	-3,649
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43621.1	393.3	43621.1	458.4	0.00	23.44	0	-3,633	-3,633
TOTAL												30,244
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.6	84659.1	97041	84659.1	0.29	0.00	-45	0	-45
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10047.2	99635	10010.5	99635	-35.23	0.00	-5,461	0	-5,461
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49167.4	93755.2	49167.1	93755.2	-0.29	0.00	-45	0	-45
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.9	72313.5	68681.9	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	0	0	0	0	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9443.9	99994.8	9444.3	99994.7	0.38	-0.10	-60	-15	-74
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3859.7	99999.7	3869.5	99999.7	9.41	0.00	-1,458	0	-1,458
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1048.9	99999.6	1053	99999.6	3.94	0.00	610	0	610
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	920.1	99999.3	926	99999.3	5.66	0.00	878	0	878
TOTAL												-5,595

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Ahmad) / Director
 उद्योग विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 13-12-2021 to 19-12-2021


Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75226.1	96259.4	75157.5	96259.4	-32.928	0	-5,104	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	0
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	93048	99149.1	92948.9	99149.1	-47.568	0	-7,373	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94347.7	99821.3	94332.5	99821.3	-7.296	0	-1,131	0	0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95232.6	99795.8	95217.5	99795.8	-7.248	0	-1,123	0	0
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92208.8	99994.6	92289.1	99994.6	38.544	0	5,974	0	0
			NP-8384-A	ME-01	94344.4	68159.7	94344.4	67989.8	0	-81.552	0	12,641	0
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	97437.1	5989.8	97079.5	5989.8	-171.648	0	-26,605	0	-13,377
			NP-9071-A	ME-16	78864.4	25042.8	79044.2	25041.5	86.304	-0.624	13,377	97	0
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	98857.3	99999.6	98246.3	99999.6	-219.96	0	-34,094	0	0
			NP-9945-A	ME-17	99739.5	99959	99726.8	99923.8	-6.096	-16.896	-945	2,619	0
TOTAL													-13,377
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	8786.3	99982.9	8968.4	99982.9	87.408	0	13,548	0	0
			NP-6892-B	TR-06	76321.8	96131.2	76321.8	95870.9	0	-24.9888	0	3,873	0
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94011.3	99321.6	94008.7	99337.3	-1.248	7.536	-193	-1,168	-1,168
			NP-9947-A	NG-02	99253.9	99935.6	99252.2	99798.7	-0.51	-41.07	-79	6,366	0
TOTAL													-1,168
MIZORAM	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9496-A	MZ-18	99970.8	99999.7	99959.1	99996.3	-4.212	-1.224	-653	190	0
			NP-9565-A	MZ-15	99979.5	98668.7	99979.5	98668.7	0	0	0	0	0
	132 KV SIHHMUI-MELRIAT	MIZORAM	NP-9493-A	MZ-17	99979.3	99979.5	99973.6	99977.6	-2.052	-0.684	-318	106	0
			NP-9497-A	MZ-16	99967.8	98713.3	99964.8	98712.8	-1.08	-0.18	-167	28	0
TOTAL												0	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVAH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S. M. Almol) S. M. Almol
 Director/Director
 न. उ. वि. वि. /NERPC
 नि. उ. वि. वि. /Min. of Power
 भारत सरकार /Govt. of India
 शिलांग /Shillong