



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022 / 2273 - 2295

Dt: 1st August 2022

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy under ABT regime-for the period 05.07.2021 to 01.08.2021 (4 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy accounting details of payables/receivables with the pool and between beneficiaries in rupees for the period 05.07.2021 to 01.08.2021 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 15.5 Paise/KVARH w.e.f from 1st April 2021, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.

भवदीय / Yours faithfully,



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

वाणिज्य / Commercial

Reactive Energy (VArH) Charge Statement
for the period 05-07-2021 to 11-07-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	869	0
ASSAM	0	3,92,726
MANIPUR	5,824	0
MEGHALAYA	0	5,38,786
MIZORAM	9,469	0
NAGALAND	8,370	0
TRIPURA	0	14,523

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	3,951
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (স্বাক্ষর/Signature)
 Director/Director
 সচিব/Secretary
 বিদ্যুৎ সচিব/Min. of Power
 बिजली सचिव/Min. of India
 Dibrugarh/Dibrugarh

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 05-07-2021 to 11-07-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97460	25.8	97481	25.8	3.78	0.00	586	0	586
	132kV Khupi-Balipara	NP-9606-A	AS-55	54827.7	79.9	54806.7	79.9	-7.56	0.00	1,172	0	1,172
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	769.7	25711.2	770.3	25711.2	0.43	0.00	67	0	67
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2123.4	442.1	2124.6	0.00	0.43	0	67	67
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2034.6	502.2	2035.6	0.00	0.36	0	56	56
	132kV Lekhi-Pare	NP-9607-A	PA-01	48538.5	167.3	48553.3	167.3	7.10	0.00	-1,101	0	-1,101
	132kV Chimpur-Pare	NP-9411-A	PA-05	1178.7	7.4	1181.6	7.4	1.39	0.00	-216	0	-216
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	159.1	0	160.2	0	1.06	0.00	164	0	164
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	60.2	0.2	60.7	0.2	0.48	0.00	74	0	74
TOTAL												869

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43329	75.8	43329	75.8	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	78859.4	6862.6	78920.6	6862.6	97.92	0.00	-15,178	0	-15,178
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72738.1	98617.5	72738.8	98617.5	0.70	0.00	109	0	109
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73325.1	99218	73327	99218	1.90	0.00	295	0	295
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27604.6	63.9	27614.2	63.9	15.36	0.00	-2,381	0	-2,381
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	39227.3	82267.8	38785.8	82267.8	-317.88	0.00	-49,271	0	-49,271
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	2094.4	7690	2099.8	7690.1	3.89	0.07	-603	11	-591
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99441.2	93143.1	99441.2	92901.5	0.00	-86.98	0	13,481	13,481
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21075.9	3240.7	21132.8	3240.7	10.24	0.00	-1,588	0	-1,588
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84982	91177.9	84917.4	91177.9	-23.26	0.00	-3,605	0	-3,605
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	89372.9	99935.1	89311.7	99935.1	-22.03	0.00	-3,415	0	-3,415
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	90031.1	99981	89958.5	99981	-26.14	0.00	-4,051	0	-4,051
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	83896.5	99986.4	83791.8	99986.4	-37.69	0.00	-5,842	0	-5,842
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29089.1	99352	29089.8	99479.4	0.25	45.86	-39	7,109	7,070
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99962.6	99838.4	99989.2	99838.4	193.45	0.00	29,985	0	29,985
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	97931.9	0.1	97931.9	0.00	0.00	0	0	0
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82609.4	93959.9	82639.2	93673	10.73	-103.28	1,663	16,009	17,672
	220kV Mariani-AGBPP	NP-6888-A	AS-03	99712.8	96335.5	98041.1	96335.5	-2,674.72	0.00	-4,14,582	0	-4,14,582
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97942.9	1.7	97894.7	1.7	-34.70	0.00	-5,379	0	-5,379
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1797.5	96.4	1807.7	96.4	7.34	0.00	1,138	0	1,138
	132kV PavoI - BNC Ckt I	NP-9680-A	AM-12	13935.9	93335.4	13935.9	92970.4	0.00	-131.40	0	20,367	20,367
	132kV PavoI - BNC Ckt II	NP-8801-A	AM-13	48989.4	90600.5	48989.4	90187.6	0.00	-148.64	0	23,040	23,040
TOTAL												-3,92,726

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96074.3	99122	96083.3	99122	6.48	0.00	1,004	0	1,004
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	524.5	99940.7	522.1	99940.7	-1.15	0.00	-179	0	-179
	JIRIBAM-TRF	NP-8501-A	MN-04	24543.9	12309.2	24543.9	12310.2	0.00	0.06	0	9	9
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98943.4	99898.5	98943.9	99898.5	0.18	0.00	-28	0	-28
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20335.6	382.4	20360.8	382.4	9.07	0.00	-1,406	0	-1,406
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17915.1	381.8	17939.1	381.8	8.64	0.00	-1,339	0	-1,339
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47642.4	99426.8	47542.1	99426.8	-36.11	0.00	5,597	0	5,597
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	95233.4	21.3	95214	21.3	-13.97	0.00	2,165	0	2,165
TOTAL												5,824


 (Signature of Director)
 Director/Secretary
 Ministry of Power
 Govt. of India
 New Delhi

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95608.9	81174.4	95583.1	81174.4	-18.58	0.00	-2,879	0	-2,879
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99928.8	20013.4	99938	20013.4	6.62	0.00	-1,027	0	-1,027
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	87465.3	90862.4	87197	0.00	-429.28	0	-66,538	-66,538
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87287.4	96033.7	87286.1	96033.7	-2.08	0.00	322	0	322
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	49256.9	99953.9	48684.7	99953.9	-2,080.73	0.00	-3,22,513	0	-3,22,513
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	3907.5	99864	3648.2	99864	-942.91	0.00	-1,46,151	0	-1,46,151
TOTAL												-5,38,786

MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35823.7	79609.1	35891.4	79780.1	24.37	61.56	-3,778	9,542	5,764
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78673	49968.4	78628.7	49966.6	-15.95	-0.65	2,472	-100	2,372
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68838.7	86433.9	68856.5	86428	6.41	-2.12	993	329	1,322
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97750.3	31664.5	97750.6	31664.7	0.22	0.14	33	-22	11
TOTAL												9,469

NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15659.8	7782.7	15662.2	7859.1	0.86	27.50	-134	4,263	4,129
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71067.7	1981.6	71072.5	2035.8	3.46	39.02	-536	6,049	5,513
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8815.3	98834.4	8806.4	98800.3	-3.20	-12.28	497	-1,903	-1,406
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44166.9	235.4	44168.1	235.4	0.43	0.00	67	0	67
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43617.1	236.1	43618.3	236.1	0.43	0.00	67	0	67
TOTAL												8,370

TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84658.5	97040.7	84658.5	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10245.7	99635.1	10245.6	99635.1	-0.10	0.00	-15	0	-15
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49181.6	93755.2	49181.6	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68680.6	72313.5	68680.6	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7201.5	99970.5	7201.5	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14452.5	25.9	14452.5	25.9	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9109.3	99994.7	9202.7	99994.7	89.66	0.00	-13,898	0	-13,898
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3672.4	99999.7	3704.1	99999.7	30.43	0.00	-4,717	0	-4,717
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1003.1	99999.6	1017.5	99999.6	13.82	0.00	2,143	0	2,143
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	880.2	99999.3	893.4	99999.3	12.67	0.00	1,964	0	1,964
TOTAL												-14,523

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director
 Tripura
 State Electricity Board
 Agartala

for the period 05-07-2021 to 11-07-2021

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) NA' means meter reading not available.

(एस.एस.आइ.मोल/ S.M.Aimol)
 निदेशक/Director
 न.पु.वै.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलोंग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 12-07-2021 to 18-07-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	1	0
ASSAM	0	5,68,816
MANIPUR	18,474	0
MEGHALAYA	0	5,77,773
MIZORAM	173	0
NAGALAND	10,390	0
TRIPURA	0	11,826

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	1,060
MEGHALAYA	ASSAM	12,209
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (Signature/Name)
 Director/Secretary
 P.W.D./P.W.D.C.
 P.W.D. Deptt./Govt. of India
 Dispur/Dispur

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 12-07-2021 to 18-07-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97481	25.8	97486.1	25.8	0.92	0.00	142	0	142
	132kV Khupi-Balipara	NP-9606-A	AS-55	54806.7	79.9	54808.7	79.9	0.72	0.00	-112	0	-112
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	770.3	25711.2	770.3	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2124.6	442.1	2124.6	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2035.6	502.2	2035.6	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	48553.3	167.3	48553.7	167.3	0.19	0.00	-30	0	-30
	132kV Chimpur-Pare	NP-9411-A	PA-05	1181.6	7.4	1181.6	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	160.2	0	160.2	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	60.7	0.2	60.7	0.2	0.00	0.00	0	0	0
TOTAL												1
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43329	75.8	43329	80.1	0.00	6.88	0	1,066	1,066
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	78920.6	6862.6	78971.4	6862.6	81.28	0.00	-12,598	0	-12,598
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72738.8	98617.5	72769.9	98617.5	31.10	0.00	4,821	0	4,821
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73327	99218	73379.6	99218	52.60	0.00	8,153	0	8,153
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27614.2	63.9	27666.2	63.9	83.20	0.00	-12,896	0	-12,896
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	38785.8	82267.8	37461.7	82267.7	-953.35	-0.07	-1,47,770	11	-1,47,758
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	2099.8	7690.1	2139	7690.1	28.22	0.00	-4,375	0	-4,375
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99441.2	92901.5	99441.2	92728.7	0.00	-62.21	0	9,642	9,642
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21132.8	3240.7	21234.2	3240.7	18.25	0.00	-2,829	0	-2,829
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84917.4	91177.9	84713.8	91177.9	-73.30	0.00	-11,361	0	-11,361
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	89311.7	99935.1	89120	99935.1	-69.01	0.00	-10,697	0	-10,697
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	89958.5	99981	89703.2	99981	-91.91	0.00	-14,246	0	-14,246
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	83791.8	99986.4	83443	99986.4	-125.57	0.00	-19,463	0	-19,463
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29089.8	99479.4	29089.4	99486.2	-0.14	2.45	22	379	402
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99989.2	99838.4	26.3	99838.4	269.82	0.00	41,822	0	41,822
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	97931.9	0.1	97931.8	0.00	-0.73	0	113	113
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82639.2	93673	82639.2	93818.9	0.00	52.52	0	-8,141	-8,141
	220kV Mariani-AGBPP	NP-6888-A	AS-03	98041.1	96335.5	96383.6	96335.5	-2,652.00	0.00	-4,11,060	0	-4,11,060
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97894.7	1.7	97759.9	1.7	-97.06	0.00	-15,044	0	-15,044
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1807.7	96.4	1865.1	96.4	41.33	0.00	6,406	0	6,406
	132KV Pavo - BNC Ckt I	NP-9680-A	AM-12	13935.9	92970.4	13935.9	92728.6	0.00	-87.05	0	13,492	13,492
	132KV Pavo - BNC Ckt II	NP-8801-A	AM-13	48989.4	90187.6	48989.4	89905.6	0.00	-101.52	0	15,736	15,736
TOTAL												-5,68,816
MANIPUR	JIRIBAM-TRF	NP-8501-A	MN-04	24543.9	12310.2	24544.6	12313.7	0.04	0.21	-7	33	26
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98943.9	99898.5	98944.1	99898.5	0.07	0.00	-11	0	-11
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20360.8	382.4	20451	382.4	32.47	0.00	-5,033	0	-5,033
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17939.1	381.8	18025.7	381.8	31.18	0.00	-4,832	0	-4,832
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47542.1	99426.8	47146.1	99426.8	-142.56	0.00	22,097	0	22,097
TOTAL												18,474


 (एस.एस. मन्त्री/Min. of Power)
 विद्युत/Minister
 राज्य/Min. of Power
 बिहार सरकार/Govt. of Bihar
 विद्युत/Ministry

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95583.1	81174.4	95540.1	81174.4	-30.96	0.00	-4,799	0	-4,799
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99938	20013.4	99932.7	20013.4	-3.82	0.00	591	0	591
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	87197	90862.4	87096.9	0.00	-160.16	0	-24,825	-24,825
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87286.1	96033.7	87254.8	96033.6	-50.08	-0.16	7,762	-25	7,738
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	48684.7	99953.9	47990.9	99953.9	-2,522.91	0.00	-3,91,051	0	-3,91,051
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	3648.2	99864	3354.7	99864	-1,067.27	0.00	-1,65,427	0	-1,65,427
TOTAL												-5,77,773

MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35891.4	79780.1	36116.8	79780.2	81.14	0.04	-12,577	6	-12,572
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78628.7	49966.6	78482.1	49966.6	-52.78	0.00	8,180	0	8,180
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68856.5	86428	68918.7	86428	22.39	0.00	3,471	0	3,471
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97750.6	31664.7	97760.4	31664.7	7.06	0.00	1,094	0	1,094
TOTAL												173

NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15662.2	7859.1	15669.7	7968.4	2.70	39.35	-419	6,099	5,680
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71072.5	2035.8	71094.6	2104.2	15.91	49.25	-2,466	7,633	5,167
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8806.4	98800.3	8784.8	98770.9	-7.78	-10.58	1,205	-1,641	-435
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44168.1	235.4	44168.1	235.6	0.00	0.07	0	-11	-11
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43618.3	236.1	43618.3	236.3	0.00	0.07	0	-11	-11
TOTAL												10,390

TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84658.5	97040.7	84659.1	0.00	0.43	0	67	67
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10245.6	99635.1	10243.5	99635.1	-2.02	0.00	-312	0	-312
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49181.6	93755.2	49181.6	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68680.6	72313.5	68680.5	72313.5	-0.12	0.00	-19	0	-19
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7201.5	99970.5	7201.5	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14452.5	25.9	14452.5	25.9	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9202.7	99994.7	9263.2	99994.7	58.08	0.00	-9,002	0	-9,002
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3704.1	99999.7	3734.6	99999.7	29.28	0.00	-4,538	0	-4,538
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1017.5	99999.6	1025.5	99999.6	7.68	0.00	1,190	0	1,190
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	893.4	99999.3	898.7	99999.3	5.09	0.00	789	0	789
TOTAL												-11,826

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director
 Eastern Region/NERPC
 Power Secretary/Min. of Power
 Govt. of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 12-07-2021 to 18-07-2021

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76037.6	96280.1	76035	96279.2	-1.248	-0.432	-193	67	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94153.8	99183.7	94152.6	99181.5	-0.576	-1.056	-89	164	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94767.2	99821.5	94757.8	99821.5	-4.512	0	-699	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	95666.1	99796	95642.8	99796	-11.184	0	-1,734	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91268.3	99993.6	91876	99993.6	291.696	0	45,213	0	13,310
			NP-8384-A	ME-01	94925.2	68520.3	94746.3	68520.3	-85.872	0	-13,310	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98847.6	5573.8	98820.7	5579.2	-12.912	2.592	-2,001	-402	-1,101
			NP-9071-A	ME-16	78462.6	27312.9	78472	27182.3	4.512	-62.688	699	9,717	
TOTAL													12,209
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	5667.5	99983.1	5797.6	99983.1	62.448	0	9,679	0	0
TOTAL			NP-6892-B	TR-06	76321.8	1394.3	76321.8	723.2	0	-64.4256	0	9,986	0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94076.4	99348.9	94054.3	99348.9	-10.608	0	-1,644	0	-1,060
TOTAL			NP-9947-A	NG-02	99220.4	99875.6	99243.2	99879.5	6.84	1.17	1,060	-181	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


Director/Director
S. J. RAO/JSRDC
Ministry of Power
Govt. of India
New Delhi

Reactive Energy (VArH) Charge Statement
for the period 19-07-2021 to 25-07-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	7,885
ASSAM	0	4,58,499
MANIPUR	10,693	0
MEGHALAYA	0	7,57,003
MIZORAM	3,750	0
NAGALAND	10,317	0
TRIPURA	0	15,505

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	7
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	1,637
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 P. K. Singh / S.M. Ahmed
 Deputy Director
 NEREP / NEREP
 Pigeon House / Min. of Power
 West Bengal / Govt. of India
 Kolkata / 700016

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 19-07-2021 to 25-07-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97486.1	25.8	97486.1	25.8	0.00	0.00	0	0	0
	132kV Khupi-Balipara	NP-9606-A	AS-55	54808.7	79.9	54950	79.9	50.87	0.00	-7,885	0	-7,885
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	770.3	25711.2	770.3	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2124.6	442.1	2124.6	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2035.6	502.2	2035.6	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	48553.7	167.3	48553.7	167.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	1181.6	7.4	1181.6	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	160.2	0	160.2	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	60.7	0.2	60.7	0.2	0.00	0.00	0	0	0
TOTAL												-7,885

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43329	80.1	43329	80.1	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	78971.4	6862.6	79514	6862.6	868.16	0.00	-1,34,565	0	-1,34,565
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72769.9	98617.5	72864.6	98617.4	94.70	-0.10	14,679	16	14,694
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73379.6	99218	73530.9	99218	151.30	0.00	23,452	0	23,452
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27666.2	63.9	27811.8	63.9	232.96	0.00	-36,109	0	-36,109
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	37461.7	82267.7	36588.7	82267.7	-628.56	0.00	-97,427	0	-97,427
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	2139	7690.1	2179	7690.1	28.80	0.00	-4,464	0	-4,464
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99441.2	92728.7	99441.2	92554.6	0.00	-62.68	0	9,715	9,715
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21234.2	3240.7	21326.1	3240.7	16.54	0.00	-2,564	0	-2,564
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84713.8	91177.9	84523.2	91177.9	-68.62	0.00	-10,635	0	-10,635
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	89120	99935.1	88936.2	99935	-66.17	-0.04	-10,256	6	-10,250
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	89703.2	99981	89434.6	99981	-96.70	0.00	-14,988	0	-14,988
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	83443	99986.4	83092.5	99986.4	-126.18	0.00	-19,558	0	-19,558
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29089.4	99486.2	29089.4	99503.9	0.00	6.37	0	988	988
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	26.3	99838.4	99995.2	99838.4	-226.18	0.00	-35,058	0	-35,058
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	97931.8	0.1	97931.8	0.00	0.00	0	0	0
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82639.2	93818.9	82645	93886.7	2.09	24.41	324	-3,783	-3,460
	220kV Mariani-AGBPP	NP-6888-A	AS-03	96383.6	96335.5	95535.7	96335.5	-1,356.64	0.00	-2,10,279	0	-2,10,279
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97759.9	1.7	97605.4	1.7	-111.24	0.00	-17,242	0	-17,242
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1865.1	96.4	1912.8	96.4	34.34	0.00	5,323	0	5,323
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	13935.9	92728.6	13935.9	92026.8	0.00	-252.65	0	39,160	39,160
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	48989.4	89905.6	48989.4	89103.3	0.00	-288.83	0	44,768	44,768
TOTAL												-4,58,499

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96108.2	99122	96123.5	99122	11.02	0.00	1,707	0	1,707
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	509.3	99940.7	516.9	99940.7	3.65	0.00	565	0	565
	JIRIBAM-TRF	NP-8501-A	MN-04	24544.6	12313.7	24544.6	12314.3	0.00	0.04	0	6	6
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98944.1	99898.5	98945.4	99898.5	0.47	0.00	-73	0	-73
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20451	382.4	20497.7	382.4	16.81	0.00	-2,606	0	-2,606
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18025.7	381.8	18071.4	381.8	16.45	0.00	-2,550	0	-2,550
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47146.1	99426.8	46973.4	99426.8	-62.17	0.00	9,637	0	9,637
TOTAL												10,693


 (ए.एस.बाबू/एस.एम.आनंद)
 निदेशक/Director
 राजकीय/REGDC
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Delhi

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kv KHLRT S-PG	NP-6865-A	ME-02	95540.1	81174.4	95525.4	81174.4	-10.58	0.00	-1,641	0	-1,641
	132kv KHLRT S-PG II	NP-6880-A	ME-09	99932.7	20013.4	99943.1	20013.4	7.49	0.00	-1,161	0	-1,161
	220kv BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	87096.9	90862.4	86880.6	0.00	-346.08	0	-53,642	-53,642
	220kv BYRNIHAT-MISA II	NP-9091-A	AS-72	87254.8	96033.6	87231	96033.6	-38.08	0.00	5,902	0	5,902
	400kv BYRNIHAT-B'GAON	NP-8370-A	ME-14	47990.9	99953.9	46840.6	99953.9	-4,182.91	0.00	-6,48,351	0	-6,48,351
	400kv BYRNIHAT-SILCHAR	NP-8371-A	ME-15	3354.7	99864	3251.6	99864	-374.91	0.00	-58,111	0	-58,111
TOTAL												-7,57,003
MIZORAM	132kv LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	36116.8	79780.2	36319.8	79780.2	73.08	0.00	-11,327	0	-11,327
	132kv ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78482.1	49966.6	78292	49966.6	-68.44	0.00	10,608	0	10,608
	132kv KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68918.7	86428	68979.8	86428	22.00	0.00	3,409	0	3,409
	132kv KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97760.4	31664.7	97769.9	31664.7	6.84	0.00	1,060	0	1,060
TOTAL												3,750
NAGALAND	132kv DIMAPUR S-PG I	NP-9602-A	NG-01	15669.7	7968.4	15669.7	8068.4	0.00	36.00	0	5,580	5,580
	132kv DIMAPUR S-PG II	NP-9649-A	NG-17	71094.6	2104.2	71096.7	2148.1	1.51	31.61	-234	4,899	4,665
	132kv KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8784.8	98770.9	8782.6	98770.1	-0.79	-0.29	123	-45	78
	132kv M'CHANG S-PG I	NP-9653-A	NG-20	44168.1	235.6	44168.1	235.7	0.00	0.04	0	-6	-6
	132kv M'CHANG S-PG II	NP-9655-A	NG-21	43618.3	236.3	43618.3	236.3	0.00	0.00	0	0	0
TOTAL												10,317
TRIPURA	132kv PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kv Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10243.5	99635.1	10244.5	99635.1	0.96	0.00	149	0	149
	132kv Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49181.6	93755.2	49182.9	93755.2	1.25	0.00	193	0	193
	132kv SM Nagar-Palatana	NP-8471-A	TR-13	68680.5	72313.5	68681.7	72313.5	1.44	0.00	223	0	223
	132kv BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7201.5	99970.5	7203.6	99970.5	2.02	0.00	-312	0	-312
	132kv SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14452.5	25.9	14455.8	26	3.17	0.10	-491	15	-476
	132kv PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9263.2	99994.7	9339.2	99994.7	72.96	0.00	-11,309	0	-11,309
	132kv AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3734.6	99999.7	3772	99999.7	35.90	0.00	-5,565	0	-5,565
	132kv PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1025.5	99999.6	1031.9	99999.6	6.14	0.00	952	0	952
	132kv PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	898.7	99999.3	903	99999.3	4.13	0.00	640	0	640
TOTAL												-15,505

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(सहायक निदेशक/उप निदेशक)
निर्माण/Construction
संयोजक/Coordinator
विद्युत विभाग/Min. of Power
भारत सरकार/Govt. of India
Bhubaneswar

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 19-07-2021 to 25-07-2021

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76035	96279.2	76024.6	96278.5	-4.992	-0.336	-774	52	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94152.6	99181.5	94142	99179.9	-5.088	-0.768	-789	119	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94757.8	99821.5	94730	99821.5	-13.344	0	-2,068	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	95642.8	99796	95614.8	99796	-13.44	0	-2,083	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91876	99993.6	92146.4	99993.6	129.792	0	20,118	0	1,637
			NP-8384-A	ME-01	94746.3	68520.3	94724.3	68520.3	-10.56	0	-1,637	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98820.7	5579.2	98819.9	5579.2	-0.384	0	-60	0	0
			NP-9071-A	ME-16	78472	27182.3	78472	27095.8	0	-41.52	0	6,436	
TOTAL													1,637
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	5797.6	99983.1	5945.7	99983.2	71.088	0.048	11,019	-7	-7
			NP-6892-B	TR-06	76321.8	723.2	76321.8	99742.4	0	-94.1568	0	14,594	
TOTAL													-7
MANIPUR	132kv KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94054.3	99348.9	94054.5	99348.9	0.096	0	15	0	0
			NP-9947-A	NG-02	99243.2	99879.5	99262.3	99879.6	5.73	0.03	888	-5	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (স্বাক্ষর/স্বাক্ষর)
 Director/সচিব
 NEERC
 বিদ্যুৎ সঞ্চালন/Min. of Power
 গণপ্রজাতন্ত্রী বাংলাদেশ
 Dhaka/Dhaka

***Reactive Energy (VArH) Charge Statement
for the period 26-07-2021 to 01-08-2021***

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

<i>BENEFICIARY</i>	<i>AMOUNT PAYABLE TO POOL(Rs.)</i>	<i>AMOUNT RECEIVABLE FROM POOL (Rs.)</i>
ARUNACHAL PRADESH	0	1,710
ASSAM	0	2,80,574
MANIPUR	1,313	0
MEGHALAYA	0	7,30,762
MIZORAM	1,144	0
NAGALAND	7,589	0
TRIPURA	0	193

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	2,872
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0

(एस.एम.आलम/ S.M.Ahmed)
 निदेशक/Director
 न.पू.वे.पि.डि./NERDC
 बिजुत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिवांग/ Shiwanj

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 26-07-2021 to 01-08-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97486.1	25.8	97504.8	25.8	3.37	0.00	522	0	522
	132kV Khupi-Balipara	NP-9606-A	AS-55	54950	79.9	55009.2	79.9	21.31	0.00	-3,303	0	-3,303
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	770.3	25711.2	770.3	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2124.6	442.1	2134.6	0.00	3.60	0	558	558
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2035.6	502.2	2044.8	0.00	3.31	0	513	513
	132kV Lekhi-Pare	NP-9607-A	PA-01	48553.7	167.3	48553.7	167.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	1181.6	7.4	1181.6	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	160.2	0	160.2	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	60.7	0.2	60.7	0.2	0.00	0.00	0	0	0
TOTAL												-1,710

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43329	80.1	43331	80.1	3.20	0.00	-496	0	-496
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	79514	6862.6	0	0	0.00	0.00	0	0	0
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72864.6	98617.4	72914.3	98617.4	49.70	0.00	7,704	0	7,704
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73530.9	99218	73646.2	99218	115.30	0.00	17,872	0	17,872
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27811.8	63.9	27922.2	63.9	176.64	0.00	-27,379	0	-27,379
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	36588.7	82267.7	35952.6	82267.7	-457.99	0.00	-70,989	0	-70,989
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	2179	7690.1	2180.8	7690.1	1.30	0.00	-201	0	-201
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99441.2	92554.6	99441.2	92249.1	0.00	-109.98	0	17,047	17,047
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21326.1	3240.7	21458.4	3240.7	23.81	0.00	-3,691	0	-3,691
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84523.2	91177.9	84456.7	91177.9	-23.94	0.00	-3,711	0	-3,711
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	88936.2	99935	88874	99935	-22.39	0.00	-3,471	0	-3,471
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	89434.6	99981	89284.5	99981	-54.04	0.00	-8,376	0	-8,376
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	83092.5	99986.4	82857.2	99986.4	-84.71	0.00	-13,130	0	-13,130
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29089.4	99503.9	29089.4	99505.9	0.00	0.72	0	112	112
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99995.2	99838.4	99942.6	99838.4	-382.55	0.00	-59,295	0	-59,295
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	97931.8	0.9	97931.8	5.82	0.00	902	0	902
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82645	93886.7	82681.9	93921.4	13.28	12.49	2,059	-1,936	123
	220kV Mariani-AGBPP	NP-6888-A	AS-03	95535.7	96335.5	94639.8	96335.5	-1,433.44	0.00	-2,22,183	0	-2,22,183
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97605.4	1.7	97545.8	1.7	-42.91	0.00	-6,651	0	-6,651
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1912.8	96.4	1918.1	96.4	3.82	0.00	591	0	591
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	13935.9	92026.8	13935.9	91229.8	0.00	-286.92	0	44,473	44,473
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	48989.4	89103.3	48989.4	88204.1	0.00	-323.71	0	50,175	50,175
TOTAL												-2,80,574

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96123.5	99122	96127.6	99122	2.95	0.00	458	0	458
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.9	99940.7	521.2	99940.7	2.06	0.00	320	0	320
	JIRIBAM-TRF	NP-8501-A	MN-04	24544.6	12314.3	24544.6	12314.3	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98945.4	99898.5	98945.5	99898.5	0.04	0.00	-6	0	-6
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20497.7	382.4	20519	382.4	7.67	0.00	-1,189	0	-1,189
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18071.4	381.8	18092.3	381.8	7.52	0.00	-1,166	0	-1,166
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46973.4	99426.8	46949.9	99426.8	-8.46	0.00	1,311	0	1,311
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	95122.3	21.3	95108.1	21.3	-10.22	0.00	1,585	0	1,585
TOTAL												1,313


(Signature/Name of Director)
Director/Secretary
Ministry of Power
Govt. of India
Discom/Ministry

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kv KHLRT S-PG	NP-6865-A	ME-02	95525.4	81174.4	95497.1	81174.4	-20.38	0.00	-3,158	0	-3,158
	132kv KHLRT S-PG II	NP-6880-A	ME-09	99943.1	20013.4	99941.9	20013.4	-0.86	0.00	134	0	134
	220kv BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86880.6	90862.4	86835.5	0.00	-72.16	0	-11,185	-11,185
	220kv BYRNIHAT-MISA II	NP-9091-A	AS-72	87231	96033.6	87225.1	96033.6	-9.44	0.00	1,463	0	1,463
	400kv BYRNIHAT-B'GAON	NP-8370-A	ME-14	46840.6	99953.9	45461.8	99953.9	-5,013.82	0.00	-7,77,142	0	-7,77,142
	400kv BYRNIHAT-SILCHAR	NP-8371-A	ME-15	3251.6	99864	3356.5	99864	381.45	0.00	59,125	0	59,125
TOTAL												-7,30,762
MIZORAM	132kv LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	36319.8	79780.2	36385.2	79780.2	23.54	0.00	-3,649	0	-3,649
	132kv ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78292	49966.6	78247.3	49966.6	-16.09	0.00	2,494	0	2,494
	132kv KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	68979.8	86428	68994	86428	5.11	0.00	792	0	792
	132kv KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97769.9	31664.7	97783.4	31664.7	9.72	0.00	1,507	0	1,507
TOTAL												1,144
NAGALAND	132kv DIMAPUR S-PG I	NP-9602-A	NG-01	15669.7	8068.4	15669.7	8138.6	0.00	25.27	0	3,917	3,917
	132kv DIMAPUR S-PG II	NP-9649-A	NG-17	71096.7	2148.1	71096.7	2181.9	0.00	24.34	0	3,772	3,772
	132kv KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8782.6	98770.1	8782.6	98768.7	0.00	-0.50	0	-78	-78
	132kv M'CHANG S-PG I	NP-9653-A	NG-20	44168.1	235.7	44168.1	235.8	0.00	0.04	0	-6	-6
	132kv M'CHANG S-PG II	NP-9655-A	NG-21	43618.3	236.3	43618.3	236.6	0.00	0.11	0	-17	-17
TOTAL												7,589
TRIPURA	132kv PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kv Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10244.5	99635.1	10244.5	99635.1	0.00	0.00	0	0	0
	132kv Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kv SM Nagar-Palatana	NP-8471-A	TR-13	68681.7	72313.5	68681.7	72313.5	0.00	0.00	0	0	0
	132kv BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.5	7203.6	99970.5	0.00	0.00	0	0	0
	132kv SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26	14455.8	26	0.00	0.00	0	0	0
	132kv PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9339.2	99994.7	9340.2	99994.7	0.96	0.00	-149	0	-149
	132kv AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3772	99999.7	3772.3	99999.7	0.29	0.00	-45	0	-45
	132kv PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1031.9	99999.6	1031.9	99999.6	0.00	0.00	0	0	0
	132kv PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	903	99999.3	903	99999.3	0.00	0.00	0	0	0
TOTAL												-193

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director
 NEERC
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 26-07-2021 to 01-08-2021

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76024.6	96278.5	76010.6	96278.5	-6.72	0	-1,042	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94142	99179.9	94128	99179.9	-6.72	0	-1,042	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94730	99821.5	94715.4	99821.5	-7.008	0	-1,086	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	95614.8	99796	95600.1	99796	-7.056	0	-1,094	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92146.4	99993.6	92217.1	99993.6	33.936	0	5,260	0	4,434
			NP-8384-A	ME-01	94724.3	68520.3	94664.7	68520.3	-28.608	0	-4,434	0	
TOTAL	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98819.9	5579.2	98848.9	5604	13.92	11.904	2,158	-1,845	-1,562
			NP-9071-A	ME-16	78472	27095.8	78468.2	26954.6	-1.824	-67.776	-283	10,505	2,872
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	5945.7	99983.2	5980.8	99983.2	16.848	0	2,611	0	0
TOTAL			NP-6892-B	TR-06	76321.8	99742.4	76321.8	98716	0	-98.5344	0	15,273	0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94054.5	99348.9	94054	99348.9	-0.24	0	-37	0	0
TOTAL			NP-9947-A	NG-02	99262.3	99879.6	99262.3	99880.6	0	0.3	0	-47	0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (सहसंचालक/Asst. Manager)
 निदेश/Director
 वृद्धि/MSDC
 विद्युत विभाग/Min. of Power
 कारगुम/Gen. of India
 बिहार/Bihar