



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022 /3137-3159

Dt: 16th August 2022

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy under ABT regime-for the period 30.08.2021 to 26.09.2021 (4 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy accounting details of payables/receivables with the pool and between beneficiaries in rupees for the period 30.08.2021 to 26.09.2021 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 15.5 Paise/KVARH w.e.f from 1st April 2021, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.

भवदीय / Yours faithfully,



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

वाणिज्य / Commercial

Reactive Energy (VArH) Charge Statement
for the period 30-08-2021 to 05-09-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	5,346
ASSAM	0	3,25,243
MANIPUR	3,599	0
MEGHALAYA	0	7,08,911
MIZORAM	7,265	0
NAGALAND	20,501	0
TRIPURA	0	517

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	878
NAGALAND	MANIPUR	51
TRIPURA	ASSAM	0


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.रे.वि.स./NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 30-08-2021 to 05-09-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97734.5	25.8	97734.5	25.8	0.00	0.00	0	0	0
	132kV Khupi-Balipara	NP-9606-A	AS-55	55260.2	79.9	55358.2	79.9	35.28	0.00	-5,468	0	-5,468
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	773.2	25711.2	773.2	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2152.6	442.1	2153.3	0.00	0.25	0	39	39
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2063.4	502.2	2064.9	0.00	0.54	0	84	84
	132kV Lekhi-Pare	NP-9607-A	PA-01	48633.7	167.3	48633.7	167.3	0.00	0.00	0	0	0
	132kV Chimpur-Pare	NP-9411-A	PA-05	1194.4	7.4	1194.4	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	162.3	0	162.3	0	0.00	0.00	0	0	0
TOTAL												-5,346

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43338	80.1	43338	80.1	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	82143.2	6862.6	82636.9	6862.6	789.92	0.00	-1,22,438	0	-1,22,438
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72937	98616.7	72942.6	98616.7	5.60	0.00	868	0	868
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73717.2	99218	73739.4	99218	22.20	0.00	3,441	0	3,441
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28415.8	63.9	28496.1	63.9	128.48	0.00	-19,914	0	-19,914
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	34152.4	82263.4	33776.4	82263.4	-270.72	0.00	-41,962	0	-41,962
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	0	0	0	0	0.00	0.00	0	0	0
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99443	91493	99443	91140.9	0.00	-126.76	0	19,647	19,647
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21587.1	3240.7	21595.6	3240.7	1.53	0.00	-237	0	-237
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84303.7	91177.9	84247.8	91177.8	-20.12	-0.04	-3,119	6	-3,114
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	88736.1	99935	88684.6	99935	-18.54	0.00	-2,874	0	-2,874
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	88953.4	99981	88828.1	99981	-45.11	0.00	-6,992	0	-6,992
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	82372.4	99986.3	82203.6	99986.3	-60.77	0.00	-9,419	0	-9,419
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59813.6	98349.8	59813.6	98198	0.00	-109.30	0	16,941	16,941
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99753.8	99838.4	99700.9	99838.4	-384.73	0.00	-59,633	0	-59,633
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.9	97931.8	1.4	97931.8	3.64	0.00	564	0	564
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	83300.2	93968.2	83311.2	94094	3.96	45.29	614	-7,020	-6,406
	220kV Mariani-AGBPP	NP-6888-A	AS-03	91451	96335.5	90804.1	96335.5	-1,035.04	0.00	-1,60,431	0	-1,60,431
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97357.4	1.7	97315	1.7	-30.53	0.00	-4,732	0	-4,732
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1935.8	139.8	1960.8	147.5	18.00	5.54	2,790	-859	1,931
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	13940.5	90303.1	13940.5	89690.6	0.00	-220.50	0	34,178	34,178
TOTAL												-3,25,243

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96139.1	99122	96173.6	99122	24.84	0.00	3,850	0	3,850
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	537	99940.7	553.8	99940.7	8.06	0.00	1,250	0	1,250
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99004.7	99898.5	99026.1	99898.5	7.70	0.00	-1,194	0	-1,194
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20594.2	382.4	20636.7	382.4	15.30	0.00	-2,372	0	-2,372
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18144.4	381.8	18186.2	381.8	15.05	0.00	-2,332	0	-2,332
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	46988.5	99426.8	47013.7	99426.8	9.07	0.00	-1,406	0	-1,406
TOTAL												3,599


 (एस.एम.अबनोल/S.M.Abnol)
 निदेशक/Director
 उद्योग विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95251.7	81174.4	95215.7	81174.4	-25.92	0.00	-4,018	0	-4,018
	132kV KHLRT S-PG II	NP-6880-A	ME-09	38.9	20013.4	42.6	20013.4	2.66	0.00	-413	0	-413
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86453.7	90862.4	86443.4	0.00	-16.48	0	-2,554	-2,554
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87179.6	96033.6	87122.9	96033.6	-90.72	0.00	14,062	0	14,062
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	39394.4	99953.9	38000	99953.9	-5,070.55	0.00	-7,85,935	0	-7,85,935
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	3969.7	99864	4093.8	99864	451.27	0.00	69,947	0	69,947
TOTAL												-7,08,911

MIZORAM	132kV LAUNGQUAL-AIZWAL PG	NP-8504-A	MZ-02	36516.4	79914.1	36528.5	80014.9	4.36	36.29	-675	5,625	4,949
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78143	49990.4	78156	50024.1	4.68	12.13	-725	1,880	1,155
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69054.1	86428	69059.3	86428	1.87	0.00	290	0	290
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97804	31664.7	97811.8	31664.7	5.62	0.00	870	0	870
TOTAL												7,265

NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96109.3	82700.3	96109.3	82596	0.00	-75.10	0	11,640	11,640
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71096.7	2507.1	71096.7	2598.6	0.00	65.88	0	10,211	10,211
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8782.7	98549.3	8787.4	98543.2	1.69	-2.20	-262	-340	-603
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44168.1	232.8	44168.1	239.3	0.00	2.34	0	-363	-363
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43618.3	233.5	43618.3	240.4	0.00	2.48	0	-385	-385
TOTAL												20,501

TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10244.5	99635.1	10244.5	99635.1	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.7	72313.5	68681.8	72313.5	0.12	0.00	19	0	19
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.5	7203.6	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26	14455.8	26	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9343.9	99994.7	9345.8	99994.7	1.82	0.00	-283	0	-283
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3774.2	99999.7	3775.9	99999.7	1.63	0.00	-253	0	-253
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1031.9	99999.6	1031.9	99999.6	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	903	99999.3	903	99999.3	0.00	0.00	0	0	0
TOTAL												-517

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(एस.एम.आलमोल/S.M.Almol)
निदेशक/Director
उत्प्रेषित/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 30-08-2021 to 05-09-2021

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75976.7	96264.8	75953.9	96264.8	-10.944	0	-1,696	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94092.8	99159.7	94070.1	99159.7	-10.896	0	-1,689	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94690.7	99821.5	94682.1	99821.5	-4.128	0	-640	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95575	99796	95566.3	99796	-4.176	0	-647	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92677.2	99994.6	92736.1	99994.7	28.272	0.048	4,382	-7	878
			NP-8384-A	ME-01	94403.8	68520.2	94392	68520.2	-5.664	0	-878	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98875.9	5933.4	98876.7	5933.4	0.384	0	60	0	0
			NP-9071-A	ME-16	78466.8	26256.7	78466.8	26115.4	0	-67.824	0	10,513	
TOTAL													878
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	6080.8	99983.2	6105	99983.2	11.616	0	1,800	0	0
			NP-6892-B	TR-06	76321.8	97687.1	76321.8	97319.6	0	-35.28	0	5,468	
TOTAL													0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94052	99362.6	94047.9	99361	-1.968	-0.768	-305	119	51
			NP-9947-A	NG-02	99262.2	99986	99262.2	99987.1	0	0.33	0	-51	
TOTAL													51

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.अहमद/S.M.Ahamd)
 निदेशक/Director
 उ.पु.रे.वि.न./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 06-09-2021 to 12-09-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	563
ASSAM	0	88,141
MANIPUR	0	1,062
MEGHALAYA	0	6,13,815
MIZORAM	8,214	0
NAGALAND	7,399	0
TRIPURA	0	878

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	618
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	98
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम.अनमोल/S.M.Anmol)
 निदेशक/Director
 उ.पु.वि.उ./NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 06-09-2021 to 12-09-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97734.5	25.8	97734.5	25.7	0.00	-0.02	0	3	3
	132kV Khupi-Balipara	NP-9606-A	AS-55	55358.2	79.9	55368.6	79.9	3.74	0.00	-580	0	-580
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	773.2	25711.2	773.2	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2153.3	442.1	2153.3	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2064.9	502.2	2064.9	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	48633.7	167.3	48633.7	167.3	0.00	0.00	0	0	0
	132kV Chimpur-Pare	NP-9411-A	PA-05	1194.4	7.4	1194.4	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	162.3	0	162.3	0	0.00	0.00	0	0	0
TOTAL												-563

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43338	80.1	43338	80.1	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	82636.9	6862.6	82616	6862.6	-33.44	0.00	5,183	0	5,183
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	72942.6	98616.7	73037.8	98616.7	95.20	0.00	14,756	0	14,756
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73739.4	99218	73869.2	99218	129.80	0.00	20,119	0	20,119
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28496.1	63.9	28496.8	63.9	1.12	0.00	-174	0	-174
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	33776.4	82263.4	33438.8	82263.4	-243.07	0.00	-37,676	0	-37,676
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	0	0	0	0	0.00	0.00	0	0	0
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99443	91140.9	99443	90655	0.00	-174.92	0	27,113	27,113
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21595.6	3240.7	21607.1	3240.7	2.07	0.00	-321	0	-321
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84247.8	91177.8	84209	91177.8	-13.97	0.00	-2,165	0	-2,165
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	88684.6	99935	88649	99935	-12.82	0.00	-1,986	0	-1,986
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	88828.1	99981	88732.9	99980.9	-34.27	-0.04	-5,312	6	-5,307
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	82203.6	99986.3	82042	99986.3	-58.18	0.00	-9,017	0	-9,017
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59813.6	98198	59813.3	98140.5	-0.22	-41.40	-33	6,417	6,384
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99700.9	99838.4	99672.5	99838.4	-206.55	0.00	-32,015	0	-32,015
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1.4	97931.8	1.3	97931.8	-0.73	0.00	-113	0	-113
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	83311.2	94094	83477.2	94286.7	59.76	69.37	9,263	-10,753	-1,490
	220kV Mariani-AGBPP	NP-6888-A	AS-03	90804.1	96335.5	90174.2	96335.5	-1,007.84	0.00	-1,56,215	0	-1,56,215
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97315	1.7	97274.2	1.6	-29.38	-0.07	-4,553	11	-4,542
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1960.8	147.5	1984.6	150.1	17.14	1.87	2,656	-290	2,366
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	13940.5	89690.6	13940.5	88934.8	0.00	-272.09	0	42,174	42,174
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	48990.5	86433.7	48990.5	85631.1	0.00	-288.94	0	44,785	44,785
TOTAL												-88,141

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96173.6	99122	96182	99121.9	6.05	-0.07	937	11	949
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	553.8	99940.7	563.9	99940.7	4.85	0.00	751	0	751
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99026.1	99898.5	99048.2	99898.5	7.96	0.00	-1,233	0	-1,233
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20636.7	382.4	20663.4	382.4	9.61	0.00	-1,490	0	-1,490
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18186.2	381.8	18211.5	381.8	9.11	0.00	-1,412	0	-1,412
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47013.7	99426.8	47038.1	99426.8	8.78	0.00	-1,362	0	-1,362
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94998.1	21.3	94973.6	21.3	-17.64	0.00	2,734	0	2,734
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-1,062


 (स.स.म. आसो/ S.M. Aisoo)
 निदेशक/Director
 उ.पु.वि.म./Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95215.7	81174.4	95203.6	81174.4	-8.71	0.00	-1,350	0	-1,350
	132kV KHLRT S-PG II	NP-6880-A	ME-09	42.6	20013.4	31.3	20013.4	-8.14	0.00	1,261	0	1,261
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86443.4	90862.4	86375.2	0.00	-109.12	0	-16,914	-16,914
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87122.9	96033.6	87036.9	96033.6	-137.60	0.00	21,328	0	21,328
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	38000	99953.9	36818.7	99953.9	-4,295.64	0.00	-6,65,824	0	-6,65,824
TOTAL												-6,13,815
MIZORAM	132kV LAUNGMUAL-AIZWAL PG	NP-8504-A	MZ-02	36528.5	80014.9	36531	80135.2	0.90	43.31	-140	6,713	6,573
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78156	50024.1	78155	50046	-0.36	7.88	56	1,222	1,278
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69059.3	86428	69059.9	86427.9	0.22	-0.04	33	6	39
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97811.8	31664.7	97814.7	31664.7	2.09	0.00	324	0	324
TOTAL												8,214
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96109.3	82596	96110	82552.5	0.50	-31.32	78	4,855	4,933
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71096.7	2598.6	71100.7	2645.4	2.88	33.70	-446	5,223	4,776
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8787.4	98543.2	8821.8	98542.4	12.38	-0.29	-1,920	-45	-1,964
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44168.1	239.3	44168.1	242.3	0.00	1.08	0	-167	-167
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43618.3	240.4	43618.3	243.6	0.00	1.15	0	-179	-179
TOTAL												7,399
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10244.5	99635.1	10244.5	99635.1	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.8	72313.5	68681.8	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.5	7203.6	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26	14455.8	26	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9345.8	99994.7	9349.7	99994.7	3.74	0.00	-580	0	-580
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3775.9	99999.7	3777.9	99999.7	1.92	0.00	-298	0	-298
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1031.9	99999.6	1031.9	99999.6	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	903	99999.3	903	99999.3	0.00	0.00	0	0	0
TOTAL												-878

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(सहायक आइसोलेट/S.M.Amoli)
निदेशक/Director
उप क्षेत्र/Min. of Power
बिहार सरकार/Govt. of India
शिवगंज/Shivganga

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 06-09-2021 to 12-09-2021

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75953.9	96264.8	75939	96264.8	-7.152	0	-1,109	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94070.1	99159.7	94052.9	99159.5	-8.256	-0.096	-1,280	15	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94682.1	99821.5	94665.8	99821.5	-7.824	0	-1,213	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95566.3	99796	95550	99796	-7.824	0	-1,213	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92736.1	99994.7	92728.2	99994.6	-3.792	-0.048	-588	7	0
			NP-8384-A	ME-01	94392	68520.2	94391.9	68520.2	-0.048	0	-7	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98876.7	5933.4	98848.1	5941.7	-13.728	3.984	-2,128	-618	-618
			NP-9071-A	ME-16	78466.8	26115.4	78466.3	25844.8	-0.24	-129.888	-37	20,133	
TOTAL													-618
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	6105	99983.2	6125.6	99983.2	9.888	0	1,533	0	0
			NP-6892-B	TR-06	76321.8	97319.6	76321.8	96578.4	0	-71.1552	0	11,029	
TOTAL													0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94047.9	99361	94043.1	99361	-2.304	0	-357	0	-98
			NP-9947-A	NG-02	99262.2	99987.1	99264.3	99985.6	0.63	-0.45	98	70	
TOTAL													-98

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (स.म.आमोल/S. M. Aimal)
 निदेशक/Director
 व.सू.वि.न/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 13-09-2021 to 19-09-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	3,052	0
ASSAM	0	4,32,530
MANIPUR	0	2,546
MEGHALAYA	0	6,01,026
MIZORAM	2,941	0
NAGALAND	12,125	0
TRIPURA	0	164

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	647
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	326
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0



 (S.M. Almot/S.M. Almot)
 निदेशक/Director
 उ.पु.वे.वि.न./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 13-09-2021 to 19-09-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97734.5	25.7	97737.7	25.7	0.58	0.00	89	0	89
	132kV Khupi-Balipara	NP-9606-A	AS-55	55368.6	79.9	55309.1	79.9	-21.42	0.00	3,320	0	3,320
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	773.2	25711.2	773.2	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2153.3	442.1	2153.5	0.00	0.07	0	11	11
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2064.9	502.2	2065.1	0.00	0.07	0	11	11
	132kV Lekhi-Pare	NP-9607-A	PA-01	48633.7	167.3	48638.8	167.3	2.45	0.00	-379	0	-379
	132kV Chimpur-Pare	NP-9411-A	PA-05	1194.4	7.4	1194.4	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	162.3	0	162.3	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	61.5	0.1	61.5	0.1	0.00	0.00	0	0	0
TOTAL												3,052

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43338	80.1	43339.8	80.1	2.88	0.00	-446	0	-446
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	82616	6862.6	83152.3	6862.6	858.08	0.00	-1,33,002	0	-1,33,002
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	73037.8	98616.7	73062.7	98616.7	24.90	0.00	3,860	0	3,860
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73869.2	99218	73962.1	99218	92.90	0.00	14,400	0	14,400
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28496.8	63.9	28828.8	63.9	531.20	0.00	-82,336	0	-82,336
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	33438.8	82263.4	33208.7	82263.4	-165.67	0.00	-25,679	0	-25,679
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	0	0	0	0	0.00	0.00	0	0	0
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99443	90655	99443	90314.1	0.00	-122.72	0	19,022	19,022
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21607.1	3240.7	21615.3	3240.7	1.48	0.00	-229	0	-229
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84209	91177.8	84175.7	91177.8	-11.99	0.00	-1,858	0	-1,858
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	88649	99935	88619.7	99935	-10.55	0.00	-1,635	0	-1,635
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	88732.9	99980.9	88629.4	99980.9	-37.26	0.00	-5,775	0	-5,775
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	82042	99986.3	81882	99986.3	-57.60	0.00	-8,928	0	-8,928
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59813.3	98140.5	59812	98056	-0.94	-60.84	-145	9,430	9,285
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99672.5	99838.4	99635.9	99838.4	-266.18	0.00	-41,258	0	-41,258
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1.3	97931.8	1.3	97928.3	0.00	-25.45	0	3,945	3,945
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	83477.2	94286.7	83672.1	94248.3	70.16	-13.82	10,875	2,143	13,018
	220kV Mariani-AGBPP	NP-6888-A	AS-03	90174.2	96335.5	89314.1	96335.5	-1,376.16	0.00	-2,13,305	0	-2,13,305
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97274.2	1.6	97242.3	1.6	-22.97	0.00	-3,560	0	-3,560
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1984.6	150.1	1985	258.9	0.29	78.34	45	-12,142	-12,097
	132kV PavoI - BNC Ckt I	NP-9680-A	AM-12	13940.5	88934.8	13940.5	88644.9	0.00	-104.36	0	16,176	16,176
	132kV PavoI - BNC Ckt II	NP-8801-A	AM-13	48990.5	85631.1	48990.5	85310.8	0.00	-115.31	0	17,873	17,873
TOTAL												-4,32,530

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96182	99121.9	96182.9	99121.9	0.65	0.00	100	0	100
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	563.9	99940.7	566.5	99940.7	1.25	0.00	193	0	193
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99048.2	99898.5	99063.2	99898.5	5.40	0.00	-837	0	-837
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20663.4	382.4	20679.4	382.4	5.76	0.00	-893	0	-893
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18211.5	381.8	18226.9	381.8	5.54	0.00	-859	0	-859
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47038.1	99426.8	47072.2	99426.8	12.28	0.00	-1,903	0	-1,903
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94973.6	21.3	94958.8	21.3	-10.66	0.00	1,652	0	1,652
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-2,546


 (एस.एम.अह्नोल/S.M.Ahnol)
 निदेशक/Director
 न.उ.रे.वि.न./NERPC
 बिहार सरकार/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

[illegible]

TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10244.5	99635.1	10244.5	99635	0.00	-0.10	0	15	15
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.8	72313.5	68681.8	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.5	7203.6	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26	14455.8	26	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9349.7	99994.7	9349.2	99994.7	-0.48	0.00	74	0	74
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3777.9	99999.7	3779.9	99999.7	1.92	0.00	-298	0	-298
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1031.9	99999.6	1031.9	99999.6	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	903	99999.3	903.3	99999.3	0.29	0.00	45	0	45
TOTAL												
-164												

4) 'NA' means meter reading not available.

(एस.एम.आलमोर/S.M.Almor)
 निदेशक/Director
 उ.पू.वे.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिवांग/Shilong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 13-09-2021 to 19-09-2021

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75939	96264.8	75920.1	96263.9	-9.072	-0.432	-1,406	67	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94052.9	99159.5	94028.4	99157.2	-11.76	-1.104	-1,823	171	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94665.8	99821.5	94643.5	99821.5	-10.704	0	-1,659	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95550	99796	95527.6	99796	-10.752	0	-1,667	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92728.2	99994.6	92641.3	99994.6	-41.712	0	-6,465	0	-7
			NP-8384-A	ME-01	94391.9	68520.2	94392	68520.2	0.048	0	7	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98848.1	5941.7	98849.4	5950.3	0.624	4.128	97	-640	-640
			NP-9071-A	ME-16	78466.3	25844.8	78466.3	25689	0	-74.784	0	11,592	
TOTAL													-647
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	6125.6	99983.2	6156.9	99983.2	15.024	0	2,329	0	0
			NP-6892-B	TR-06	76321.8	96578.4	76321.8	96318	0	-24.9984	0	3,875	
TOTAL													0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94043.1	99361	94036.6	99347.2	-3.12	-6.624	-484	1,027	-326
			NP-9947-A	NG-02	99264.3	99985.6	99271.3	99982.8	2.1	-0.84	326	130	
TOTAL													-326

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.अहमद/S.M.Ahamd)
 निदेशक/Director
 उ.पु.से.वि.न./Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 20-09-2021 to 26-09-2021

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	3,602	0
ASSAM	0	2,34,881
MANIPUR	0	430
MEGHALAYA	0	5,50,308
MIZORAM	352	0
NAGALAND	0	10,926
TRIPURA	0	0

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	1,771
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	15



 (एस.एम.आल्मोल/S.M.Almol)
 निदेशक/Director
 उत्तरी क्षेत्र/NERFC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 20-09-2021 to 26-09-2021

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	97737.7	25.7	97746.2	25.7	1.53	0.00	237	0	237
	132kV Khupi-Balipara	NP-9606-A	AS-55	55309.1	79.9	55300.9	79.9	-2.95	0.00	458	0	458
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	773.2	25711.2	773.2	25711.2	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	442.1	2153.5	442.1	2180.7	0.00	9.79	0	1,518	1,518
	Nirjuli-TRF 2	NP-9662-A	AR-02	502.2	2065.1	502.2	2090	0.00	8.96	0	1,389	1,389
	132kV Lekhi-Pare	NP-9607-A	PA-01	48638.8	167.3	48638.8	167.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	1194.4	7.4	1194.4	7.4	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	162.3	0	162.3	0	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	61.5	0.1	61.5	0.1	0.00	0.00	0	0	0
TOTAL												3,602

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	43339.8	80.1	43339.8	80.1	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	83152.3	6862.6	83362.1	6862.6	335.68	0.00	-52,030	0	-52,030
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	73062.7	98616.7	73062.7	98616.3	0.00	-0.40	0	62	62
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	73962.1	99218	73965.2	99217.6	3.10	-0.40	481	62	543
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28828.8	63.9	29186	63.9	571.52	0.00	-88,586	0	-88,586
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	33208.7	82263.4	33063	82263.4	-104.90	0.00	-16,260	0	-16,260
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	0	0	0	0	0.00	0.00	0	0	0
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99443	90314.1	99443	90122.3	0.00	-69.05	0	10,702	10,702
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21615.3	3240.7	21618.9	3240.7	0.65	0.00	-100	0	-100
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	84175.7	91177.8	84175.7	91177.8	0.00	0.00	0	0	0
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	88619.7	99935	88619.7	99935	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	88629.4	99980.9	88622.3	99980.9	-2.56	0.00	-396	0	-396
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	81882	99986.3	81846.8	99986.3	-12.67	0.00	-1,964	0	-1,964
	132kV BOKAJAN-DIMAPUR	NP-7587-A	AS-63	59812	98056	59812	97980.2	0.00	-54.58	0	8,459	8,459
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	99635.9	99838.4	99628.8	99838.4	-51.64	0.00	-8,004	0	-8,004
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1.3	97928.3	99999.9	97928.3	-10.18	0.00	-1,578	0	-1,578
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	83672.1	94248.3	83776.9	94351	37.73	36.97	5,848	-5,731	117
	220kV Mariani-AGBPP	NP-6888-A	AS-03	89314.1	96335.5	88550	96335.4	-1,222.56	-0.16	-1,89,497	25	-1,89,472
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	97242.3	1.6	97242.3	1.6	0.00	0.00	0	0	0
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	1985	258.9	1985	294.2	0.00	25.42	0	-3,939	-3,939
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	13940.5	88644.9	13940.5	87703.1	0.00	-339.05	0	52,552	52,552
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	48990.5	85310.8	48990.5	84324.9	0.00	-354.92	0	55,013	55,013
TOTAL												-2,34,881

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96182.9	99121.9	96183.3	99121.9	0.29	0.00	45	0	45
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	566.5	99940.7	567.1	99940.7	0.29	0.00	45	0	45
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99063.2	99898.5	99072.1	99898.5	3.20	0.00	-497	0	-497
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	20679.4	382.4	20687.7	382.4	2.99	0.00	-463	0	-463
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	18226.9	381.8	18234.1	381.8	2.59	0.00	-402	0	-402
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	47072.2	99426.8	47069.7	99426.8	-0.90	0.00	140	0	140
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94958.8	21.3	94952.5	21.3	-4.54	0.00	703	0	703
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-430


 (स.स.म.अलमो/S.M.Almo)
 निदेशक/Director
 उ.पु.वे.वि.न./NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95253	81174.4	95261.6	81174.4	6.19	0.00	960	0	960
	132kV KHLRT S-PG II	NP-6880-A	ME-09	28.5	20013.4	28.5	20013.4	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	86348.2	90862.4	86333.3	0.00	-23.84	0	-3,695	-3,695
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87021.2	96033.6	87021.2	96033.6	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	35446.2	99953.9	34463.5	99953.9	-3,573.45	0.00	-5,53,885	0	-5,53,885
TOTAL												-5,50,308
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	36541.4	80158.5	36542.1	80173.7	0.25	5.47	-39	848	809
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	78150.3	50062.7	78149.9	50065.4	-0.14	0.97	22	151	173
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69060.3	86427.9	69060.4	86427.9	0.00	0.00	6	0	6
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97823.7	31664.7	97818	31664.7	-4.10	0.00	-636	0	-636
TOTAL												352
NAGALAND	132kV DIMAPUR S-PG I	NP-5777-A	NG-11	96110.8	82516.9	96110.8	82688.8	0.00	123.77	0	-19,184	-19,184
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	71104.9	2737.8	71104.9	2816	0.00	56.30	0	8,727	8,727
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	8855.6	98539.2	8855.6	98537.4	0.00	-0.65	0	-100	-100
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44171.7	243	44171.7	246.4	0.00	1.22	0	-190	-190
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43621.1	244.2	43621.1	247.4	0.00	1.15	0	-179	-179
TOTAL												-10,926
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97040.7	84659.1	97040.7	84659.1	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10244.5	99635	10244.5	99635	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49182.9	93755.2	49182.9	93755.2	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68681.8	72313.5	68681.8	72313.5	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7203.6	99970.5	7203.6	99970.5	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14455.8	26	14455.8	26	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9349.2	99994.7	9349.2	99994.7	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	3779.9	99999.7	3779.9	99999.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1031.9	99999.6	1031.9	99999.6	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	903.3	99999.3	903.3	99999.3	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(सहायक महानिरीक्षक/स.म.अमोल)
निदेशक/Director
उप क्षेत्र/NERPC
विद्युत मंत्रालय/Min. of Power
नगर सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 20-09-2021 to 26-09-2021

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	75920.1	96263.9	75907.7	96261.7	-5.952	-1.056	-923	164	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94028.4	99157.2	94015.5	99153.1	-6.192	-1.968	-960	305	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	94643.5	99821.5	94643.5	99821.5	0	0	0	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	95527.6	99796	95527.6	99796	0	0	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92641.3	99994.6	92603.2	99994.6	-18.288	0	-2,835	0	0
			NP-8384-A	ME-01	94392	68520.2	94392	68520.2	0	0	0	0	
AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	98849.4	5950.3	98849.4	5974.1	0	11.424	0	-1,771	-1,771	
		NP-9071-A	ME-16	78466.3	25689	78466.3	25507.2	0	-87.264	0	13,526		
TOTAL													-1,771
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	6156.9	99983.2	6156.9	99983	0	-0.096	0	15	15
			NP-6892-B	TR-06	76321.8	96318	76321.8	96346.8	0	2.7648	0	-429	
TOTAL													15
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94036.6	99347.2	94036.6	99347	0	-0.096	0	15	0
			NP-9947-A	NG-02	99271.3	99982.8	99271.3	99979.9	0	-0.87	0	135	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आल्मोल/S.M.Almol)
 निदेशक/Director
 डायरेक्टोर/NERPC
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong