

**Format AS3: RRAS Provider Parameters by RPC**

**From:**NERPC

**To:** Nodal Agency (NLDC,Delhi)

(Name of RRAS Provider Generating Station)**Agartala Gas Based Power Station**

(Name of Owner Organization)**North Eastern Electric Power Corporation Limited (NEEPCO)**

**Validity of the Information**

**From:**16/06/2023

**To:** 15/07/2023

**Date:** June 15, 2023

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	4x21MW+2x23MW
b)	Total Installed Capacity (MW)	130
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	126
d)	Technical Minimum (MW)	69.28
e)	Type of Fuel	Natural Gas
f)	Region	N.E.R
g)	Bid area	Tripura
h)	Fixed Cost (Paise/kWh up to one decimal place)	<b>194.30 (for May,2023)</b>
i)	Variable Cost (Paise/kWh up to one decimal place)	<b>437.00 (for May,2023)</b>
j)	Ramp-Up Rate (MW/Min) for each unit	GTG 1-4: 2 MW/min STG1-2: 0.5 MW/min
k)	Ramp- Down Rate (MW/Min) for each unit	GTG 1-4: 2 MW/min STG1-2: 0.5 MW/min
l)	Start-up Time from Cold Start (in Min) & Warm Start of each unit	Cold Start GTG 1-4: 25 min STG1-2: 480-600 min
		Warm Start GTG 1-4: 25min STG1-2: 240min
m)	Any other information	Minimum Loading of Gas Turbines must be at least 18 MW each for taking individual HRSG into service

Signature of Authorized Signatory (With Stamp)



कार्पेयानक अभियंता Executive Engineer  
उ. पू. वि. स. N.E.R.P.C.  
विद्युत मंत्रालय Min of Power  
नया दिल्ली Govt of India  
शिलोंग Shillong

Name: Abhijeet Agrawal

Designation: Deputy Director (Commercial)

**Format AS3: RRAS Provider Parameters by RPC**

**From:**NERPC

**To:** Nodal Agency (NLDC,Delhi)

(Name of RRAS Provider Generating Station) **Assam Gas Based Power Station(Kathalgori)**

(Name of Owner Organization) **North Eastern Electric Power Corporation Limited(NEEPCO)**

**Validity of the Information**

**From:**16/06/2023

**To:** 15/07/2023

**Date:** June 15, 2023

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	6x33.5MW+3x30 MW
b)	Total Installed Capacity (MW)	291
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	110%
d)	Technical Minimum (MW)	155.65
e)	Type of Fuel	Natural Gas
f)	Region	N.E.R
g)	Bid area	N.E.R
h)	Fixed Cost (Paise/kWh up to one decimal place)	<b>196.20(for May',2023)</b>
i)	Variable Cost (Paise/kWh up to one decimal place)	<b>468.80(for May',2023)</b>
j)	Ramp-Up Rate (MW/Min) for each unit	GTG 1-4: 2.27MW/min GTG 5&6: 4.28 MW/min STG 1-3: 3.00MW/min
k)	Ramp- Down Rate (MW/Min) for each unit	GTG 1-4: 2.27 MW/min GTG 5&6: 4.28 MW/min STG 1-3: 3.00 MW/min
l)	Start-up Time (in Min) from Cold Start & Warm Start of each unit	Cold Start GTG 1-4: 28 min GTG 5&6: 22 min STG 1-3: 180 min
		Warm Start GTG 1-4: 13min GTG 5&6: 7 min STG 1-3: 30min
m)	Any other information	NIL

Signature of Authorized Signatory (With Stamp)



कार्यपालक अभियंता Executive Engineer  
उ. पू. बि. म. N.E.R.P.C.  
विद्युत मंत्रालय Min of Power  
भारत सरकार Govt of India  
शिलांग Shillong

Name: Abhijeet Agrawal

Designation: Deputy Director (Commercial)

**Format AS3: RRAS Provider Parameters by RPC**

**From:**NERPC  
(Name of RRAS Provider Generating Station) **LOKTAK HEP**  
(Name of Owner Organization) **NHPC Limited**

**To:** Nodal Agency (NLDC,Delhi)

**Validity of the Information**

**From:**16/06/2023

**To:** 15/07/2023

**Date:** June 15, 2023

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	3x35
b)	Total Installed Capacity (MW)	105
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	105 MW*
d)	Technical Minimum (MW)	N.A
e)	Type of Fuel	WATER
f)	Region	N.E.R
g)	Bid area	A1
h)	Fixed Cost (Paise/kWh up to one decimal place)	<b>194.5</b>
i)	Variable Cost (Paise/kWh up to one decimal place)	<b>194.5</b>
j)	Ramp-Up Rate (MW/Min) for each unit	30 MW per min
k)	Ramp- Down Rate (MW/Min) for each unit	30 MW per min
l)	Start-up Time from Cold Start (in Min) / Warm Start/Hot Start of each unit	15 min
m)	Any other information	

\* As per water availability

Signature of Authorized Signatory (With Stamp)

  
कार्यवाहक अभियंता Executive Engineer  
उ.पु. वि. म. N.E.R.P.C.  
विद्युत परामर्शक Min. of Power  
भारत सरकार Govt. of India  
शिलांग Shillong

Name: Abhijeet Agrawal  
Designation: Deputy Director (Commercial)

**Format AS3: RRAS Provider Parameters by RPC**

**From:**NERPC

**To:** Nodal Agency (NLDC,Delhi)

(Name of RRAS Provider Generating Station) **Bongaigaon Thermal Power**

**Plant** (Name of Owner Organization) **NTPC Limited**

**Validity of the Information**

**From:**16/06/2023

**To:** 15/07/2023

**Date:** June 15, 2023

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	3x250 MW
b)	Total Installed Capacity (MW)	750
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	239.06 MW per unit
d)	Technical Minimum (MW)	375.37
e)	Type of Fuel	Coal
f)	Region	N.E.R
g)	Bid area	N.E.R.
h)	Fixed Cost (Paise/kWh up to one decimal place)	<b>240.63</b>
i)	Variable Cost (Paise/kWh up to one decimal place)	<b>357.50</b>
j)	Ramp-Up Rate (MW/Min) for each unit	2.28 MW per min (ex Bus)
k)	Ramp- Down Rate (MW/Min) for each unit	2.28 MW per min (ex Bus)
l)	Start-up Time from Cold Start (in Min) / Warm Start/Hot Start of each unit	Cold Start: 600 min Warm Start: 360 min Hot Start: 66 Min
m)	Any other information	Warm start up time: 10 hr. (i.e. 600 min.) if RSD>12 hr. Cold start up time: 23 hr. (i.e. 1380 min.) if RSD>4 days as boiler will be kept under preservation

Signature of Authorized Signatory (With Stamp)

  
कार्यालयक अधिष्ठा Executive Engineer  
उ. पू. वि. म. N.E.R.P.C.  
विद्युत विभाग Min of Power  
भारत सरकार Govt of India  
शिलांग Shillong

Name: Abhijeet Agrawal

Designation: Deputy Director (Commercial)