

North Eastern Regional Power Committee

Agenda For

51st PCC Sub-Committee Meeting

Time of meeting : 10:00 Hrs.

Date of meeting : 9th August, 2018 (Thursday)

Venue : "Hotel Nandan", Guwahati.

A. CONFIRMATION OF MINUTES

CONFIRMATION OF MINUTES OF 50th MEETING OF PROTECTION SUB-COMMITTEE OF NERPC.

The minutes of 50th meeting of Protection Sub-committee held on 10th May, 2018 at Guwahati were circulated vide letter No. NERPC/SE/PCC/2018/2565-589 dated 23rd May, 2018.

The Sub-committee may confirm the minutes of 50th PCCM of NERPC as no comments/observations were received from the constituents.

ITEMS FOR DISCUSSION

1. FOLLOW UP OF REMEDIAL ACTIONS:

The suggested measures with status as per 50th PCC:

Sl. No	Name of element	Actions to be taken	Concerned Utilities	Status as per 50th PCC Meeting	Latest status
1	133 kV Lekhi - Nirjuli Line	Checking of healthiness of Protection System (Relays, Circuit breaker, DC system etc) of downstream substations	DoP, AP	Status could not be updated due to absence by DoP, AP	
2	132 kV Agia - Medipathar I line and 132 kV Mawngap - Nongstoin I line	Healthiness of Protection System at Nongstoin for 132 kV Mawngap - Nongstoin Line to be done by MePTCL.	MePTCL	Under PSDF works By Nov'18	
3	133 kV Agia - Medipathar I line and 132 kV Mawngap - Nongstoin I line	Checking of healthiness of Protection System (Relays, Circuit breaker, DC system etc) of downstream substations	MePTCL	Under PSDF works By Nov'18	
4	132 kV Kolasib-Badarpur line & 132	Relay Coordination to be done at Kolasib & downstream substations of Kolasib	P & ED Mizoram, NERTS	POWERGRID & P & ED Mizoram to co-ordinate the settings.	

Agenda for 51st PCC Meeting to be held on 9th August, 2018

	kV Kolasib-Aizwal line	by P&ED Mizoram.			
5	133 kV Aizawl - Zungtui Line	Checking of healthiness of Protection System (Relays, Circuit breaker, DC system etc) of downstream substations	P&ED Mizoram	P&ED Mizoram would revert back with the exact status.	
6	400 kV Azara - Bongaigaon Line	AEGCL(Azara) to keep the fault clearing time within 100 msec.	POWERGRID & AEGCL	Mail sent on 09.05.18. NERTS & AEGCL to revert back.	
7	132 kV AGTCCPP-Agartala	Over-reach of DPR at AGTCCPP. Setting to be revised after HTLS upgradation.	NEEPCO	Settings sent to NERTS. Conductor parameters to be confirmed and setting is to be changed accordingly.	
8	132 kV Rangia - Motonga	Checking of relay settings at Rangia	NERTS	NERPC written to NLDC vide letter dtd.07.05.18 AEGCL to provide DR and Relay flag of Rangia end of this line henceforth.	
9	400kV Balipara-BNC I&II	POR settings to be disabled. Till SVC is in service Z-I to be kept at 80%	NERTS	Oct'18	
10	220/132kV Dimapur ICT-1	Backup O/C, E/F settings to be reviewed such that it operates before Z-III at Misa	NERTS	May'18	
11	220kV Dimapur-Misa -2	Z-III protection timing to be reviewed such that it operates after operation of backup of ICT at Dimapur	NERTS	May'18	
12	132kV Bus Bar at Palatana	Healthiness/operation of bus bar protection need to be reviewed	OTPC	May'18.	

Agenda for 51st PCC Meeting to be held on 9th August, 2018

13	220 kV BTPS - Salakati	05.04.2018 14:24 hrs. Root cause not concluded due to unavailability of DR / EL outputs. Unwanted operation of Trip relay at BTPS to be investigated y AEGCL	AEGCL / NERTS	DR erased due to frequent pickup of Earth fault function. Y-ph current pickup but not trip. NERTS to check and revert back.	
14	Blackout of 220 kV Mariani(PG) on 06.03.18	POWERGRID to review over voltage setting at Mariani and Mokokchung SS and time grading may be provided.** Issue of non-tripping at AGBPP end of Mariani(PG)-AGBPP line & at Misa end of Mariani(PG)-Misa line are to be attended.	NERTS/NEEPCO	No trip at AGBPP & Misa due to carrier not being in service. Both implementations of O/V settings(settings suggested by subgroup) and attending issue with the carrier by May'18.	
15	Disturbance in Tripura on 22nd, 26th & 31st Mar'18 and 30th Apr'18 Fault in 132 kV Rokhia - Agartala D/C. Delayed fault clearance due to absence of DPR.	Status of Installation of DPR in 132 kV Rokhia - Agartala D / C	TSECL	Aug'18	
		O / C & E / F co- ordination after installation of DPR		Aug'18	
		Review of Z-II (to be 150% of line length) settings at SM Nagar for Agartala D / C		May'18	
		R & B phase analog DR input to be reversed at SM Nagar.		May'18	
		Review of Z-II (to be 120% of line length) settings at Budhajagar for Agartala line		May'18	
		Review of Z-II & Z-III settings at Palatana for SM Nagar line. Adopted CT ratio & CT ratio in relay settings at Palatana for SMNagar line to be checked.	OTPC	May'18	

Agenda for 51st PCC Meeting to be held on 9th August, 2018

16	132 kV AGTCCPP - Agartala D/C on 31.03.18	Installation of Line Differential in 132 kV AGTCCPP - 79 Tilla D/C & Review of impedance setting of both ends as a temporary measure.	NERTS/NEEPCO	LDP 132kv AGTCCPP- 79Tilla D/C - Dec'18 Review of settings after confirmation of impedance, by May'18.	
17	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	Healthiness of Protection System at Khliehriat end & Leshka end of 132 kV Khliehriat - Leshka D/C line to be ensured, Z-II settings at KHL(MePTCL) for Leshka lines to be reduced.	MePTCL	By May'18	
18	400 kV Balipara - Biswanath Chariali 4 Line	Review of DPR settings to clear the fault within limits allowed in CEA standards	NERTS	By May'18	

Concerned utilities may please intimate the latest status.

A. OLD ITEMS

A.1 Third Party Protection audit of NER Sub-Stations

The 48th PCC Forum decided that Report of 1st Phase of 3rd Party Protection Audit of NER Substations has to be completed by the Committee formed during Subgroup Meeting held on 06.12.17 by 31.01.18, only after which the 2nd Phase of 3rd Party Protection Audit shall be started. DGM, NERLDC informed the Forum that the report shall comprise of both recommendations as well as action plans. Corrective actions that are taken by Power Utilities against observations of audit team may be monitored in the PCC Meeting.

The Forum discussed the audit procedures followed for +/- 800 kV Biswanath Chariali HVDC Station as it is different from other substations. NERLDC expressed that the DC protection part is complex and would need more than 1 day to audit the entire Substation.

Member Secretary, NERPC requested POWERGRID to find out the audit procedures of other HVDC stations outside NER like +/- 500 kV Rihand – Dadri, +/- 500 kV Talcher – Kolar HVDC Station etc, which can be practiced in NER as well.

Member Secretary informed the forum that proposal has been sent recently for obtaining Protection Database Management System(PDMS) from PSDF. PDMS will comprise of mainly 2 parts: i) Collection of data from all stations of NER and ii)

Collection of Settings. This will make the auditing practice easier as unavailability of Data and Settings is one of the common issue that has been observed during 1st phase of 3rd Party Protection Audit.

Also, NERLDC informed the forum that as per draft “Reliability Standard for Protection System”, periodic protection audit has to be conducted once in year for critical substation and once in four years other substations. Subgroup had discussed to find out the list of critical substations in the Meeting held on 6th December, 2017. After detailed deliberation, forum finalized the **critical substations of NER** and are as follows:

- a. **POWERGRID: 400/220/33 kV Balipara, 400/132 kV Biswanath Chariali, 400/220/33 kV Bongaigaon, 400/220/33 kV Misa, 400/132/33 kV Silchar, 220/132 kV Dimapur, 220 kV Mariani (PG), 220/132 kV Salakati**
- b. **NEEPCO: 400/132 kV Ranganadi, 220/132 kV AGBPP**
- c. **OTPC: 400/132 kV Palatana**
- d. **NTPC: 400/220 kV BgTPP**
- e. **AEGCL: 400/220 kV Azara, 220/132/66/33 kV Agia, 220/132/33 kV BTPS, 220/132/66/33 kV Mariani, 220/132/33 kV Samaguri, 220/132/33 kV Sarusajai, 220/132 kV Sonabil**
- f. **MePTCL: 400/220/132 kV Byrnihat (Killing)**
- g. **TSECL: 132/33/11 kV Agartala (79 Tilla), 132/33 kV Surajmani Nagar**

In 50th PCCM, CM, NERTS informed that the all audit reports have been completed except Assam. AM, AEGCL informed that Assam Audit Report would be submitted by 10.05.2018.

SE(O&P), NERPC informed that a meeting would be convened tentatively in the last week of May'18 to discuss the findings of the Protection Audit. He requested concerned members to attend the meeting, date and venue of which would be intimated in due course of time.

Members may please discuss

A.2 Standardization of Disturbance Recorder Channels:

In 49th PCCM, AEGCL representative informed that for remaining 6 sub-stations standardization would be completed by May'18. E E (System Protection), MePTCL informed that after obtaining the ABB software from AEGCL, the standardisation for remaining stations of Mendipathar SS, Killing SS, Stage III PS and Stage IV PS will be completed by 30.04.2018. The forum requested NERLDC to circulate the DR template to all concerned utilities.

SE(O&P), NERPC suggested that during erection works under R&U scheme the commissioning engineers should do the work of DR channel standardization.

In 50th PCCM, NERLDC informed the forum that list of elements for which DR standardization has been completed will be circulated to all constituents. Forum requested all constituents to update the status.

SE(O&P),NERPC requested other utilities to submit a schedule in alignment with R&U works.

Format for DR standardization (formulated by POWERGRID) is for One and Breaker scheme and DMT scheme. Few modifications are required for other bus schemes.

A common format may be formulated for other bus schemes.

Members may please discuss

A.3 Implementation of SPAR

In 48th PCCM, NTPC informed the forum that they are having problem with implementation of the scheme due to coordination issue between differential and distance protection. POWERGRID informed that they will take up the issue.

NERLDC suggested to the forum that Single Phase/Three Phase Auto-reclosing scheme as applicable considering breaker mechanism has to be implemented in all the lines to ensure reliability. For Single pole breaker, Single Phase Auto reclosing scheme has to be enabled for maintaining synchronism through other healthy phases. Also, priority scheme is to be ensured in one and half breaker scheme.

The committee requested all constituent to furnish the status report of SPAR implementation to NERPC and NERLDC latest by 31st January, 2018.

In 49th PCCM, DM(E/M), NEEPCO enquired whether there are any specific guidelines regarding activation of A/R for lines connecting two generating stations eg. 132kV Khandong-Kopili D/C. NERLDC informed the forum that as per Central Electricity Authority (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2010, 3 ph A/R should be in place for 132 kV lines. EE,SP, MePTCL informed that a feasibility report regarding implementation of A/R in MeECL system would be submitted by Apr'18. The forum decided that availability of A/R facility would be specifically mentioned in the Protection Audit Report. It was also discussed that once installation of Numerical Relays under PSDF scheme is done, the implementation of Auto-reclosing schemes in all the states can be done more effectively.

In 50th PCCM DM(E/M), NEEPCO once again re-iterated that for 132kV Khandong-Kopili D/C a detailed study is required regarding which end should be dead sync and which end check sync as both end involve generator. He informed that it would be a retrograde step to implement 3-ph A/R for 132kV Khandong-Kopili D/C.

OTPC representative also expressed similar concerns regarding 132kV Palatana - SMNagar because of poor fault clearing times at 132kV SM.Nagar and beyond.

DGM(SO-II), NERLDC informed that as per CEA (Technical Standards for Construction of Electric Plants and Lines) Regulations, 2010 it is mandatory to implement A/R for all 132kV and above lines. Members noted the concern of OTPC & NEEPCO and decided that the matter would be referred to CEA/NPC with 3-ph fault levels of the respective buses.

A list detailing the status of implementation of A/R for different lines is attached at **Annexure-A.3**. SE(O&P),NERPC requested all the utilities to update the status in the attached list before the next meeting.

The matter of A/R for 132kV Khandong-Kopili D/C was referred to NPC for resolution. NPC vide letter dated. 03.07.2018 has provided the following input:

"NPC is of the view that the Auto-Reclosure between two generating stations can be avoided considering stress on generators. However if required, from grid consideration the same may be got studied through an expert and implemented accordingly."

Members may please discuss.

A.4 Disturbance in Tripura System

As discussed in previous PCC meeting there have been a number of disturbances in Tripura system. However no fruitful resolution was achieved due to non-participation by TSECL. Brief recommendations of 48th PCC are as follows:

- Non-directional E/M relays for O/C, E/F at PKBari to be made directional
- Installation of Numerical relay at 132kV PKBari
- Installation of Line differential relay for 132kV PKBari - Kumarghat

These are to be addressed immediately.

Further Kumarghat blackout happened on 04.02.18. This could not be analysed in the Sub-group meeting on 06.03.18 due to absence of DR/EL outputs from Tripura.

In 50th PCCM Sr. Manager, TSECL informed that R&U works have been taken up in earnest. He informed that works at 79Tilla, Rokhia, Udaipur and PKBari would be carried out with utmost priority. The approximate timeline agreed by TSECL is as follows:

<u>Name of sub-station</u>	<u>Time of completion</u>
79Tilla	Jul'18
Rokhia	Aug'18
Udaipur	Oct'18
PKBari	Oct'18

Members requested that in view of the large number of grid incidences concerning Tripura, the R&U works be expedited ASAP. Forum requested TSECL to ensure installation of DPR at both ends of the lines emanating from these substations.

CM, NERTS informed that Line Differential Relay for 132kV PK.Bari-Kumarghat and 132kV AGTCCPP-Agartala D/C would be commissioned by Dec'18.

NERTS/TSECL may please update the status.

A.5. Identification of short lines to install line differential protection

As per deliberation of 47th PCC Meeting of NERPC, it was decided to change the criterion for installation of Line Differential Protection (LDP) in 132 kV lines from 5 kms. to 10 kms to cover important lines of NER like 132 kV AGTCCPP – Agatala D/C.

During 47th PCC Meeting of NERPC, Member Secretary, NERPC requested all constituents make a list of following information:

List of all short lines.

List of lines where differential protection was commissioned.

List of all short lines where differential protection was installed but not commissioned.

List of all short lines where installation of differential protection is envisaged

The forum requested all states to make the above-mentioned list and make DPR for PSDF funding for installation of differential protection.

In 50th PCCM Sr. Manager, TSECL informed that 132kV 79Tilla-Bodhjannagar is to be included in the list of lines for Line Differential Protection. CM, NERTS stated that FO between two stations are essential for implementing Line Differential Protection in the line. In this regard SE(O&P), NERPC requested all states to approach for PSDF funding under 'Reliable Communication' category. He also requested all STUs to kindly prepare a list of lines of length less than 10km and submit before next PCCM. NERLDC informed that a list has been prepared for important grid elements under the category of short lines and the same is attached at **Annexure A.5** for reference.

SE (O&P) requested all states to identify short lines in their power system for installation of LDP. MePTCL representative informed that MePTCL has already submitted DPR for Line Differential Protection and Reliable Communication factoring in the FO and allied materials required for line differential protection and both DPRs are awaiting approval of Appraisal Committee. NERTS informed that 15 Nos. of lines has been identified for installation of LDP and expected to be commissioned by Dec'18.

Members may please discuss.

A.6 Tripping of 400kV BgTPP-Bongaigaon-I on 08.05.18:

400 kV Bongaigaon - BgTPP Line I tripped at 17:39 Hrs on 08.05.18 due to DT Received from Bongaigaon.

400 kV Bongaigaon - BgTPP I Line had also tripped on 06.10.17 at 15:50 Hrs due to DT received at BgTPP end and no tripping at Bongaigaon.

Tripping of 400 kV Bongaigaon - BgTPP I and II Lines is a very critical issue and pose a threat to the security and reliability of the grid.

In 50th PCCM CM, NERTS informed that on 08.05.18 due to Main DC(+/- 220V) Mixing, DT was send to BgTPP from the respective PLCC panel. Mixing of DC (220 V & 48 V) occurred due to DC earth fault at Bongaigaon(PG). AGM(OS), NTPC opined that since the problem was recurring in nature, PLCC panels may be checked immediately. He also suggested that inter-trip for main protection may be shifted to OFC for Line Differential protection, by using the spare core. It was decided that NERTS would investigate the issue thoroughly and rectify the issue at the earliest.

NERTS may please intimate the status.

A.7 Technical presentation in PCCM:

In 50th PCCM SE(O&P), NERPC stated that as decided in earlier PCC meeting; technical presentation would be given on important topics once PCC deliberations are completed. It was decided that on the 51st PCC meeting, presentations on (1)Ramakrishna Task Force Recommended settings by NERTS (2) D/R inference and analysis will be given by NERTS.

NERTS may please give the presentation.

B. NEW ITEMS

B.1 Actions recommended by Sub-group:

The Sub-group in its meeting held on 29.06.18 & 02.08.2018 recommended the following actions:

Agenda for 51st PCC Meeting to be held on 9th August, 2018

Sl. No	Brief details of the disturbance/incidence	Actions to be taken	Concerned Utilities	Latest Status
1	220kV Misa blackout and loss of generation of Khandong and Kopili on 21.05.18 **	ICT-2 at Misa delayed fault clearance is to be analysed.	NERTS	
		O/C settings for 132 kV Khliehriat – Khandong -I to be checked.	NERTS/NEEPCO	
		Z-2 overlapping of 220 kV Misa - Samaguri and 220 kV Samaguri -Sarujajai to be checked.	AEGCL/NERTS	
2	Faults in 132kV 79Tilla-Rokhia D/C	Rokhia E/F relay to be made directional. OR Directional Earth Fault function of DPR is to be enabled and then disable backup earth fault relay (EM).	TSECL	
3	Tripping of 400kV Silchar-Byrnihat and 400kV Silchar-Azara on 18.06.18	Tower top patrolling to be undertaken to identify the exact location of the fault.	NERTS	
		Reason for DPR (Main-2) overreach at Bongaigaon is to be investigated	NERTS	
		A separate group of settings for Micom P 444 to be activated with Zone 1 setting =60% when the parallel circuit is earthed at both ends for maintenance.	NERTS	
		Reasons for non-operation of R-ph CB for 132kV Dimapur-Imphal to be investigated	NERTS	
4	Repeated trippings of 132kV Doyang-Mokokchung and 132kV Mokokchung-Mokokchung D/C	Timings at 132 kV Mokokchung(PG) and 132kV Doyang to be increased.	NERTS/NEEPCO	
		Relay and protection system healthiness of all elements to be checked at Mokokchung(NAG).	DoP Nagaland	
5	Tripping of 132kV Khliehriat-Khliehriat D/C on 09.05.18	Reasons for non-tripping of 132 kV NEHU-Khliehriat line from NEHU end and 132 kV Mustem –	MePTCL	

Agenda for 51st PCC Meeting to be held on 9th August, 2018

		Khliehriat line from Mustem end are to be investigated.*		
		Reasons for non-operation of bus bar protection at Khliehriat(ME).	MePTCL	
		Z-III timing of 132 kV Khliehriat (PG) for 132 kV Khliehriat-Khliehriat Line 2 is to be checked	NERTS	Done
6	Jiribam blackout on 06.06.18	Z-III timing at Jiribam reduced to 200ms for 132kV Jiribam-Pailapol.	NERTS	Done
		Downstream settings at Pailapol to be coordinated if not done	AEGCL	
		Protection settings and relay healthiness for 132kV Pailapol-Srikona at Pailapol to be ensured	AEGCL	
7	Tripping of 400kV Palatana-Silchar D/C on 11.05.18	Non attempt of Auto recloser at Palatana of 400 kV Silchar – Palatana 2 line to be investigated	OTPC	
8	Tripping of 220kV Misa-Byrnihat-I on 09.05.18	Maloperation of Earth Fault relay at Misa to be attended	NERTS	
9	Repeated trippings of Silchar ICT-I in June	Opto i/ps to Main protection becoming high upon relay restart. Matter has been referred to OEM. Meanwhile to prevent such mal operation, delay of 19 mS has been introduced to all binary inputs.	NERTS	Done
10	Tripping of ICT at Bongaigaon and 400kV Bongaigaon-BgTPP-II	Due to DC earth fault.	NERTS	Rectified.
11	Repeated tripping of 400kV Palatana-Silchar-2	Maloperation of B/U impedance relay. DT send due to relay restart/self-restart to be investigated.	NERTS	
12	Tripping of ICT-II at BgTPP on 30.07.2018	Reasons for PRV operation to be intimated.	NTPC	
13	Tripping of Balipara ICT on 04.07.18	Maloperation of R-ph WTI & OTI due to burning of control wires in the marshalling box. Proper covers to be provided.	NERTS	Already completed.
14	Tripping of 400kV Balipara-Bongaigaon-3 on	Maloperation of O/C relay at Bongaigaon	NERTS	

Agenda for 51st PCC Meeting to be held on 9th August, 2018

	26.07.18			
15	Repeated tripping of 400kV Balipara-Bongaigaon-3	Resistive reach to be reviewed at both ends	NERTS	
16	Tripping of 220kV Misa-Samaguri-2 on 02.07.18	SOTF operation while transferring from one bus to another(non-operation of changeover switch) at Samaguri.	AEGCL	
17	Aizawl blackout on 12.08.18	CT blast in one of the 33kV feeders at Kolasib. Healthiness of protection system of faulty 33kV feeder to be checked.	P&ED Mizoram	
		LBB operation at Aizawl due to non-extension of relay trip signal. Old 7SA51 relay at Aizawl to be replaced.	NERTS	Completed
18	Tripping of 132kV Bus-B at RHEP due to bus differential on 07.07.18	Failure of bus post insulator of 132kV RHEP-Chimpu. To be replaced.	NEEPCO	Done
		Bus bar protection to be configured in DR of all elements at RHEP.	NEEPCO	
19	Repeated Tripping of 132kV Palatana-SMNagar and 132kV SMNagar-Comilla	DPR at Palatana over-reached. Settings to be reviewed and DPR tested.	OTPC	
20	Tripping of 132kV Rangia-Motonga-I on 20.07.18	DR standardization to be done at Rangia.	NERTS	
21	Repeated tripping of 400kV Silchar-Azara	Resistive reach of DPR to be reviewed at both ends.	NERTS	

**** Deliberation in 146th OCC vis-a-vis operational recommendations:**

The forum took due note of the findings and recommendations of the Sub-group w.r.t. Misa Disturbance. DGM (AM), NERTS opined that all CT, PT are not to be replaced due to failure of one PT. He recommended that by mere age the equipments replacement should not be done unless there is some indicative problem found during diagnostic testing. NERLDC informed the forum that in existing 220kV Bus Bar Protection there are some feeders where 3 core CTs are used. DGM (AM), NERTS informed that the existing 220kV Bus Bar Protection at Misa is already obsolete and under ongoing NERSS VII scheme the 220kV Bus Bar Protection and all 3 Core CTs will be replaced.

Sr. Manager, NEEPCO informed that at Khandong SY, Transfer Isolator is present but not used due to bus bar conductor limitation (ACSR Zebra). Further Main Bus Conductor is to be upgrades to HTLS Zebra(already approved in SCM). DGM(AM) suggested that the upgradation of 132kV Khandong - Kopili Ckt#II to HTLS be included in the MoM of 7th SCM.

* MePTCL informed in the Sub-group meeting that 132kV NEHU- Khliehriat-I is LILO at 132kV Mustem. He informed that the zone timings for 132kV NEHU-Mustem and 132kV Mustem-Khliehriat are to be coordinated.

Members may please discuss.

B.2 Tripping due to downstream fault or fault beyond the lines:

In the deliberations of the Sub-group it has been observed that a number of lines are being tripped due to downstream fault or fault beyond the lines. The list is enumerated below:

- 132kV Silchar(PG)-Hailakandi(AS) D / C
- 132kV Khliehriat(PG) - Khliehriat(MEG)-II
- 132kV Imphal(PG) - Imphal(MAN) -D / C
- 132kV Haflong(PG) - Haflong(AS)
- 132kV Pare(NEEPCO) - Lekhi(AP)
- 132kV Doyang(NEEPCO) - Mokokchung(NAG)
- 132kV Doyang(NEEPCO) - Sanis(NAG)

Concerned utilities may kindly submit the status for (i) relay setting co-ordination with downstream, (ii) healthiness of protection system for downstream feeders.

Members may please discuss.

B.3 Repeated trippings due to vegetation:

In the deliberations of the Sub-group it has been observed that a number of lines are tripping due to vegetation overgrowth i.e. transient tripping almost continuously throughout the year.

Month	Name of line/ No. of trippings		
	132kV Balipara-Khupi	132kV Dimapur-Kohima	132kV Aizawl-Kumarghat
Jan'18	2	1	1
Feb'18	1	1	2
Mar'18	3	4	1
Apr'18	4	1	2
May'18	0	0	4
June'18	4	6	3
July'18	6	4	4

For this patrolling reports and self-certification of vegetation clearance is to be submitted by the concerned utilities. The item has been included in the 147th OCCM also.

Also the following lines have been observed to have tripped frequently on transient faults due to vegetation in the months of May-Jul'18:

- 400kV Balipara- Biswanath Chariali -II
- 400kV Silchar - Azara
- 400kV Balipara - Bongaigaon-III

Agenda for 51st PCC Meeting to be held on 9th August, 2018
NERTS may please certify the vegetation clearance for the above critical corridors.

Members may please discuss.

AGENDA ITEMS FROM NERLDC:

B.4 Approval of protection settings to be adapted by NERPC secretariat for 1st time charging of any new elements to the grid

Before 1st time charging of any new elements to the grid, applicant must apply for approval of protection settings to be adapted to NERPC secretariat.

For ensuring the safe and secure operation of the grid, 1st time charging request will be processed by NERLDC after implementation of approved settings.

NERLDC may please deliberate.

B.4 Protection database

For preparation of a basic protection database of North Eastern region, Power Utilities of NER are requested to check and verify the following details attached as **Annexure-I**. Updated Annexure-I will be presented in the meeting.

Sl No	Details Required	Remarks
1	Adopted CT Ratio, PMS and TMS of Over Current Relay, Current Rating of Terminal Equipments (Isolator, wavetrap etc), Conductor Type & any other limitations, if any	To calculate the Max. allowable Line Loading
3	Availability of DR & EL (Element wise & Protection wise in case of stand-alone DR & EL not available) and DR standardization	For event analysis
5	Details of Polymer Insulator, TLSA of lines	
6	Relay Details with present settings , Auto Recloser facility in lines	

Utilities are requested to check and verify the data provided in the Annexure-I and also provide the data is missing.

Utilities are requested to update the document and email to NERLDC (nerldcprotection@posoco.in) by 31st Aug'18.

NERLDC may please deliberate.

B.5 Tripping Monitoring System Web portal for DR & EL output and FIR

Web portal has been developed by POSOCO for furnishing DR & EL outputs and FIR along with documentary evidences for each grid events by concerned utilities. Tripping of important grid elements will be made available in the web portal by NERLDC.

Utilities are requested to upload DR & EL outputs and FIR along with documentary evidences for the events pertaining to them through this web portal within 24 Hours of an grid event.

NERLDC will explain the procedure for uploading DR & EL outputs and FIR to constituents in the meeting.

Members may please discuss.

B.6 Analysis & Discussion on Events, Grid Incidences, Grid Disturbances which occurred in NER Grid w.e.f 1st May 2018 – 31st July 2018.

The following numbers of Grid Disturbances (GD) & Grid Incidents (GI) occurred during the period **w.e.f 1st May 2018 – 31st July 2018**:

Sl. No.	Control Area	Grid Incident s in nos. (May'18 to Jul'18)	Grid Disturbanc e in nos. (May'18 to Jul'18)	Grid Incident s in nos. (Jan'18 to Jul'18)	Grid Disturbanc e in nos. (Jan'18 to Jul'18)
1	Palatana	7	1	12	1
2	AGBPP	8	0	21	0
3	AGTPP	4	1	28	2
4	Ranganad i	0	0	0	0
5	Kopili	5	1	10	1
6	Khandong	6	2	7	2
7	Doyang	2	1	2	1
8	Loktak	0	1	0	1
9	BgTPP	9	0	18	0
10	Pare	4	0	4	0
11	Arunacha l Pradesh	3	12	3	29
12	Assam	0	16	0	25
13	Manipur	0	13	0	15
14	Meghalay a	0	9	0	9
15	Mizoram	0	6	0	13
16	Nagaland	0	17	0	31
17	Tripura	0	11	0	25

Sl. No.	Category of GD / GI	Grid Disturbance in nos.	
		May'18 to Jul'18	Jan'18 to Jul'18
1	GI-I	16	53
2	GI-II	29	49
3	GD 1	72	127
4	GD 2	0	1
5	GD 3	1	1
6	GD 4	0	0
7	GD 5	0	0

8	Total GI	45	102
9	Total GD	73	129

This is for information to the members.

B.7 Non-furnishing of DR/EL:

DR/EL are not being furnished timely or not at all by various utilities. The status is given at **Annexure-B.7.**

NERLDC may please deliberate.

AGENDA ITEM FROM NERTS:

B.8 Installation of Line Differential Relays in Transmission Line length less than 10 Km.

In various PCC Meetings, deliberations in regard to installation of Line Differential Relays for short lines was done and finally, in 50th PCC Meeting it has been decided to install Line Differential Relays for lines having length less than 10 Km. Accordingly, following lines are worked out for installation of Line Differential Relays:

SN	Line	Length (CKm)
1	132kV D/C RC Nagar – Agartala - I	8.38
2	132kV D/C RC Nagar – Agartala - II	8.38
3	132kV D/C Mokokchung – Mokokchung - I	1.70
4	132kV D/C Mokokchung – Mokokchung - II	1.70
5	132kV S/C Aizawl – Melriat	12.00
6	132kV S/C Badarpur – Badarpur	1.02
7	132kV S/C Imphal – Imphal – I	1.50
8	132kV S/C Imphal – Imphal – II	1.50
9	132kV S/C Kumarghat – PK Bari	5.00
10	132kV S/C Khliehriat – Khliehriat - I	7.8
11	132kV S/C Dimapur (PG) – Dimapur (S) - Old	0.65
12	132kV S/C Dimapur (PG) – Dimapur (S) - New	0.65
13	220kV S/C Balipara - Tezpur	8.62
14	220kV Salakati – BTPS - I	2.70
15	220kV Salakati – BTPS - II	2.70

The tentative expenditure for **(1) Procurement of Relays, FO Cables, Connectors etc.** and **(2) OPGW for lines in SN 8 & 12** will be approximately **Rs. 1.70 Crores (One Crores Seventy Lakhs Only)**. POWERGRID proposes to execute the job and recover the expenditure on PoC Mechanism obtaining approval of TCC & NERPC.

NERTS may please deliberate.

B.9 Status of Installation of Line Differential Relays in Transmission Line length less than 10 Km.

Following is the list of lines where it is proposed to install Line Differential Relays:

SN	Line	Length (CKm)
1	132kV D/C RC Nagar – Agartala - I	8.38
2	132kV D/C RC Nagar – Agartala - II	8.38
3	132kV D/C Mokokchung – Mokokchung - I	1.70
4	132kV D/C Mokokchung – Mokokchung - II	1.70
5	132kV S/C Aizawl – Melriat	12.00
6	132kV S/C Badarpur – Badarpur	1.02
7	132kV S/C Imphal – Imphal – I	1.50
8	132kV S/C Imphal – Imphal – II	1.50
9	132kV S/C Kumarghat – PK Bari	5.00
10	132kV S/C Khliehriat – Khliehriat - I	7.8
11	132kV S/C Dimapur (PG) – Dimapur (S) - Old	0.65
12	132kV S/C Dimapur (PG) – Dimapur (S) - New	0.65
13	220kV S/C Balipara - Tezpur	8.62
14	220kV Salakati – BTPS - I	2.70
15	220kV Salakati – BTPS - II	2.70

Status of Relays

Schedule for procurement of Line Differential Relays, FO Cables, Connectors etc. is as below:

- T&A Approval : 31.08.2018
- NIT : 30.09.2018 (After approval of NERPC)
- OBD : 15.01.2019
- LOA : 15.02.2019

Status of OPGW

The status of OPGW of various lines for installation of Line Differential Relays is as below:

SN	Transmission Lines	Name of Project	Completion Status
1	132KV D/C RC Nagar-Agartala-I	NERFO Expansion	Completed
2	132KV D/C RC Nagar-Agartala-II	NERFO Expansion	Completed
3	132kV D/C Mokokchung – Mokokchung - I	MW Vacation	WIP Nov'18

SN	Transmission Lines	Name of Project	Completion Status
4	132kV D/C Mokokchung – Mokokchung - II	MW Vacation	WIP Nov'18
5	132 KV S/C Aizwal - Melriat	MW Vacation	Completed
6	132KV S/C Badarpur - Badarpur	MW Vacation	Completed
7	132 KV S/C Imphal - Imphal-I	MW Vacation	WIP October'18
8	132 KV S/C Imphal - Imphal-II	To be awarded	January 2019
9	132 KV S/C Kumarghat - PK Bari	Tripura state line	NA
10	132 KV S/C Khliehriat-Khliehriat-I	NERFO Expansion	WIP November'18
11	132KV Dimapur (PG)-Dimapur (S) - Old	NERFO Expansion	WIP November'18
12	132KV Dimapur (PG)-Dimapur (S) - New	To be awarded	February 2019
13	220 KV S/C Balipara-Tezpur	AEGCL	NA
14	220KV Salakati-BTPS-I	NERFO Expansion	Yet to Start August'19
15	220KV Salakati-BTPS - II	NERFO Expansion	Yet to Start August'19

This is for information please.

ADDITIONAL AGENDA FROM NERPC:

B.10 Draft Reliability Standards:

The draft reliability standards are available at:

http://www.cea.nic.in/reports/committee/nrce/rel_stand_pcs_minutes-5.pdf

http://www.cea.nic.in/reports/committee/nrce/rel_stand_pcs_minutes-4.pdf

http://www.cea.nic.in/reports/committee/nrce/rel_stand_pcs_minutes-3.pdf

http://www.cea.nic.in/reports/committee/nrce/rel_stand_pcs_minutes-2.pdf

http://www.cea.nic.in/reports/committee/nrce/rel_stand_pcs_minutes-1.pdf

Members may please give their comments.

NERPC may please deliberate.

Any other item:

Date and Venue of next PCC

It is proposed to hold the 52nd PCC meeting of NERPC on second week of October, 2018. The date & exact venue will be intimated in due course.

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
1	132 kV	132 kV South Comilla (Bangladesh) - Surajmani Nagar	1	D/C	PGCB	TSECL	47.0	POWERGRID	Information not Available	
2	132 kV	132 kV South Comilla (Bangladesh) - Surajmani Nagar	2	D/C	PGCB	TSECL	47.0	POWERGRID	Information not Available	
1	132 kV	132 kV Gelyphu (Bhutan) - Salakati	1	S/C	BPCL	POWERGRID	49.2	POWERGRID	SPAR in service	
2	132 kV	132 kV Motonga (Bhutan) - Rangia	1	S/C	BPCL	AEGCL	49.0	POWERGRID & BPC	Information not Available	
1	400 kV	400 kV Azara - Bongaigaon	1	D/C	AEGCL	POWERGRID	162.9	NETC(1.8%) & AEGCL (98.2%)	SPAR in service	
2	400 kV	400 kV Azara - Silchar	1	D/C	AEGCL	POWERGRID	256.0	NETC(37.5%) & AEGCL(62.5%)	SPAR in service	
3	400 kV	400 kV Balipara - Biswanath Chariali	1	D/C	POWERGRID	POWERGRID	60.0	POWERGRID	SPAR in service	
4	400 kV	400 kV Balipara - Biswanath Chariali	2	D/C	POWERGRID	POWERGRID	60.0	POWERGRID	SPAR in service	
5	400 kV	400 kV Balipara - Biswanath Chariali	3	D/C	POWERGRID	POWERGRID	57.1	POWERGRID	SPAR in service	
6	400 kV	400 kV Balipara - Biswanath Chariali	4	D/C	POWERGRID	POWERGRID	57.1	POWERGRID	SPAR in service	
7	400 kV	400 kV Balipara - Bongaigaon	1	D/C	POWERGRID	POWERGRID	289.7	POWERGRID	SPAR in service	
8	400 kV	400 kV Balipara - Bongaigaon	2	D/C	POWERGRID	POWERGRID	289.7	POWERGRID	SPAR in service	
9	400 kV	400 kV Balipara - Bongaigaon	3	D/C	POWERGRID	POWERGRID	304.6	POWERGRID	SPAR in service	
10	400 kV	400 kV Balipara - Bongaigaon	4	D/C	POWERGRID	POWERGRID	304.6	POWERGRID	SPAR in service	
11	400 kV	400 kV Balipara - Misa	1	D/C	POWERGRID	POWERGRID	95.9	POWERGRID	SPAR in service	
12	400 kV	400 kV Balipara - Misa	2	D/C	POWERGRID	POWERGRID	95.9	POWERGRID	SPAR in service	

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
13	400 kV	400 kV Biswanath Chariali - Ranganadi	1	D/C	POWERGRID	NEEPCO	131.0	POWERGRID	SPAR in service	
14	400 kV	400 kV Biswanath Chariali - Ranganadi	2	D/C	POWERGRID	NEEPCO	131.0	POWERGRID	SPAR in service	
15	400 kV	400 kV Bongaigaon - Byrnihat	1	D/C	POWERGRID	MePTCL	203.5	NETC(97.91 %) & MePTCL(2.09%)	SPAR in service	
16	400 kV	400 kV Binaguri - Bongaigaon	1	D/C	POWERGRID	POWERGRID	218.0	POWERGRID	SPAR in service	
17	400 kV	400 kV Binaguri - Bongaigaon	2	D/C	POWERGRID	POWERGRID	218.0	POWERGRID	SPAR in service	
18	400 kV	400 kV Alipurduar - Bongaigaon	1	D/C	POWERGRID	POWERGRID	106.0	ENICL	SPAR in service	
19	400 kV	400 kV Alipurduar - Bongaigaon	2	D/C	POWERGRID	POWERGRID	106.0	ENICL	SPAR in service	
20	400 kV	400 kV BgTPP - Bongaigaon	1	D/C	NTPC	POWERGRID	3.1	POWERGRID	SPAR Available	Due to LDP, SPAR is not attempting
21	400 kV	400 kV BgTPP - Bongaigaon	2	D/C	NTPC	POWERGRID	3.1	POWERGRID	SPAR Available	Due to LDP, SPAR is not attempting
22	400 kV	400 kV Byrnihat - Silchar	1	D/C	MePTCL	POWERGRID	217.0	NETC(98.06%)& MePTCL(1.94%)	SPAR in service	
23	400 kV	400 kV Pallatana - Silchar	1	D/C	OTPC	POWERGRID	247.0	NETC	SPAR in service	
24	400 kV	400 kV Pallatana - Silchar	2	D/C	OTPC	POWERGRID	247.0	NETC	SPAR in service	
1	220 kV	220 kV AGBPP - Mariani	1	S/C	NEEPCO	AEGCL	162.9	POWERGRID	Information not available	AGBPP-SPAR enabled, Mariani end-POWERGRID may intimate
2	220 kV	220 kV AGBPP - Mariani(PG)	1	S/C	NEEPCO	POWERGRID	160.5	POWERGRID	SPAR in service	
3	220 kV	220 kV Mariani - Misa	1	S/C	AEGCL	POWERGRID	220.0	POWERGRID	Information not available	POWERGRID may intimate the status
4	220 kV	220 kV Mariani (PG) - Misa	1	S/C	POWERGRID	POWERGRID	222.7	POWERGRID	SPAR in service	
1	132 kV	132kV Imphal - Silchar	1	D/C	POWERGRID	POWERGRID	166.5	POWERGRID	SPAR in service	
2	132 kV	132kV Imphal - Silchar	2	D/C	POWERGRID	POWERGRID	166.5	POWERGRID	SPAR in service	
3	132 kV	132kV P K Bari - Silchar	1	D/C	TSECL	POWERGRID	127.2	POWERGRID	SPAR in service	
4	132 kV	132kV P K Bari - Silchar	2	D/C	TSECL	POWERGRID	127.2	POWERGRID	SPAR in service	
1	220 kV	220 kV AGBPP - Deomali	1	S/C	NEEPCO	DoP,Arunachal Pradesh	19.0	DoP, Arunachal Pradesh	Information not available	DoP AP may intimate the status
2	220 kV	220 kV AGBPP - Tinsukia	1	S/C	NEEPCO	AEGCL	24.6	AEGCL	SPAR not in service	SPAR available at both ends, but is not enabled at AGBPP as per Audit report

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
3	220 kV	220 kV AGBPP - Tinsukia	2	S/C	NEEPCO	AEGCL	24.6	AEGCL	SPAR not in service	SPAR available at both ends, but is not enabled at AGBPP as per Audit report
4	220 kV	220 kV Agia - Azara	1	D/C	AEGCL	AEGCL	107.0	AEGCL	Not Available	SPAR available at Azara, Agia end will be done in R&M works
5	220 kV	220 kV Agia - Boko	1	D/C	AEGCL	AEGCL	70.0	AEGCL	Not Available	SPAR will be done in R&M works
6	220 kV	220 kV Agia - BTPS	1	D/C	AEGCL	AEGCL	62.5	AEGCL	Not Available	SPAR will be done in R&M works
7	220 kV	220 kV Agia - BTPS	2	D/C	AEGCL	AEGCL	62.5	AEGCL	Not Available	SPAR will be done in R&M works
8	220 kV	220 kV Azara - Boko	1	D/C	AEGCL	AEGCL	38.0	AEGCL	Not Available	SPAR available at Azara, other end will be done in R&M works
9	220 kV	220 kV Azara - Sarusajai	1	D/C	AEGCL	AEGCL	24.0	AEGCL	Not Available	SPAR available at Azara, other end will be done in R&M works
10	220 kV	220 kV Azara - Sarusajai	2	D/C	AEGCL	AEGCL	24.0	AEGCL	Not Available	SPAR available at Azara, other end will be done in R&M works
11	220 kV	220 kV Balipara - Sonabil	1	S/C	POWERGRID	AEGCL	10.0	AEGCL	SPAR in service	AEGCL & POWERGRID may confirm
12	220 kV	220 kV Alipurduar - Salakati	1	D/C	POWERGRID	POWERGRID	100.6	POWERGRID	SPAR in service	
13	220 kV	220 kV Alipurduar - Salakati	2	D/C	POWERGRID	POWERGRID	100.6	POWERGRID	SPAR in service	
14	220 kV	220 kV BTPS - Salakati	1	D/C	AEGCL	POWERGRID	2.7	POWERGRID	SPAR in service	AEGCL & POWERGRID may confirm
15	220 kV	220 kV BTPS - Salakati	2	D/C	AEGCL	POWERGRID	2.7	POWERGRID	SPAR in service	AEGCL & POWERGRID may confirm
16	220 kV	220 kV Dimapur - Misa	1	D/C	POWERGRID	POWERGRID	123.5	POWERGRID	SPAR in service	
17	220 kV	220 kV Dimapur - Misa	2	D/C	POWERGRID	POWERGRID	123.5	POWERGRID	SPAR in service	
18	220 kV	220 kV Jawaharnagar - Samaguri	1	D/C	AEGCL	AEGCL	119.0	AEGCL	Not Available	SPAR available at Jawaharnagar, other end will be done in R&M works

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
19	220 kV	220 kV Jawaharnagar - Sarusajai	1	D/C	AEGCL	AEGCL	11.0	AEGCL	Not Available	SPAR available at JawaharNagar, other end will be done in R&M works
20	220 kV	220 kV Karbi Langpi - Sarusajai	1	S/C	APGCL	AEGCL	108.0	AEGCL	Not Available	SPAR will be done in R&M works
21	220 kV	220 kV Karbi Langpi - Sarusajai	2	S/C	APGCL	AEGCL	108.0	AEGCL	Not Available	SPAR will be done in R&M works
22	220 kV	220 kV Byrnihat - Misa	1	S/C	MePTCL	POWERGRID	113.4	MePTCL	SPAR in service	
23	220 kV	220 kV Byrnihat - Misa	2	S/C	MePTCL	POWERGRID	113.4	MePTCL	SPAR in service	
24	220 kV	220 kV Kopili - Misa	1	D/C	NEEPCO	POWERGRID	73.0	POWERGRID	SPAR in service	
25	220 kV	220 kV Kopili - Misa	2	D/C	NEEPCO	POWERGRID	73.0	POWERGRID	SPAR in service	
26	220 kV	220 kV Kopili - Misa	3	S/C	NEEPCO	POWERGRID	75.8	POWERGRID	SPAR in service	
27	220 kV	220 kV Mariani (AEGCL) - Samaguri	1	S/C	AEGCL	AEGCL	168.0	AEGCL	Not Available	will be done in PSDF scheme
28	220 kV	220 kV Mariani (PG) - Mokokchung (PG)	1	D/C	POWERGRID	POWERGRID	48.8	POWERGRID	SPAR in service	
29	220 kV	220 kV Mariani (PG) - Mokokchung (PG)	2	D/C	POWERGRID	POWERGRID	48.8	POWERGRID	SPAR in service	
30	220 kV	220 kV Misa - Samaguri	1	D/C	POWERGRID	AEGCL	34.4	POWERGRID	Information not available	POWERGRID may intimate the status
31	220 kV	220 kV Misa - Samaguri	2	D/C	POWERGRID	AEGCL	34.4	POWERGRID	Information not available	POWERGRID may intimate the status
32	220 kV	220 kV NTPS - Tinsukia	1	D/C	AEGCL	AEGCL	39.8	AEGCL	Not Available	will be done in PSDF scheme
33	220 kV	220 kV NTPS - Tinsukia	2	D/C	AEGCL	AEGCL	39.8	AEGCL	Not Available	will be done in PSDF scheme
34	220 kV	220 kV Samaguri - Sarusajai	1	D/C	AEGCL	AEGCL	130.0	AEGCL	Not Available	AEGCL may intimate the plan of action
35	220 kV	220 kV Samaguri - Sarusajai	2	D/C	AEGCL	AEGCL	130.0	AEGCL	Not Available	will be done in PSDF scheme
35	220 kV	220 kV Samaguri - Sonabil	1	S/C	AEGCL	AEGCL	56.0	AEGCL	Not Available	Due to problem at Samaguri end. Implemented in R&M scheme funded from PSDF
36	220 kV	220 kV Samaguri - Sonabil	2	S/C	AEGCL	AEGCL	56.0	AEGCL	Not Available	Due to problem at Samaguri end. Implemented in R&M scheme funded from PSDF

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
1	132 kV	132 kV Agartala - AGTCCPP	1	D/C	TSECL	NEEPCO	8.4	POWERGRID	Not Available	SPAR available at AGTCCPP, PLCC is not in service
2	132 kV	132 kV Agartala - AGTCCPP	2	D/C	TSECL	NEEPCO	8.4	POWERGRID	Not Available	SPAR available at AGTCCPP, PLCC is not in service
3	132 kV	132 kV Agartala - Bodhjannagar	1	S/C	TSECL	TSECL	8.0	TSECL	Not Available	TSECL may intimate the plan of action
4	132 kV	132 kV Agartala - Dhalabil	1	S/C	TSECL	TSECL	45.0	TSECL	Not Available	TSECL may intimate the plan of action
5	132 kV	132 kV Agartala - Rokhia	1	D/C	TSECL	TSECL	35.0	TSECL	Not Available	TSECL may intimate the plan of action
6	132 kV	132 kV Agartala - Rokhia	2	D/C	TSECL	TSECL	35.0	TSECL	Not Available	TSECL may intimate the plan of action
7	132 kV	132 kV Agia - Mendipathar	1	S/C	AEGCL	MePTCL	31.3	MePTCL	Not Available	Agia end: 3-ph AR will be will be implemented under R&M works, Mendipathar-MePTCL may intimate the status
8	132 kV	132 kV AGTCCPP - Kumarghat	1	S/C	NEEPCO	POWERGRID	7.8	POWERGRID	Not Available	AGTCCPP end: Single pole CB, E/M AR relay available; Kumarghat end: Gang operated CB
9	132 kV	132 kV Aizawl - Jiribam	1	S/C	POWERGRID	POWERGRID	172.3	POWERGRID	3-Ph AR in service	

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
10	132 kV	132 kV Aizawl - Kolasib	1	S/C	POWERGRID	P&ED, Mizoram	66.1	POWERGRID	3-Ph AR in service	POWERGRID may confirm
11	132 kV	132 kV Aizawl - Kumarghat	1	S/C	POWERGRID	POWERGRID	132.9	POWERGRID	3-Ph AR in service	
12	132 kV	132 kV Aizawl - Luangmual	1	S/C	POWERGRID	P&ED, P&ED, Mizoram	0.8	P&ED, Mizoram	Not Available	
13	132 kV	132 kV Aizawl - Melriat(PG)	1	S/C	POWERGRID	POWERGRID	6.7	POWERGRID	Not Available	
14	132 kV	132 kV Ambasa - Gamaitila	1	S/C	TSECL	TSECL	25.0	TSECL	Information not available	TSECL may intimate the status
15	132 kV	132 kV Ambasa - Kamalpur	1	S/C	TSECL	TSECL	31.0	TSECL	Information not available	TSECL may intimate the status
16	132 kV	132 kV Ambasa - P K Bari	1	S/C	TSECL	TSECL	45.0	TSECL	Information not available	TSECL may intimate the status
17	132 kV	132 kV Badarpur - Jiribam	1	S/C	POWERGRID	POWERGRID	67.2	POWERGRID	Information not available	POWERGRID may intimate the status
18	132 kV	132 kV Badarpur - Kolasib	1	S/C	POWERGRID	P&ED, Mizoram	107.2	POWERGRID	Information not available	POWERGRID may intimate the status
19	132 kV	132 kV Badarpur - Kumarghat	1	S/C	POWERGRID	POWERGRID	118.5	POWERGRID	3-Ph AR in service	
20	132 kV	132 kV Badarpur - Panchgram	1	S/C	POWERGRID	AEGCL	1.0	POWERGRID	Information not available	POWERGRID may intimate the status, Panchgram end: 3 ph AR will be implemented under R&M
21	132 kV	132 kV Badarpur - Silchar	1	D/C	POWERGRID	POWERGRID	19.2	POWERGRID	Information not available	Silchar end: AR in BCU available, AEGCL may intimate the status
22	132 kV	132 kV Badarpur - Silchar	2	D/C	POWERGRID	POWERGRID	19.2	POWERGRID	Information not available	Silchar end: 3-ph AR in BCU available, AEGCL may intimate the status
23	132 kV	132 kV Balipara - Bhalukpong	1	S/C	POWERGRID	DoP, Arunachal Pradesh		NEEPCO & DoP, Arunachal Pradesh	Not Available	
24	132 kV	132 kV Balipara - Depota	1	S/C	POWERGRID	AEGCL	29.8	AEGCL	Not Available	AEGCL&POWERGRID may intimate the plan of action
25	132 kV	132 kV Balipara - Sonabil	1	S/C	AEGCL	AEGCL	10.0	AEGCL	Information not available	Sonabil end: 3-ph AR available, Balipara end: POWERGRID may intimate

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
26	132 kV	132 kV Baramura - Gamaitilla	1	S/C	TSECL	TSECL	14.0	TSECL	Not Available	TSECL may intimate the status
27	132 kV	132 kV Baramura - Jirania	1	S/C	TSECL	TSECL	12.6	TSECL	Not Available	TSECL may intimate the status
28	132 kV	132 kV Bhalukpong - Khupi	1	S/C	DoP, Arunachal Pradesh	NEEPCO		NEEPCO & DoP, Arunachal Pradesh	Not Available	
29	132 kV	132 kV Biswanath Chariali - Pavoi	1	D/C	POWERGRID	AEGCL	12.9	POWERGRID	Not Available	Pavoi end- 3-ph AR will be implemented, BNC: POWERGRID may intimate the status
30	132 kV	132 kV Biswanath Chariali - Pavoi	2	D/C	POWERGRID	AEGCL	12.9	POWERGRID	Not Available	Pavoi end- 3-ph AR will be implemented, BNC: POWERGRID may intimate the status
31	132 kV	132 kV Pavoi - Sonabil	1	S/C	AEGCL	AEGCL	39.0	AEGCL	Not available	Sonabil end: 3-ph AR available, Pavoi end: 3-ph AR under R&M
32	132 kV	132 kV Bodhjannagar - Jirania	1	S/C	TSECL	TSECL	13.5	TSECL	Not Available	TSECL may intimate the status
33	132 kV	132 kV Bokajan - Dimapur	1	S/C	AEGCL	POWERGRID	26.4	AEGCL	Not available	
34	132 kV	132 kV Bokajan - Golaghat	1	S/C	AEGCL	AEGCL	15.0	AEGCL	Not available	AEGCL may intimate the plan of action
35	132 kV	132 kV BTPS - Dhaligaon	1	D/C	AEGCL	AEGCL	21.5	AEGCL	Not available	3-ph AR under R&M
36	132 kV	132 kV BTPS - Dhaligaon	2	D/C	AEGCL	AEGCL	21.5	AEGCL	Not available	3-ph AR under R&M
37	132 kV	132 kV BTPS-Kokrajhar	1	S/C	AEGCL	AEGCL	10.3	AEGCL	Not available	AEGCL may intimate the plan of action
38	132 kV	132 kV Bilashipara-Kokrajhar	1	S/C	AEGCL	AEGCL	24.2	AEGCL	Not available	AEGCL may intimate the plan of action
39	132 kV	132 kV Bilashipara-Gauripur	1	S/C	AEGCL	AEGCL	37.6	AEGCL	Not available	AEGCL may intimate the plan of action
40	132 kV	132 kV Bornagar - Dhaligaon	1	S/C	AEGCL	AEGCL	41.3	AEGCL	Not available	AEGCL may intimate the plan of action
41	132 kV	132 kV Bornagar - Rangia	1	S/C	AEGCL	AEGCL	85.7	AEGCL	Not available	AEGCL may intimate the plan of action

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
42	132 kV	132 kV Budhjangnagar - Surjamaninagar	1	D/C	TSECL	TSECL	18.3	TSECL	Not available	
43	132 kV	132 kV Budhjangnagar - Surjamaninagar	2	D/C	TSECL	TSECL	18.3	TSECL	Not available	
44	132 kV	132 kV Dhalabil - Kamalpur	1	S/C	TSECL	TSECL	32.0	TSECL	Not available	
45	132 kV	132 kV Dhaligaon-Gossaigaon	1	S/C	AEGCL	AEGCL	64.0	AEGCL	Not available	AEGCL may intimate the plan of action
46	132 kV	132 kV Dharmanagar - Dullavcherri	1	S/C	TSECL	AEGCL	29.0	AEGCL	Not available	AEGCL&TSECL may intimate the plan of action
47	132 kV	132 kV Dullavcherri - Hailakandi	1	S/C	AEGCL	AEGCL	33.8	AEGCL	Not available	AEGCL may intimate the plan of action
48	132 kV	132 kV Dharmanagar - P K Bari	1	S/C	TSECL	TSECL	36.5	TSECL	Not available	
49	132 kV	132 kV Dimapur - Doyang	1	D/C	POWERGRID	NEEPCO	92.5	POWERGRID	SPAR in service	
50	132 kV	132 kV Dimapur - Doyang	2	D/C	POWERGRID	NEEPCO	92.5	POWERGRID	SPAR in service	
51	132 kV	132 kV Dimapur - Imphal	1	S/C	POWERGRID	POWERGRID	168.9	POWERGRID	SPAR in service	
52	132 kV	132 kV Dimapur (PG) - Dimapur (DoP, Nagaland)	1	S/C	POWERGRID	ED, DoP, Nagaland	0.5	DoP, Nagaland	Not Available	DoP Nagaland may please intimate the plan of action
53	132 kV	132 kV Dimapur (PG) - Dimapur (DoP, Nagaland)	2	S/C	POWERGRID	ED, DoP, Nagaland	0.5	DoP, Nagaland	Not Available	DoP Nagaland may please intimate the plan of action
54	132 kV	132 kV Dimapur (PG) - Kohima	1	S/C	POWERGRID	ED, DoP, Nagaland	45.0	DoP, Nagaland	Not Available	DoP Nagaland may please intimate the plan of action
55	132 kV	132 kV Doyang - Mokochung (DoP, Nagaland)	1	S/C	NEEPCO	ED, DoP, Nagaland	30.1	DoP, Nagaland	Not Available	DoP Nagaland may please intimate the plan of action
56	132 kV	132 kV Doyang - Sanis	1	S/C	NEEPCO	DoP, Nagaland	6.4	DoP, Nagaland	Not Available	NEEPCO & DoP Nagaland may please intimate the plan of action
57	132 kV	132 kV EPIP II - Byrnihat	1	D/C	MePTCL	MePTCL	10.3	MePTCL	Not Available	
58	132 kV	132 kV EPIP II - Byrnihat	2	D/C	MePTCL	MePTCL	10.3	MePTCL	Not Available	
59	132 kV	132 kV EPIP II - Umtru	1	D/C	MePTCL	MePTCL	0.7	MePTCL	Not Available	
60	132 kV	132 kV EPIP II - Umtru	2	D/C	MePTCL	MePTCL	0.7	MePTCL	Not Available	

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

Sl No	Voltage Level	Name of Element (Emanating - Terminating)	Ckt ID	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
61	132 kV	132 kV Gauripur-Gossaigaon	1	S/C	AEGCL	AEGCL	63.0	AEGCL	Not available	AEGCL may intimate the plan of action
62	132 kV	132 kV Gohpur - Pavoi	1	S/C	AEGCL	AEGCL	51.0	AEGCL	Not available	AEGCL may intimate the plan of action
63	132 kV	132 kV Gohpur - Nirjuli	1	S/C	AEGCL	POWERGRID	42.5	POWERGRID	Not available	AEGCL may intimate the plan of action
64	132 kV	132 kV Golaghat - Mariani (AEGCL)	1	S/C	AEGCL	AEGCL	45.0	AEGCL	Not available	AEGCL may intimate the plan of action
65	132 kV	132 kV Haflong - Jiribam	1	S/C	POWERGRID	POWERGRID	100.6	POWERGRID	Not available	AEGCL may intimate the plan of action
66	132 kV	132 kV Haflong - Umranshu	1	S/C	AEGCL	POWERGRID	8.2	AEGCL	Not available	AEGCL may intimate the plan of action
67	132 kV	132 kV Imphal (MSPCL) - Imphal (PG)	1	S/C	MSPCL	POWERGRID	1.5	POWERGRID	Not available	AEGCL may intimate the plan of action
68	132 kV	132 kV Imphal (MSPCL) - Imphal (PG)	2	S/C	MSPCL	POWERGRID	2.3	POWERGRID & MSPCL	Not available	AEGCL may intimate the plan of action
69	132 kV	132 kV Imphal (MSPCL) - Karong	1	S/C	MSPCL	MSPCL	60.0	MSPCL	Not Available	AEGCL may intimate the plan of action
70	132 kV	132 kV Imphal (PG) - Ningthoukong	1	S/C	POWERGRID	MSPCL	27.5	MSPCL	Not Available	AEGCL may intimate the plan of action
71	132 kV	132 kV Imphal (PG) - Loktak	1	S/C	POWERGRID	NHPC	35.0	POWERGRID	SPAR in service	
72	132 kV	132 kV Jiribam - Loktak	2	S/C	POWERGRID	NHPC	82.4	POWERGRID	SPAR in service	
73	132 kV	132 kV Jiribam - Pailapool	1	S/C	POWERGRID	AEGCL	15.0	AEGCL/ MSPCL	Not Available	POWERGRID & AEGCL may intimate the plan of action
74	132 kV	132 kV Jiribam(PG) - Jiribam(MA)	1	S/C	POWERGRID	MSPCL	1.0	MSPCL	Not available	AEGCL may intimate the plan of action
75	132 kV	132 kV Jorhat - Mariani	1	S/C	AEGCL	AEGCL	19.5	AEGCL	Not Available	AEGCL may intimate the plan of action
76	132 kV	132 kV Jorhat - Mariani	2	S/C	AEGCL	AEGCL	19.5	AEGCL	Not Available	AEGCL may intimate the plan of action
77	132 kV	132 kV Jorhat - Nazira	1	S/C	AEGCL	AEGCL	69.0	AEGCL	Not Available	AEGCL may intimate the plan of action
78	132 kV	132 kV Kahilipara - Kamalpur	1	S/C	AEGCL	AEGCL	57.0	AEGCL	Not Available	AEGCL may intimate the plan of action
79	132 kV	132 kV Kamalpur - Rangia	1	D/C	AEGCL	AEGCL		AEGCL	Not Available	AEGCL may intimate the plan of action
80	132 kV	132 kV Kamalpur - Rangia	2	D/C	AEGCL	AEGCL		AEGCL	Not Available	AEGCL may intimate the plan of action
81	132 kV	132 kV Kahilipara - Sarusajai	1	D/C	AEGCL	AEGCL	3.5	AEGCL	Not Available	AEGCL may intimate the plan of action
82	132 kV	132 kV Kahilipara - Sarusajai	2	D/C	AEGCL	AEGCL	3.5	AEGCL	Not Available	AEGCL may intimate the plan of action

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
83	132 kV	132 kV Kahilipara - Sarusajai	3	D/C	AEGCL	AEGCL	3.9	AEGCL	Not Available	AEGCL may intimate the plan of action
84	132 kV	132 kV Sarusajai - Sishugram	1	D/C	AEGCL	AEGCL	3.9	AEGCL	Not Available	AEGCL may intimate the plan of action
85	132 kV	132 kV Kamalpur - Sishugram	1	S/C	AEGCL	AEGCL		AEGCL	Not Available	AEGCL may intimate the plan of action
86	132 kV	132 kV Kahilipara - Umtru	1	D/C	AEGCL	MePTCL	11.0	MePTCL	Not Available	
87	132 kV	132 kV Kahilipara - Umtru	2	D/C	AEGCL	MePTCL	11.0	MePTCL	Not Available	
88	132 kV	132 kV Kamalpur - P K Bari	1	S/C	TSECL	TSECL	31.0	TSECL	Not Available	
89	132 kV	132 kV Karong - Kohima	1	S/C	DoP, Nagaland	MSPCL	50.0	MSPCL(65.3%) / DoP, Nagaland(34.7%)	Not Available	
90	132 kV	132 kV Khandong - Khliehriat	1	S/C	NEEPCO	POWERGRID	42.5	POWERGRID	SPAR in service	
91	132 kV	132 kV Khandong - Khliehriat	2	S/C	NEEPCO	POWERGRID	40.9	POWERGRID	Information not available	POWERGRID may intimate the status
92	132 kV	132 kV Khandong - Kopili	1	S/C	NEEPCO	NEEPCO	10.9	POWERGRID	SPAR in service	
93	132 kV	132 kV Khandong - Kopili	2	S/C	NEEPCO	NEEPCO	11.6	POWERGRID	Not Available	Gang operated CB at Kopili end (Owner:POWERGRID)
94	132 kV	132 kV Khandong - Umranshu	1	S/C	NEEPCO	AEGCL	11.4	POWERGRID & AEGCL	Not Available	Due to problem at Umrangshu end, Single pole CB, AR relay available at Khandong end
95	132 kV	132 kV Khliehriat - Badarpur	1	S/C	POWERGRID	POWERGRID	76.7	POWERGRID	3-Ph AR in service	
96	132 kV	132 kV Khliehriat - Mustem	1	S/C	MePTCL	MePTCL	15.7	MePTCL	Not available	
97	132 kV	132 kV Mustem - NEHU line	1	S/C	MePTCL	MePTCL	41.9	MePTCL	Not available	
98	132 kV	132 kV Khliehriat (MePTCL) - Khliehriat (PG)	1	S/C	MePTCL	POWERGRID	7.8	POWERGRID	Not available	
99	132 kV	132 kV Khliehriat (MePTCL) - Khliehriat (PG)	2	S/C	MePTCL	POWERGRID	5.4	MePTCL	Not available	
100	132 kV	132 kV Khliehriat- NEIGRIHMS	1	S/C	MePTCL	POWERGRID	62.8	MePTCL	Not available	

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
101	132 kV	132 kV Kumarghat - P K Bari	1	S/C	POWERGRID	TSECL	1.0	TSECL	Not Available	Scheme not available at PK Bari end; PLCC not available
102	132 kV	132 kV Lekhi - Nirjuli	1	S/C	DoP, Arunachal Pradesh	POWERGRID	9.5	DoP, Arunachal Pradesh & POWERGRID	Information not available	DoP, Arunachal Pradesh & POWERGRID may please intimate the status
103	132 kV	132 kV Lekhi - Ranganadi	1	S/C	DoP, Arunachal Pradesh	NEEPCO	24.0	DoP, Arunachal Pradesh & POWERGRID	SPAR in service	
104	132 kV	132 kV Loktak - Ningthoukhong	1	S/C	NHPC	MSPCL	10.5	MSPCL	Not Available	
105	132 kV	132 kV Loktak - Rengpang	1	S/C	NHPC	MSPCL	35.0	MSPCL	Not Available	
106	132 kV	132 kV LTPS - Mariani	1	S/C	AEGCL	AEGCL	80.0	AEGCL	Not Available	AEGCL may intimate the plan of action
107	132 kV	132 kV LTPS - Moran	1	S/C	AEGCL	AEGCL	39.0	AEGCL	Not Available	AEGCL may intimate the plan of action
108	132 kV	132 kV LTPS - Nazira	1	D/C	AEGCL	AEGCL	22.0	AEGCL	Not Available	AEGCL may intimate the plan of action
109	132 kV	132 kV LTPS - Nazira	2	D/C	AEGCL	AEGCL	22.0	AEGCL	Not Available	AEGCL may intimate the plan of action
110	132 kV	132 kV LTPS - NTPS	1	D/C	AEGCL	AEGCL	60.0	AEGCL	Not Available	AEGCL may intimate the plan of action
111	132 kV	132 kV LTPS - Sonari	1	D/C	AEGCL	AEGCL	30.0	AEGCL	Not Available	AEGCL may intimate the plan of action
112	132 kV	132 kV Mariani (AEGCL) - Mokokchung (DoP, Nagaland)	1	S/C	AEGCL	ED, DoP, Nagaland	50.0	AEGCL(40%)/ DoP, Nagaland(60%)	Not Available	
113	132 kV	132 kV NEHU - Mawlai	1	S/C	MePTCL	MePTCL	7.9	MePTCL	Not available	MePTCL may intimate the plan of action
114	132 kV	132 kV Mawlai - Umiam Stage I	2	S/C	MePTCL	MePTCL	12.1	MePTCL	Not available	MePTCL may intimate the plan of action
115	132 kV	132 kV Mawphlang - Nongstoin	1	S/C	MePTCL	MePTCL	56.3	MePTCL	Not available	MePTCL may intimate the plan of action
116	132 kV	132 kV Mawphlang - Umiam Stg I	1	D/C	MePTCL	MePTCL	33.1	MePTCL	Not available	MePTCL may intimate the plan of action
117	132 kV	132 kV Mawphlang - Umiam Stg I	2	D/C	MePTCL	MePTCL	33.1	MePTCL	Not available	MePTCL may intimate the plan of action
118	132 kV	132 kV Mawphlang- Mawlai	1	S/C	MePTCL	MePTCL	20.9	MePTCL	Not available	MePTCL may intimate the plan of action

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	<i>Tower Configuration (S/C or D/C)</i>	<i>Agency at End 1</i>	<i>Agency at End 2</i>	<i>Line Length in km</i>	<i>Owner</i>	<i>AR Details (SPAR/3-Ph AR/Not Available/Information not Available)</i>	<i>Remarks</i>
119	132 kV	132 kV Melriat(PG) - Zuangtui	1	S/C	POWERGRID	P&ED, Mizoram	10.2	POWERGRID	Not Available	POWERGRID may intimate the status
120	132 kV	132 kV Mendipathar - Nangalbibra	1	S/C	MePTCL	MePTCL	65.2	MePTCL	Not available	
121	132 kV	132 kV Mokochung (PG) - Mokochung (DoP, Nagaland)	1	D/C	POWERGRID	DoP,Nagaland	1.4	POWERGRID	Information not available	
122	132 kV	132 kV Mokochung (PG) - Mokochung (DoP, Nagaland)	2	D/C	POWERGRID	DoP,Nagaland	1.4	POWERGRID	Information not available	
123	132 kV	132 kV Monarchak - Rokhia	1	S/C	NEEPCO	TSECL	29.0	TSECL	Not Available	TSECL may intimate the plan of action
124	132 kV	132 kV Monarchak - Udaipur	1	S/C	NEEPCO	TSECL	41.5	TSECL	Not Available	TSECL may intimate the plan of action
125	132 kV	132 kV Myntdu Leshka - Khleihriat	1	D/C	MePTCL	MePTCL	26.5	MePTCL	Not available	MePTCL may intimate the plan of action
126	132 kV	132 kV Myntdu Leshka - Khleihriat	2	D/C	MePTCL	MePTCL	26.5	MePTCL	Not available	MePTCL may intimate the plan of action
127	132 kV	132 kV Nangalbibra - Nongstoin	1	S/C	MePTCL	MePTCL	57.1	MePTCL	Not available	MePTCL may intimate the plan of action
128	132 kV	132 kV NEHU - NEIGRIHMS	1	S/C	MePTCL	MePTCL	6.7	MePTCL	Not available	MePTCL may intimate the plan of action
129	132 kV	132 kV NEHU - Umiam	1	D/C	MePTCL	MePTCL	6.2	MePTCL	Not available	MePTCL may intimate the plan of action
130	132 kV	132 kV NTPS - Tinsukia	1	S/C	AEGCL	AEGCL	43.0	AEGCL	Not Available	AEGCL may intimate the plan of action
131	132 kV	132 kV NTPS - Sonari	1	D/C	AEGCL	AEGCL	30.0	AEGCL	Not Available	AEGCL may intimate the plan of action
132	132 kV	132 kV Pailapool - Srikona	1	D/C	AEGCL	AEGCL	34.5	AEGCL	Not Available	AEGCL may intimate the plan of action
133	132 kV	132 kV Palatana - Surjamaninagar	1	D/C	OTPC	TSECL	37.2	POWERGRID	Not Available	Gang operated CB at Palatana end
134	132 kV	132 kV Palatana - Udaipur	1	S/C	TSECL	TSECL	11.1	TSECL	Not Available	Gang operated CB at Palatana end
135	132 kV	132 kV Hailakandi - Silchar	1	S/C	AEGCL	POWERGRID	30.3	POWERGRID	Information not available	Silchar end: AR in BCU available, AEGCL may intimate the status
136	132 kV	132 kV Panchgram - Srikona	1	S/C	AEGCL	AEGCL	19.1	AEGCL	Not Available	Will be implemented under R&M works funded from PSDF
137	132 kV	132 kV Ranganadi - Ziro	1	S/C	NEEPCO	POWERGRID	44.5	POWERGRID	SPAR in service	
138	132 kV	132 kV Roing - Pasighat	1	S/C	POWERGRID	POWERGRID		POWERGRID	Information not available	POWERGRID may intimate the status
139	132 kV	132 kV Roing - Tezu	1	S/C	POWERGRID	POWERGRID		POWERGRID	Information not available	POWERGRID may intimate the status

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
140	132 kV	132 kV Sarusajai - Umtru	1	D/C	AEGCL	MePTCL	37.0	MePTCL	Not Available	Not available at both ends

Details of Auto Recloser of Lines in North Eastern Regional Grid

ANNEXURE-A.3

<i>Sl No</i>	<i>Voltage Level</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Owner	AR Details (SPAR/3-Ph AR/Not Available/Information not Available)	Remarks
141	132 kV	132 kV Sarusajai - Umtru	2	D/C	AEGCL	MePTCL	37.0	MePTCL	Not Available	Not available at both ends
142	132 kV	132 kV Silchar - Srikona	1	D/C	POWERGRID	AEGCL	1.2	POWERGRID	Information not available	Silchar end: AR in BCU available, AEGCL may intimate the status
143	132 kV	132 kV Silchar - Srikona	2	D/C	POWERGRID	AEGCL	1.2	POWERGRID	Information not available	Silchar end: AR in BCU available, AEGCL may intimate the status
144	132 kV	132 kV Umiam - Umiam St I	1	S/C	MePTCL	MePTCL	5.1	MePTCL	Not Available	MePTCL may intimate the plan of action
145	132 kV	132 kV Umiam St I - Umiam St II	1	S/C	MePTCL	MePTCL	3.0	MePTCL	Not Available	MePTCL may intimate the plan of action
146	132 kV	132 kV Umiam St I - Umiam St III	1	D/C	MePTCL	MePTCL	17.5	MePTCL	Not Available	MePTCL may intimate the plan of action
147	132 kV	132 kV Umiam St I - Umiam St III	2	D/C	MePTCL	MePTCL	17.5	MePTCL	Not Available	MePTCL may intimate the plan of action
148	132 kV	132 kV Umiam St III - Umiam St IV	1	D/C	MePTCL	MePTCL	8.0	MePTCL	Not Available	MePTCL may intimate the plan of action
149	132 kV	132 kV Umiam St III – Umiam St IV	2	D/C	MePTCL	MePTCL	9.7	MePTCL	Not Available	MePTCL may intimate the plan of action
150	132 kV	132 kV Umiam St III - Umtru	1	D/C	MePTCL	MePTCL	41.1	MePTCL	Not Available	MePTCL may intimate the plan of action
151	132 kV	132 kV Umiam St III - Umtru	2	D/C	MePTCL	MePTCL	41.1	MePTCL	Not Available	MePTCL may intimate the plan of action
152	132 kV	132 kV Umtru - Umiam St IV	1	D/C	MePTCL	MePTCL	29.9	MePTCL	Not Available	MePTCL may intimate the plan of action
153	132 kV	132 kV Umtru - Umiam St IV	2	D/C	MePTCL	MePTCL	29.9	MePTCL	Not Available	MePTCL may intimate the plan of action

List of Lines in North Eastern Regional Grid

ANNEXURE-A.5

<i>Sl No</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Type of Conductor	Owner
C. 400 kV Lines								
1	BgTPP - Bongaigaon	1	D/C	NTPC	POWERGRID	3.1	ACSR Twin Moose	POWERGRID
2	BgTPP - Bongaigaon	2	D/C	NTPC	POWERGRID	3.1	ACSR Twin Moose	POWERGRID
F. 220 kV Lines								
1	Balipara - Sonabil	1	S/C	POWERGRID	AEGCL	10.0	ACSR Zebra	AEGCL
2	BTPS - Salakati	1	D/C	AEGCL	POWERGRID	2.7	ACSR Zebra	POWERGRID
3	BTPS - Salakati	2	D/C	AEGCL	POWERGRID	2.7	ACSR Zebra	POWERGRID
G. 132 kV Lines								
1	Agartala - AGTCCPP	1	D/C	TSECL	NEEPCO	8.4	AAAC Panther	POWERGRID
2	Agartala - AGTCCPP	2	D/C	TSECL	NEEPCO	8.4	AAAC Panther	POWERGRID
3	Agartala - Bodhjannagar	1	S/C	TSECL	TSECL	8.0	AAAC Panther	TSECL

List of Lines in North Eastern Regional Grid

ANNEXURE-A.5

<i>Sl No</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Type of Conductor	Owner
4	AGTCCPP - Kumarghat	1	S/C	NEEPCO	POWERGRID	7.8	ACSR Panther	POWERGRID
5	Aizawl - Luangmual	1	S/C	POWERGRID	P&ED, P&ED, Mizoram	0.8	ACSR Panther	P&ED, Mizoram
6	Aizawl - Melriat(PG)	1	S/C	POWERGRID	POWERGRID	6.7	ACSR Panther	POWERGRID
7	Badarpur - Panchgram	1	S/C	POWERGRID	AEGCL	1.0	AAAC Panther	POWERGRID
8	Balipara - Sonabil	1	S/C	AEGCL	AEGCL	10.0	AAAC Panther	AEGCL
9	EPIP II - Umtru	1	D/C	MePTCL	MePTCL	0.7	ACSR Panther	MePTCL
10	EPIP II - Umtru	2	D/C	MePTCL	MePTCL	0.7	ACSR Panther	MePTCL
11	Haflong - Umranshu	1	S/C	AEGCL	POWERGRID	8.2	ACSR Panther	AEGCL
12	Imphal (MSPCL) - Imphal (PG)	1	S/C	MSPCL	POWERGRID	1.5	ACSR Panther	POWERGRID
13	Imphal (MSPCL) - Imphal (PG)	2	S/C	MSPCL	POWERGRID	2.3	ACSR Panther	POWERGRID & MSPCL
14	Kahilipara - Sarusajai	1	D/C	AEGCL	AEGCL	3.5	ACSR Panther	AEGCL
15	Kahilipara - Sarusajai	2	D/C	AEGCL	AEGCL	3.5	ACSR Panther	AEGCL
16	Kahilipara - Sarusajai	3	D/C	AEGCL	AEGCL	3.9	ACSR Panther	AEGCL

List of Lines in North Eastern Regional Grid

ANNEXURE-A.5

<i>Sl No</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Type of Conductor	Owner
17	Sarusajai - Sishugram	1	D/C	AEGCL	AEGCL	3.9	ACSR Panther	AEGCL
18	Khliehriat (MePTCL) - Khliehriat (PG)	1	S/C	MePTCL	POWERGRID	7.8	ACSR Panther	POWERGRID
19	Khliehriat (MePTCL) - Khliehriat (PG)	2	S/C	MePTCL	POWERGRID	5.4	ACSR Panther	MePTCL
20	Kumarghat - P K Bari	1	S/C	POWERGRID	TSECL	1.0	ACSR Panther	TSECL
21	Lekhi - Nirjuli	1	S/C	DoP, Arunachal Pradesh	POWERGRID	9.5	ACSR Panther	DoP, Arunachal Pradesh & POWERGRID
22	NEHU - Mawlai	1	S/C	MePTCL	MePTCL	7.9	ACSR Panther	MePTCL
23	Mokochung (PG) - Mokochung (DoP, Nagaland)	1	D/C	POWERGRID	DoP, Nagaland	1.4	ACSR Zebra	POWERGRID
24	Mokochung (PG) - Mokochung (DoP, Nagaland)	2	D/C	POWERGRID	DoP, Nagaland	1.4	ACSR Zebra	POWERGRID
25	NEHU - NEIGRIHMS	1	S/C	MePTCL	MePTCL	6.7	ACSR Panther	MePTCL
26	NEHU - Umiam	1	D/C	MePTCL	MePTCL	6.2	ACSR Panther	MePTCL
27	Ranganadi - Pare	1	S/C	NEEPCO	NEEPCO	9.0	ACSR Panther	POWERGRID

List of Lines in North Eastern Regional Grid

ANNEXURE-A.5

<i>Sl No</i>	<i>Name of Element (Emanating - Terminating)</i>	<i>Ckt ID</i>	Tower Configuration (S/C or D/C)	Agency at End 1	Agency at End 2	Line Length in km	Type of Conductor	Owner
28	Silchar - Srikona	1	D/C	POWERGRID	AEGCL	1.2	ACSR Panther	POWERGRID
29	Silchar - Srikona	2	D/C	POWERGRID	AEGCL	1.2	ACSR Panther	POWERGRID
30	Umiam - Umiam St I	1	S/C	MePTCL	MePTCL	5.1	ACSR Panther	MePTCL
31	Umiam St III - Umiam St IV	1	D/C	MePTCL	MePTCL	8.0	ACSR Panther	MePTCL
32	Umiam St III – Umiam St IV	2	D/C	MePTCL	MePTCL	9.7	ACSR Panther	MePTCL

ANNEXURE-B.7

Pending DR and EL output for the period w.e.f 1st May'18 to 31st Jul'18

Sl. No	Name of the Utility	No. of DR and EL output which are not furnished		
		May'18	Jun'18	Jul'18
1	POWERGRID	40	45	40
2	DoP, Arunchal Pradesh	2	0	6
3	Assam	16	18	12
4	MSPCL	1	9	4
5	MePTCL	5	1	2
6	P&ED, Mizoram	1	1	1
7	DoP, Nagaland	5	3	8
8	TSECL	26	0	5
9	Palatana, OTPC	1	0	0
10	BgTPP	0	0	1
11	NEEPCO	20	4	18
12	NHPC	0	0	0
	Total Pending DR	117	81	97
	Total no of element tripping	143	111	101

Pending DR and EL output for the month of May'18

Event ID	Name of tripping element (End A - End B)	मालिक / Owner of the element	Date & Time of Event	Date & Time of Restoration	Relay indications		DR to be furnished by
					End A	End B	
1	132 kV Jiribam (PG) - Jiribam (MA) 1 Line	MSPCL	01-05-2018 05:40:00	01-05-2018 10:52:00	Tripped	No tripping	Jiribam(PG),
2	220 kV Killing (Byrnihat) - Misa 2 Line	MePTCL	01-05-2018 14:20:00	01-05-2018 14:37:00	DP, ZI, B-E	DP, ZI, B-E	Byrnihat, Misa
3	400 kV Azara - Silchar 1 Line	NETC & AEGCL	02-05-2018 01:25:00	02-05-2018 01:50:00	DP, ZI, Y-E	DP, ZI, Y-E	Azara
4	132 kV Mokokchung (PG) - Mokokchung (DoP, Nagaland) 1 Line	POWERGRID	02-05-2018 13:41:00	02-05-2018 13:57:00	Earth Fault	No tripping	Mokokchung (PG),
5	132 kV Mokokchung (PG) - Mokokchung (DoP, Nagaland) 2 Line	POWERGRID	02-05-2018 13:41:00	02-05-2018 13:54:00	Earth Fault	No tripping	Mokokchung (PG),
6	132 kV Dimapur (PG) - Kohima (DoP, Nagaland) 1 Line	POWERGRID & DoP, Nagaland	02-05-2018 14:24:00	02-05-2018 18:43:00	Earth Fault	No tripping	Dimapur(PG),
7	132 kV Bokajan - Dimapur(PG) 1 Line	AEGCL	02-05-2018 14:34:00	03-05-2018 14:25:00	No tripping	DP, ZII, B-E	Dimapur
8	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	POWERGRID	04-05-2018 13:09:00	04-05-2018 13:35:00	No tripping	Earth Fault	Mokokchung (DoP, Nagaland)
9	132 kV Badarpur - Jiribam 1 Line	POWERGRID	05-05-2018 21:45:00	06-05-2018 21:56:00	DP, ZI, B-E	DP, ZI, B-E	Jiribam
10	132 kV Mokochung (PG) - Mokokchung (DoP, Nagaland) 1 Line	POWERGRID	06-05-2018 10:07:00	06-05-2018 10:43:00	Earth Fault	No tripping	Mokokchung(PG)
11	132 kV Mokochung (PG) - Mokokchung (DoP, Nagaland) 2 Line	POWERGRID	06-05-2018 10:07:00	06-05-2018 10:44:00	Earth Fault	No tripping	Mokokchung(PG)
12	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	06-05-2018 10:06:00	06-05-2018 10:50:00	DP, ZI, R-E	No tripping	Doyang
13	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	06-05-2018 12:13:00	06-05-2018 19:55:00	DP, ZI, R-E	No tripping	Doyang
14	132 kV Mokokchung (PG) - Mokokchung (DoP, Nagaland) 1 Line	POWERGRID	06-05-2018 12:13:00	06-05-2018 12:30:00	Earth Fault	No tripping	Mokokchung(PG)
15	132 kV Mokokchung (PG) - Mokokchung (DoP, Nagaland) 2 Line	POWERGRID	06-05-2018 12:13:00	06-05-2018 12:31:00	Earth Fault	No tripping	Mokokchung(PG)
16	420 kV Silchar - Azara Line Reactor 1	POWERGRID	06-05-2018 13:11:00	06-05-2018 16:24:00	Bucholz relay optd		Silchar
17	420 kV Silchar - Azara Line Reactor 1	POWERGRID	06-05-2018 16:42:00	06-05-2018 16:52:00	Bucholz relay optd		Silchar
18	220 kV Misa - Byrnihat 1 Line	MePTCL	07-05-2018 17:44:00	07-05-2018 17:53:00	Earth Fault	No tripping	Misa
19	220 kV Killing (Byrnihat) - Misa 1 Line	MePTCL	07-05-2018 17:55:00	07-05-2018 18:06:00	No tripping	Earth Fault	Misa
20	132 kV Kumarghat - P K Bari 1 Line	TSECL	08-05-2018 04:30:00	08-05-2018 05:08:00	DP, ZIII, Y-B-E	No tripping	Kumarghat
21	132 kV Dharmanagar - P K Bari 1 Line	TSECL	08-05-2018 04:30:00	10-05-2018 18:54:00	No tripping	Over current	PK Bari
22	132 kV Dharmanagar - Dullavcherra 1 Line	AEGCL & TSECL	08-05-2018 04:30:00	08-05-2018 05:38:00	No tripping	Tripped	Dullavcherra
23	400 kV Azara - Bongaigaon 1 Line	NETC & AEGCL	08-05-2018 17:39:00	08-05-2018 17:56:00	DP, ZI, R-E	DP, ZI, R-E	Azara,
24	400 kV Balipara - Bongaigaon 4 Line	POWERGRID	09-05-2018 03:21:00	09-05-2018 03:51:00	DP, ZII, Y-E	DP, ZI, Y-E	Balipara(wrong DR submitted)
25	220 kV Killing (Byrnihat) - Misa 1 Line	MePTCL	09-05-2018 03:53:00	09-05-2018 04:16:00	Earth Fault	No tripping	Byrnihat

POWERGRID	
DoP, Arunchal Pradesh	
AEGCL	
MSPCL	
MePTCL	
P&ED, Mizoram	
DoP, Nagaland	
TSECL	
BgTPP	
NEEPCO	
Palatana	

Pending DR and EL output for the month of May'18

Event ID	Name of tripping element (End A - End B)	मालिक / Owner of the element	Date & Time of Event	Date & Time of Restoration	Relay indications		DR to be furnished by
					End A	End B	
26	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	MePTCL	09-05-2018 05:33:00	09-05-2018 05:44:00	Not Furnished	DP, ZI, B-E	Khliehriat(PG)
27	400 kV Bongaigaon - Killing (Byrnihat) 1 Line	NETC & MePTCL	09-05-2018 05:06:00	09-05-2018 05:34:00	DP, ZII, R-B-E	DP, ZI, B-E	Byrnihat
28	132 kV Dimapur (PG) - Dimapur (Nagaland) 1 Line	DoP,Nagaland	09-05-2018 12:36:00	09-05-2018 12:53:00	Earth Fault	No tripping	Dimapur(PG)
29	132 kV Dimapur (PG) - Dimapur (Nagaland) 2 Line	DoP,Nagaland	09-05-2018 12:36:00	09-05-2018 15:11:00	Earth Fault	No tripping	Dimapur(PG)
30	132 kV Dharmanagar - Dullavcherra 1 Line	AEGCL & TSECL	09-05-2018 13:15:00	09-05-2018 13:42:00	Tripped	Earth Fault	Dharmanagar, Dullavcherra
31	132 kV Mokochung (PG) - Mokochung (Nagaland) 1 Line	POWERGRID	09-05-2018 13:21:00	09-05-2018 13:26:00	Earth Fault	Earth Fault	Mokokchung(PG), Mokochung(DoP, Nagaland)
32	132 kV Mokochung (PG) - Mokochung (Nagaland) 2 Line	POWERGRID	09-05-2018 13:21:00	09-05-2018 13:28:00	Earth Fault	No tripping	Mokokchung(PG)
33	132 kV Doyang - Mokochung (Nagaland) 1 Line	Nagaland	09-05-2018 13:28:00	09-05-2018 13:50:00	Tripped	DP	Doyang, Mokochung(DoP, Nagaland)
34	132 kV Loktak - Ningthoukhong 1 Line	MSPCL	09-05-2018 13:28:00	09-05-2018 17:27:00	No tripping	Earth Fault	Ningthoukhong
35	400 kV Palatana - Silchar 1 Line	NETCL	09-05-2018 13:45:00	09-05-2018 13:59:00	DP, ZI, B-E	DP, ZI, B-E	Palatana
36	132 kV Jiribam - Pailapool 1 Line	AEGCL & MSPCL	09-05-2018 13:46:00	09-05-2018 14:40:00	DP, ZI, B-E	No tripping	Jiribam
37	132 kV Dimapur (PG) - Dimapur (Nagaland) 1 Line	DoP, Nagaland	09-05-2018 13:30:00	09-05-2018 14:42:00	Earth Fault	No tripping	Dimapur(PG)
38	132 kV Kamalpur - P K Bari 1 Line	TSECL	09-05-2018 14:33:00	09-05-2018 14:35:00	Earth Fault	No tripping	Kamalpur
39	132 kV Agartala - Dhalabil Line	TSECL	09-05-2018 14:33:00	10-05-2018 00:39:00	Earth Fault	No tripping	Agartala
40	132 kV Dimapur (PG) - Dimapur (Nagaland) 1 Line	DoP Nagaland	09-05-2018 14:45:00	09-05-2018 17:19:00	Earth Fault	No tripping	Dimapur(PG)
41	132 kV Dimapur (PG) - Dimapur (Nagaland) 2 Line	DoP, Nagaland	09-05-2018 15:40:00	09-05-2018 16:22:00	Earth Fault	No tripping	Dimapur(PG)
42	132 kV Doyang - Mokochung (Nagaland) 1 Line	DoP, Nagaland	09-05-2018 15:40:00	09-05-2018 18:35:00	Over current	No tripping	Doyang
43	132 kV Dimapur (PG) - Dimapur (Nagaland) 1 Line	DoP, Nagaland	09-05-2018 14:45:00	09-05-2018 17:19:00	Earth Fault	-	Dimapur(PG)
44	132 kV Dimapur (PG) - Kohima 1 Line	DoP, Nagaland	09-05-2018 16:08:00	09-05-2018 16:30:00	DP, ZI, B-E	No tripping	Dimapur(PG)
45	132 kV Dharmanagar - Dullavcherra 1 Line	AEGCL & TSECL	10-05-2018 07:45:00	10-05-2018 08:15:00	Earth Fault	Earth Fault	Dharmanagar, Dullavcherra
46	132 kV Agartala - Rokhia 1 Line	TSECL	10-05-2018 12:04:00	10-05-2018 16:53:00	Earth Fault	Earth Fault	Agartala, Rokhia
47	132 kV Agartala - Rokhia 2 Line	TSECL	10-05-2018 12:04:00	10-05-2018 12:24:00	No tripping	Earth Fault	Rokhia

--	--

Pending DR and EL output for the month of May'18

Event ID	Name of tripping element (End A - End B)	मालिक / Owner of the element	Date & Time of Event	Date & Time of Restoration	Relay indications		DR to be furnished by	
					End A	End B		
48	132 kV Agartala - Dhalabil Line	TSECL	10-05-2018 12:04:00	10-05-2018 12:52:00	Earth Fault	Earth Fault	Agartala, Dhalabil	
49	132 kV AGTPP - Kumarghat 1 Line	POWERGRID	10-05-2018 13:03:00	10-05-2018 13:12:00	DP, ZII, B-E	DP, ZI, R-E	AGTCCPP	
50	132 kV Kumarghat - P K Bari 1 Line	TSECL	10-05-2018 13:03:00	10-05-2018 13:34:00	DP, ZIII, B-E	Not Furnished	Kumarghat	
51	132 kV Kamalpur - P K Bari Line	TSECL	10-05-2018 13:03:00	10-05-2018 3:29:00	Earth Fault	No tripping	Kamalpur	
52	132 kV Ambassa - P K Bari Line	TSECL	10-05-2018 13:03:00	10-05-2018 13:35:00	Earth Fault	Earth Fault	Ambassa, PK Bari	
53	132 kV Aizawl - Kolasib 1 Line	POWERGRID	10-05-2018 13:53:00	10-05-2018 14:43:00	DP, ZI, B-E	Not Furnished	Aizawl	
54	132 kV Aizawl - Jiribam 1 Line	POWERGRID	10-05-2018 14:23:00	10-05-2018 14:40:00	No tripping	DP, ZII, R-Y-E	Jiribam	
55	132 kV Imphal - Silchar 2 Line	POWERGRID	10-05-2018 16:04:00	10-05-2018 16:15:00	DP, ZI, B-E	DP, ZI, B-E	Imphal, Silchar	
56	400/132/33 kV, 200 ICT II at Silchar	POWERGRID	11-05-2018 01:18:00	11-05-2018 18:11:00	Bucholtz Operated		Silchar	
57	132 kV Kumarghat - P K Bari 1 Line	TSECL	11-05-2018 08:17:00	11-05-2018 08:40:00	DP, ZIII, Y-E	No tripping	Kumarghat	
58	132 kV Dharmanagar - Dullavcherra 1 Line	AEGCL & TSECL	11-05-2018 08:17:00	11-05-2018 10:21:00	Earth Fault	Earth Fault	Dharmanagar, Dullavcherra	
59	132 kV Ranganadi - Pare 1 Line	POWERGRID	11-05-2018 11:09:00	11-05-2018 11:26:00	Earth Fault	Earth Fault	Ranganadi, Pare	
60	132 kV Ranganadi - Pare 1 Line	POWERGRID	11-05-2018 13:04:00	11-05-2018 14:32:00	Earth Fault	Over current	Ranganadi, Pare	
61	220 kV Samaguri - Sarusajai 2 Line	AEGCL	13-05-2018 11:50:00	13-05-2018 11:58:00	DP, ZI, Y-B-E	DP, ZI, R-B-E	Samaguri, Sarusajai	
62	132 kV Bokajan - Dimapur(PG) 1 Line	AEGCL	14-05-2018 11:35:00	14-05-2018 12:05:00	Earth Fault	DP, ZI, B-E	Bokajan, Dimapur	
63	132 kV Khandong - Kopili 1 Line	POWERGRID	14-05-2018 13:59:00	14-05-2018 14:09:00	DP, ZIII, R-Y-B-E	Over current	Khandong, Kopili	
64	220 kV Samaguri - Sarusajai 2 Line	AEGCL	15-05-2018 10:00:00	15-05-2018 17:55:00	Earth Fault, R-E	DP, ZI, R-E	Samaguri, Sarusajai	
65	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	15-05-2018 13:52:00	15-05-2018 18:52:00	No tripping	Earth Fault	Mokokchung(DoP, Nagaland)	
66	132 kV Monarchak - Rokhia 1 Line	TSECL	15-05-2018 15:28 :00	16-05-2018 06:30:00	Over Current	Over Current	Monarchak, Rokhia	
67	132 kV Khandong - Khliehriat 2 Line	POWERGRID	15-05-2018 18:01:00	15-05-2018 18:12:00	DP, ZII, R-Y-B-E	DP, ZI, R-Y-B-E	Khandong	
68	132 kV Bokajan - Dimapur(PG) Line	AEGCL	16-05-2018 09:22:00	16-05-2018 09:47:00	Tripped	DP, ZI, B-E	Bokajan, Dimapur	
69	132 kV Bokajan - Golaghat Line	AEGCL	16-05-2018 09:22:00	16-05-2018 09:40:00	Tripped	DP, ZI, B-E	Bokajan, Golaghat	
70	220 kV Killing (Byrnihat) - Misa 1 Line	MePTCL	16-05-2018 11:25:00	16-05-2018 11:50:00	DP, ZII, B-E	Auto-reclosure successfully operated	Misa	
71	132 kV Monarchak - Udaipur 1 Line	TSECL	16-05-2018 15:30:00	16-05-2018 15:44:00	DP, Z-II, R-E	Earth Fault	Monarchak, Udaipur	
72	132 kV Monarchak - Rokhia 1 Line	TSECL	16-05-2018 15:30:00	16-05-2018 15:37:00	Earth Fault	Earth Fault	Monarchak, Udaipur	

--	--

Pending DR and EL output for the month of May'18

Event ID	Name of tripping element (End A - End B)	मालिक / Owner of the element	Date & Time of Event	Date & Time of Restoration	Relay indications		DR to be furnished by
					End A	End B	
73	132 kV Lumshnong - Panchgram 1 Line	MePTCL & AEGCL	18-05-2018 06:13:00	Not yet restored	DP, ZI, B-E	No tripping	Lumshnong
74	132 kV Monarchak - Udaipur 1 Line	TSECL	18-05-2018 06:37:00	18-05-2018 07:06:00	No tripping	Earth Fault	Udaipur
75	132 kV Monarchak - Rokhia 1 Line	TSECL	18-05-2018 06:37:00	18-05-2018 08:51:00	DP, ZII, R-Y-B-E	Earth Fault	Monarchak, Udaipur
76	132 kV Monarchak - Udaipur 1 Line	TSECL	18-05-2018 11:50:00	18-05-2018 16:37:00	DP, ZII, R-E	Earth Fault	Monarchak, Udaipur
77	132 kV Monarchak - Rokhia 1 Line	TSECL	18-05-2018 12:24:00	18-05-2018 14:58:00	DP, ZII, R-E	Earth Fault	Monarchak, Rokhia
78	132 kV Agartala - Rokhia 1 Line	TSECL	20-05-2018 06:02:00	20-05-2018 06:22:00	Earth Fault	Earth Fault	Agartala, Rokhia
79	132 kV Agartala - Rokhia 2 Line	TSECL	20-05-2018 06:02:00	20-05-2018 06:22:00	Earth Fault	Earth Fault	Agartala, Rokhia
80	132 kV Monarchak - Rokhia 1 Line	TSECL	20-05-2018 06:02:00	20-05-2018 06:25:00	No tripping	Earth Fault	Rokhia
81	220 kV Kopili - Misa 1 Line	POWERGRID	21-05-2018 16:34:00	21-05-2018 18:48:00	Bus Bar Protection, Zone-B	Bus Bar Protection, Zone-B	Kopili
82	220 kV Misa - Samaguri 1 Line	POWERGRID	21-05-2018 16:34:00	21-05-2018 18:01:00	Pole Discrepancy operated	Bus Bar Protection, Zone-B	Samaguri
83	220 kV Killing (Byrnihat) - Misa 2 Line	MePTCL	21-05-2018 16:34:00	21-05-2018 18:43:00	DP, Z-II, B-E	No tripping	Killing
84	220 kV Misa - Samaguri 1 Line	POWERGRID	24-05-2018 11:33:00	24-05-2018 12:01:00	DP, ZI, R-E	DP, ZI, R-E	Samaguri
85	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	24-05-2018 14:09:00	24-05-2018 17:59:00	No tripping	Earth Fault	Mokokchung(DoP, Nagaland)
86	132 kV Doyang - Sanis Line	DoP, Nagaland	24-05-2018 14:09:00	24-05-2018 15:20:00	DP, Z-I, R-Y-E	Earth Fault	Doyang
87	132 kV Balipara- Khupi line	NEEPCO & DoP, AP	24-05-2018 16:04:00	24-05-2018 16:33:00	DP, ZI, Y-B-E	Not Furnished	Balipara
88	400/132/33 kV, 200 MVA ICT II Silchar	POWERGRID	25-05-2018 16:32:00	25-05-2018 17:40:00	Buchholz relay operated		Silchar
89	132 kV Khandong - Khliehriat 2 Line	POWERGRID	25-05-2018 22:26:00	25-05-2018 22:44:00	DP, ZII, R-Y-B-E	DP, ZI, R-Y-B-E	Khandong
90	132 kV Badarpur - Kolasib 1 Line	POWERGRID	26-05-2018 17:24:00	26-05-2018 17:35:00	No tripping	Earth Fault	Kolasib
91	220 kV Agia - BTPS 1 Line	AEGCL	27-05-2018 11:20:00	27-05-2018 11:40:00	No tripping	Earth Fault	BTPS
92	132 kV Pasighat - Roing Line	POWERGRID	29-05-2018 11:20:00	29-05-2018 11:55:00	DP, ZI, Y-B-E	No tripping	Pasighat
93	132 kV Along - Pasighat Line	DoP, Arunachal Pradesh	30-05-2018 12:15:00	30-05-2018 12:58:00	No tripping	Over current	Pasighat

--	--

DR and EL output not furnished for the month of June'18

Event ID	Name of tripping element (End A - End B)	Date & Time of Event	Date & Time of Restoration	Relay indications		DR and EL output to be furnished by
				End A	End B	
1	132 kV Motonga - Rangia Line	02-06-2018 11:05:00	02-06-2018 11:45:00	Not Furnished	Distance Protection	Rangia
2	132 kV Kamalpur - Kahilipara 1 Line	02-06-2018 11:05:00	02-06-2018 11:45:00	DP, ZI, R-E	DP, ZI, R-E	Kamalpur, Kahilipara
3	132 kV Imphal (Manipur) - Imphal (PG) 2 Line	03-06-2018 10:31:00	03-06-2018 10:53:00	No tripping	Over current	Imphal(PG)
4	132 kV Imphal (Manipur) - Imphal (PG) 1 Line	03-06-2018 10:31:00	03-06-2018 10:51:00	Earth Fault	No tripping	Imphal(Manipur)
5	132 kV Biswanath Chariali - Pavo 1 Line	04-06-2018 09:26:00	04-06-2018 09:55:00	No tripping	Earth Fault	Pavo
6	132 kV Gelyphu - Salakati 1 Line	04-06-2018 13:36:00	04-06-2018 19:09:00	Not Furnished	Earth Fault, Y-E	Salakati
7	132 kV Haflong (AS) - Haflong(PG) 1 Line	05-06-2018 13:57:00	05-06-2018 14:37:00	Earth Fault	No tripping	Haflong(AS)
8	132 kV Aizawl - Jiribam 1 Line	06-06-2018 01:42:00	06-06-2018 01:55:00	Earth Fault	No tripping	Aizawl
9	132 kV Dharmanagar - Dullavcherra Line	06-06-2018 02:20:00	06-06-2018 2:45:00	No tripping	Earth Fault	Dullavcherra
10	132 kV Khandong - Khliehriat 1 Line	06-06-2018 06:53:00	06-06-2018 07:18:00	DP, ZI, R-Y-B-E	No tripping	Khandong
11	132 kV Imphal (MSPCL) - Imphal (PG) 1 Line	06-06-2018 10:54:00	06-06-2018 11:10:00	Earth Fault, B-E	Earth Fault	Imphal(PG), Imphal(MSPCL)
12	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	06-06-2018 10:54:00	06-06-2018 11:47:00	Earth Fault, B-E	Earth Fault	Imphal(PG), Imphal(MSPCL)
13	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	06-06-2018 21:14:00	06-06-2018 21:29:00	DP, ZI, R-E	Earth Fault	Mokokchung(DoP, Nagaland)
14	132 kV Khandong - Khliehriat 1 Line	07-06-2018 14:23:00	07-06-2018 14:37:00	DP, ZII, R-Y-B-E	DP, ZI, R-Y-B-E	Khandong
15	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 1 Line	07-06-2018 14:26:00	07-06-2018 14:37:00	DP, ZI, R-Y-B	DP, ZI, Y-E	Khliehriat(MePTCL), Khliehriat(PG)
16	132 kV Khandong - Khliehriat 2 Line	08-06-2018 14:25:00	08-06-2018 14:46:00	Earth Fault	DP, ZI, Y-B-E	Khandong
17	132 kV Aizawl - Kolasib 1 Line	09-06-2018 02:33:00	09-06-2018 03:21:00	DP, ZI, R-E	DP, ZI, R-E	Aizawl, Kolasib
18	132 kV Balipara - Khupi 1 Line	09-06-2018 11:16:00	09-06-2018 11:34:00	Earth Fault	No tripping	Balipara
19	132 kV Dimapur (PG) - Kohima 1 Line	09-06-2018 13:46:00	09-06-2018 13:51:00	Earth Fault	No tripping	Dimapur

POWERGRID

Assam

MSPCL

MePTCL

P&ED, Mizoram

DoP, Nagaland

NEEPCO

DR and EL output not furnished for the month of June'18

Event ID	Name of tripping element (End A - End B)	Date & Time of Event	Date & Time of Restoration	Relay indications		DR and EL output to be furnished by
				End A	End B	
20	132 kV Dharmanagar - Dullavcherra 1 Line	09-06-2018 17:56:00	09-06-2018 18:15:00	No tripping	Earth Fault	Dullavcherra
21	132 kV Kumarghat - P K Bari 1 Line	09-06-2018 17:56:00	09-06-2018 18:04:00	DP, ZIII, R-E	No tripping	Kumarghat
22	132 kV Motonga - Rangia 1 Line	10-06-2018 18:28:00	10-06-2018 21:10:00	Not Furnished	DP, ZI, R-Y-B-E	Rangia
23	400 kV Azara - Silchar Line	11-06-2018 01:49:00	11-06-2018 02:27:00	DP, ZI, Y-B	DP, ZII, R-B	Azara
24	132 kV Loktak - Ningthoukhong Line	12-06-2018 06:38:00	12-06-2018 08:31:00	No tripping	Earth Fault	Ningthoukhong
25	132 kV Haflong (AS)-Haflong(PG) Line	12-06-2018 22:50:00	12-06-2018 23:01:00	No tripping	Earth Fault	Haflong(PG)
26	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	13-06-2018 04:45:00	13-06-2018 05:00:00	No tripping	DP, ZIII, B-E	Khliehriat(PG)
27	132 kV Haflong (AS)-Haflong(PG) Line	13-06-2018 21:36:00	13-06-2018 21:52:00	Over current, R ph	Over current, RYB ph	Haflong(PG), Haflong(AS)
28	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	14-06-2018 00:50:00	14-06-2018 00:57:00	No tripping	DP, ZIII, R-Y	Khliehriat(PG)
29	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	14-06-2018 01:24:00	14-06-2018 01:28:00	No tripping	DP, ZIII, B-E	Khliehriat(PG)
30	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	14-06-2018 01:42:00	14-06-2018 01:59:00	No tripping	DP, ZIII, B-E	Khliehriat(PG)
31	132 kV Imphal (Manipur) - Imphal (PG) 1 Line	14-06-2018 03:32:00	14-06-2018 04:13:00	Earth Fault	No tripping	Imphal(Manipur)
32	132 kV Imphal (Manipur) - Imphal (PG) 2 Line	14-06-2018 03:32:00	14-06-2018 04:13:00	Earth Fault	DP, ZI, B-E	Imphal(Manipur). Imphal(PG)
33	132 kV Daporijo - Ziro 1 Line	14-06-2018 05:00:00	15-06-2018 15:07:00	Tripped(no indication recorded), conductor snapped	DP, R-E, conductor snapped	Ziro
34	220 kV Samaguri - Sonapur Line	16-06-2018 04:10:00	16-06-2018 04:30:00	DP, ZI, B-E	Tripped(no indication recorded)	Samaguri
35	132 kV P.K.Bari - Silchar 1 Line	18-06-2018 01:40:00	18-06-2018 02:34:00	Master Relay	Over voltage	Silchar

DR and EL output not furnished for the month of June'18

Event ID	Name of tripping element (End A - End B)	Date & Time of Event	Date & Time of Restoration	Relay indications		DR and EL output to be furnished by
				End A	End B	
36	132 kV P.K.Bari - Silchar 2 Line	18-06-2018 01:40:00	18-06-2018 02:18:00	Master Relay	Over voltage	Silchar
37	132 kV Imphal (MSPCL) - Imphal (PG) 1 Line	18-06-2018 10:29:00	18-06-2018 10:54:00	Earth Fault	Earth Fault	Imphal(MSPCL), Imphal(PG)
38	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	18-06-2018 10:29:00	18-06-2018 10:42:00	Earth Fault	Earth Fault	Imphal(MSPCL), Imphal(PG)
39	132 kV Haflong (AEGCL) - Haflong(PG) Line	20-06-2018 21:21:00	20-06-2018 21:34:00	Over current, RY ph	No tripping	Haflong(AEGCL)
40	220 kV Misa - Samaguri 2 Line	21-06-2018 12:16:00	21-06-2018 12:25:00	DP, ZI, R-E	DP, ZI, R-E	Samaguri
41	132 kV Haflong (AEGCL) - Haflong(PG) 1 Line	21-06-2018 20:37:00	21-06-2018 20:49:00	No tripping	Earth Fault	Haflong(PG)
42	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	22-06-2018 03:36:00	22-06-2018 04:00:00	No tripping	DP, ZIII, R-Y-B-E	Khliehriat(PG)
43	132 kV Lekhi - Pare Line	21-06-2018 23:30:00	21-06-2018 23:55:00	No tripping	Over current	Pare
44	132 kV Imphal (MSPCL) - Imphal (PG) 1 Line	23-06-2018 10:04:00	23-06-2018 10:14:00	No tripping	Earth Fault	Imphal(PG)
45	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	23-06-2018 10:04:00	23-06-2018 10:15:00	No tripping	Earth Fault	Imphal(PG)
46	132 kV Balipara - Khupi 1 Line	23-06-2018 12:45:00	23-06-2018 13:02:00	DP, ZI, R-B-E	No tripping	Balipara
47	132 kV Dimapur (PG) - Kohima Line	23-06-2018 12:45:00	23-06-2018 13:06:00	Earth Fault, R-ph	No tripping	Dimapur
48	132 kV Balipara - Sonabil Line	24-06-2018 01:21:00	25-06-2018 14:14:00	DP, ZI, Y-E	DP, ZI, R-Y-B-E	Balipara, Sonabil
49	132 kV Dimapur (PG) - Kohima Line	24-06-2018 12:10:00	24-06-2018 12:21:00	DP, ZI, B-E	DP, ZI, R-Y-B	Dimapur, Kohima
50	132 kV Dimapur (PG) - Kohima Line	24-06-2018 12:49:00	24-06-2018 12:58:00	DP, ZI, B-E	DP, ZI, B-E	Dimapur, Kohima
51	132 kV Aizawl - Kumarghat 1 Line	25-06-2018 13:32:00	25-06-2018 13:47:00	DP, ZI, R-B	DP, ZI, R-B	Aizawl
52	400/132/33kV, ICT II at Silchar	25-06-2018 14:58:00	25-06-2018 15:15:00	WTI Trip		Silchar
53	220 kV AGBPP - Tinsukia 1 Line	25-06-2018 17:42:00	25-06-2018 20:03:00	No tripping	Tripped	Tinsukia
54	400/132/33kV, ICT I at Silchar	25-06-2018 18:09:00	25-06-2018 18:58:00	OTI Trip		Silchar
55	400/132/33kV, ICT I at Silchar	25-06-2018 14:58:00	25-06-2018 15:15:00	WTI Trip		Silchar

DR and EL output not furnished for the month of June'18

Event ID	Name of tripping element (End A - End B)	Date & Time of Event	Date & Time of Restoration	Relay indications		DR and EL output to be furnished by
				End A	End B	
56	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	26-06-2018 11:30:00	26-06-2018 11:44:00	Earth Fault	Earth Fault	Imphal(MSPCL), Imphal(PG)
57	132 kV Balipara - Khupi 1 Line	27-06-2018 04:39:00	27-06-2018 05:21:00	DP, ZI, R-B	No tripping	Balipara
58	132 kV Lumshnong - Panchgram 1 Line	27-06-2018 10:58:00	27-06-2018 16:25:00	No tripping	Over current	Panchgram
59	220 kV Jawaharnagar - Samaguri Line	27-06-2018 17:50:00	28-06-2018 15:20:00	DP, Z-I, B-E	DP, Z-I, R-E	Jawaharnagar, Samaguri
60	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	29-06-2018 01:50:00	29-06-2018 02:18:00	No tripping	Earth Fault	Imphal(PG)
61	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	29-06-2018 02:22:00	29-06-2018 02:41:00	No tripping	Earth Fault	Imphal(PG)
62	132 kV Ranganadi - Ziro 1 Line	29-06-2018 18:40:00	29-06-2018 18:48:00	No tripping	Over current	Ziro
63	132 kV Haflong - Jiribam 1 Line	30-06-2018 15:00:00	30-06-2018 15:10:00	DP, ZII, R-Y	DP, ZI, R-Y	Haflong, Jiribam
64	132 kV Haflong (AEGCL) - Haflong(PG) 1 Line	30-06-2018 06:29:00	30-06-2018 06:34:00	No tripping	Earth Fault	Haflong(PG)
65	132 kV Haflong (AEGCL) - Haflong(PG) 1 Line	30-06-2018 08:14:00	30-06-2018 08:23:00	No tripping	Over current	Haflong(PG)
66	132 kV Balipara - Khupi 1 Line	30-06-2018 13:59:00	30-06-2018 14:22:00	DP, ZI, R-B	No tripping	Balipara

DR and EL output not furnished for the month of July'18

Sl.No	Name of tripping element (End A - End B)	मालिक / Owner of the element	Date & Time of Event	Date & Time of Restoration	Relay indications		DR and EL output to be furnished by
					End A	End B	
1	132 kV Haflong (AEGCL) - Haflong(PG) 1 Line	AEGCL	01-07-2018 04:36:00	01-07-2018 05:02:00	No tripping	Over current	Haflong(PG)
2	132 kV Haflong (AEGCL) - Haflong(PG) 1 Line	AEGCL	01-07-2018 05:59:00	01-07-2018 06:13:00	No tripping	Over current	Haflong(PG)
3	220 kV Balipara - Sonabil 1 Line	POWERGRID & AEGCL	01-07-2018 13:02:00	01-07-2018 13:21:00	DP, ZII, R-Y-E	DP, ZI, R-Y-B	Balipara, Sonabil
4	132 kV Dimapur (PG) - Kohima 1 Line	POWERGRID & DoP, Nagaland	01-07-2018 12:54:00	01-07-2018 13:10:00	DP, ZI, B-E	No tripping	Dimapur
5	220 kV Misa - Samaguri 2 Line	POWERGRID	02-07-2018 09:55:00	02-07-2018 14:22:00	No tripping	SOTF	Samaguri
6	132 kV Balipara - Khupi Line	NEEPCO & DoP, AP	02-07-2018 16:12:00	02-07-2018 16:28:00	DP, ZI, R-E	No tripping	Balipara
7	400 kV Bongaigaon - New Siliguri (Binaguri) 1 Line	POWERGRID	04-07-2018 07:43:00	04-07-2018 09:13:00	PRV & Bucholz of Line Reactor at Bongaigaon	Direct Trip received	Bongaigaon
8	400/220 kV, 315 MVA ICT 1 at Balipara	POWERGRID	04-07-2018 14:24:00	04-07-2018 15:22:00	R phase OTI & WTI		Balipara
9	132 kV Dimapur (PG) - Kohima Line	POWERGRID & DoP, Nagaland	05-07-2018 10:00:00	05-07-2018 15:10:00	DP, ZI, B-E	No tripping	Dimapur
10	132 kV Motonga - Rangia Line	POWERGRID	05-07-2018 12:35:00	05-07-2018 13:03:00	No tripping	Over current	Rangia
11	132 kV Balipara - Khupi Line	NEEPCO & DoP, AP	06-07-2018 08:48:00	06-07-2018 09:03:00	Earth Fault	No tripping	Balipara
12	132 kV Kumarghat - P K Bari Line	TSECL	06-07-2018 12:10:00	06-07-2018 12:25:00	DP, ZIII, R-Y-E	No tripping	Kumarghat
13	132 kV Pasighat - Roing Line	POWERGRID	06-07-2018 12:55:00	06-07-2018 13:40:00	DP, ZI, Y-B-E	No tripping	Pasighat
14	132 kV Silchar - Hailakandi 1 Line	POWERGRID	07-07-2018 05:48:00	07-07-2018 06:16:00	DP, ZIII, Y-E	DP, ZI, Y-E	Hailakandi
15	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	07-07-2018 10:34:00	07-07-2018 11:00:00	DP, ZI, B-E	Over current	Doyang, Mokokchung
16	132 kV Balipara - Khupi Line	NEEPCO & DoP, AP	07-07-2018 11:28:00	07-07-2018 11:42:00	DP, ZI, B-E	No tripping	Balipara

POWERGRID

DoP, Arunchal Pradesh

AEGCL

MSPCL

MePTCL

P&ED, Mizoram

DoP, Nagaland

TSECL

BgTPP

NEEPCO

17	132 kV Ranganadi - Pare 1 Line	POWERGRID	07-07-2018 13:32:00	07-07-2018 13:54:00	Bus differential operated (Bus -B)	No tripping	Ranganadi
18	400/132/33 kV, 360 MVA ICT 2 at Ranganadi	NEEPCO	07-07-2018 13:32:00	07-07-2018 13:42:00	Bus Bar Differential operated (Bus B)		Rangandi
20	220 kV Samaguri - Sonabil 2 Line	AEGCL	08-07-2018 09:02:00	08-07-2018 09:21:00	DP, ZI, R-Y-B	DP, ZI, R-Y-B	Samaguri, Sonabil
21	220 kV Samaguri - Sonabil 2 Line	AEGCL	08-07-2018 10:56:00	09-07-2018 11:02:00	DP, ZI, R-Y-B	DP, ZI, R-Y-B	Samaguri, Sonabil
22	132 kV Imphal (MSPCL) - Imphal (PG) 1 Line	POWERGRID	11/07/2018 10:55:00	11/07/2018 11:09:00	Over current	No tripping	Imphal(MSPCL)
23	132 kV Imphal (MSPCL) - Imphal (PG) 2 Line	POWERGRID & MSPCL	11/07/2018 10:55:00	11/07/2018 11:11:00	Over current	No tripping	Imphal(MSPCL)
24	132 kV Dimapur (PG) - Kohima 1 Line	POWERGRID & DoP, Nagaland	11/07/2018 11:26:00	11/07/2018 11:38:00	DP, ZI, B-E	No tripping	Dimapur
25	400 kV Balipara - Bongaigaon 3 Line	POWERGRID	11/07/2018 13:58:00	11/07/2018 14:12:00	Directional Earth Fault	Direct Trip received	Balipara, Bongaigaon
26	400 kV Bongaigaon - Alipurduar 2 Line	ENICL	11/07/2018 14:04:00	11/07/2018 15:13:00	DP, ZII, Y-E	Not Furnished	Bongaigaon
27	132 kV Lekhi - Pare 1 Line	NEEPCO, DoP, AP & POWERGRID	11/07/2018 14:25:00	11/07/2018 14:35:00	Over current	No tripping	Lekhi
28	400 kV Balipara - Bongaigaon 3 Line	POWERGRID	11/07/2018 17:39:00	11/07/2018 17:55:00	Direct Trip received	GRP A & B Relay operated	Balipara, Bongaigaon
29	400 kV Balipara - Bongaigaon 3 Line	POWERGRID	11/07/2018 18:03:00	11/07/2018 19:02:00	Direct Trip received	GRP A & B Relay operated	Balipara, Bongaigaon
30	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	11/07/2018 22:34:00	11/07/2018 22:49:00	No tripping	Over current	Mokokchung(DoP, Nagaland)
31	220 kV Mariani (PG) - Mokokchung (PG) 2 Line	POWERGRID	11/07/2018 22:32:00	12/07/2018 13:14:00	DP, ZI, Y-E	DP, ZI, Y-E	Mokokchung
32	132 kV Aizawl - Melriat 1 Line	POWERGRID	12/07/2018 13:53:00	12/07/2018 14:17:00	Over current	Earth Fault	Aizawl, Melriat
33	132 kV Lekhi - Pare 1 Line	NEEPCO, DoP, AP & POWERGRID	12/07/2018 14:07:00	12/07/2018 14:50:00	Over current	No tripping	Lekhi
34	132 kV Aizawl - Kolasib 1 Line	POWERGRID	12/07/2018 16:16:00	12/07/2018 19:27:00	DP, ZII, R-E, LBB operated	Not Furnished	Aizawl, Kolasib
35	132 kV Doyang - Wokha 1 Line	DoP, Nagaland	13/07/2018 12:00:00	13/07/2018 13:27:00	DP, ZI, Y-B-E	Not Furnished	Doyang
36	132 kV Balipara - Khupi 1 Line	DoP, AP & POWERGRID	13/07/2018 14:48:00	13/07/2018 15:10:00	DP, ZI, B-E	No tripping	Balipara
37	132 kV Kumarghat - P K Bari 1 Line	TSECL	14/07/2018 09:26:00	14/07/2018 09:42:00	No tripping	Earth Fault	PK Bari
38	132 kV Doyang - Wokha 1 Line	DoP, Nagaland	14/07/2018 13:19:00	14/07/2018 13:35:00	DP, ZI, Y-E	Over current	Doyang, Wokha
39	132 kV Dimapur - Doyang 1 Line	POWERGRID	14/07/2018 23:26:00	15/07/2018 00:00:00	DP, ZI, B-E	DP, ZI, B-E	Dimapur, Doyang
40	Doyang - Mokokchung (DoP, Nagaland)	DoP, Nagaland	14/07/2018 23:26:00	15/07/2018 10:40:00	DP, ZI, B-E	DP, ZI, B-E	Doyang, Mokochung
41	132 kV Doyang - Wokha 1 Line	DoP, Nagaland	15/07/2018 04:35:00	15/07/2018 04:50:00	DP, Z-I, B-E	No tripping	Doyang
42	132 kV Kumarghat - P K Bari 1 Line	TSECL	15/07/2018 12:45:00	15/07/2018 12:49:00	No tripping	Earth Fault	PK Bari
43	132 kV Aizawl - Kumarghat 1 Line	POWERGRID	15/07/2018 16:00:00	15/07/2018 16:21:00	RYB Ph, 78 km	RYB Ph, 61 km	Kumarghat
44	132 kV Balipara - Khupi 1 Line	NEEPCO & DoP, AP	16-07-2018 11:52:00	16-07-2018 12:10:00	DP, ZII, B-E	No tripping	Balipara

45	+/- 800 kV Biswanath Chariali - Agra 2 HVDC	POWERGRID	17-07-2018 12:27:00	17-07-2018 13:01:00	DC Line Fault	No tripping	Biswanath Chariali	
46	132 kV Dharmanagar - Dullavcherra 1 Line	AEGCL & TSECL	17-07-2018 12:40:00	17-07-2018 12:53:00	Earth Fault	Earth Fault	Dharmanagar, Dullavcherra	
47	132 kV Doyang - Sanis 1 Line	DoP, Nagaland	18-07-2018 12:33:00	18-07-2018 13:09:00	Earth Fault	Earth Fault	Doyang	
48	132 kV Doyang - Sanis 1 Line	DoP, Nagaland	18-07-2018 19:30:00	18-07-2018 20:30:00	Earth Fault	No tripping	Doyang	
49	132 kV Monarchak - Udaipur 1 Line	TSECL	19/07/2018 10:40:00	19/07/2018 11:05:00	No tripping	tripped	Udaipur	
50	132 kV Monarchak - Rokhia 1 Line	TSECL	19/07/2018 10:40:00	19/07/2018 11:06:00	No tripping	tripped	Udaipur	
51	132 kV Doyang - Mokokchung (DoP, Nagaland) 1 Line	DoP, Nagaland	19-07-2018 10:50:00	19-07-2018 11:25:00	No tripping	Earth Fault	Mokokchung(DoP, Nagaland)	
52	132 kV Doyang - Sanis 1 Line	DoP, Nagaland	19-07-2018 17:20:00	19-07-2018 17:30:00	DP, Z-III, Y-B-E	Over current	Doyang	
53	132 kV Lumshnong - Panchgram 1 Line	AEGCL & MePTCL	19-07-2018 14:10:00	20-07-2018 12:05:00	Earth Fault	Not Furnished	Lumshnong	
54	132 kV Motonga - Rangia 1 Line	POWERGRID	20-07-2018 12:47:00	20-07-2018 13:23:00	Not Furnished	Tripped	Rangia	
55	220 kV AGBPP - Tinsukia 2 Line	AEGCL	20-07-2018 13:10:00	20-07-2018 14:15:00	DP, ZI, B-E	DP, ZI, B-E	AGBPP, Tinsukia	
56	132 kV Khliehriat (MePTCL) - Khliehriat (PG) 2 Line	MePTCL	20-07-2018 14:44:00	20-07-2018 15:28:00	Earth Fault	DP, ZI, R-Y-E	Khliehriat(MePTCL), Khliehriat	
57	132 kV Khandong - Khliehriat 1 Line	POWERGRID	20-07-2018 14:51:00	20-07-2018 14:57:00	DP, ZII, R-Y-B-E	Not Furnished	Khliehriat	
58	132 kV Lekhi - Nirjuli 1 Line	DoP, AP & POWERGRID	21-07-2018 00:53:00	21-07-2018 02:30:00	Not Furnished	No tripping	Lekhi	
59	132 kV Gelyphu - Salakati 1 Line	POWERGRID	21-07-2018 01:24:00	21-07-2018 01:45:00	DP, ZI, Y-E	DP, Z-I, Y-B-E	Salakati	
60	132 kV Loktak - Ningthoukhong 1 Line	MSPCL	21-07-2018 12:40:00	21-07-2018 15:52:00	DP, ZI, B-E	Earth Fault	Ningthoukhong	
61	132 kV Doyang - Sanis 1 Line	DoP, Nagaland	21-07-2018 13:18:00	21-07-2018 13:44:00	DP, Z-III, Y-B-E	Earth Fault	Doyang	
62	132 kV Doyang - Sanis 1 Line	DoP, Nagaland	21-07-2018 13:57:00	21-07-2018 14:48:00	DP, Z-III, Y-B-E	Earth Fault	Doyang	
63	132 kV Along - Daporijo 1 Line	DoP, Arunachal Pradesh	22-07-2018 23:35:00	23-07-2018 18:06:00	No tripping	Earth Fault	Daporijo	
64	132 kV Doyang - Sanis Line	DoP, Nagaland	25-07-2018 10:40:00	25-07-2018 11:04:00	Earth Fault	No tripping	Doyang	
65	132 kV Jiribam - Tipaimukh Line	POWERGRID	25-07-2018 22:05:00	25-07-2018 22:34:00	DP, ZI, R-E, 0.1 Kms	DP, ZII, R-E, 66 Kms	Jiribam , Tipaimukh	
66	400 kV Balipara - Bongaigaon 3 Line	POWERGRID	26-07-2018 08:23:00	26-07-2018 08:32:00	Relay maloperation	Direct trip received	Balipara, Bongaigaon	
67	132 kV Badarpur - Kolasib Line	POWERGRID	26-07-2018 10:00:00	26-07-2018 10:18:00	DP, ZII, Y-E	Earth Fault	Badarpur	
68	132 kV Balipara - Khupi Line	NEEPCO & DoP, AP	27-07-2018 18:38:00	27-07-2018 19:20:00	DP, Z-II, Y-E	No tripping	Balipara	
69	132 kV Motonga - Rangia Line	POWERGRID	27-07-2018 18:29:00	27-07-2018 19:41:00	Not Furnished	DP, R-Y-B	Rangia	
70	132 kV Pare - Itanagar 1 Line	NEEPCO & DoP, AP	28-07-2018 01:25:00	28-07-2018 11:23:00	Over current	Over current	Pare, Itanagar	
71	132 kV Doyang - Sanis Line	DoP, Nagaland	29-07-2018 07:13:00	29-07-2018 07:21:00	Distance Protection operated	Earth Fault	Doyang, Sanis	

72	800 kV Biswanath Chariali - Agra 2 HVDC	POWERGRID	30-07-2018 04:03:00	30-07-2018 05:58:00	Not Furnished	due to Fire Trip(VESDA Zone-3)	Biswanath Chariali
73	400kV BGTTP - Transformer 2 Transformer	NTPC	30-07-2018 11:20:00	31-07-2018 13:53:00	Tripped on PRV		BgTTP
74	400 kV Palatana - Silchar 2 Line	NETCL	30-07-2018 17:57:00	30-07-2018 18:22:00	Direct Trip received	No tripping	Silchar
75	400 kV Palatana - Silchar 2 Line	NETCL	30-07-2018 22:09:00	30-07-2018 22:29:00	Direct Trip received	No tripping	Silchar
76	132 kV Doyang - Sanis Line	DoP, Nagaland	31/07/2018 05:35:00	31/07/2018 05:58:00	Over current	Not Furnished	Doyang
77	132 kV Kohima - Wokha 1 Line	DoP, Nagaland	31-07-2018 12:30:00	31-07-2018 16:25:00	Earth Fault	No tripping	Kohima
78	132 kV Dimapur - Kohima Line	POWERGRID & DoP, Nagaland	31/07/2018 16:20:00	Not restored yet	Over current	Earth Fault	Dimapur, Kohima