



[illegible]

		400kV Misa SS																												
66	220 KV Bus coupler Bay																												0900Hrs to 1700Hrs	AMP of Bay Equipments
67	400/220kV, 315 MVA ICT-2																												0900Hrs to 1700Hrs	Repeat testing after violation found in winding tandela
68	400kV, 50 MVAR Bus reactor 1																												CSD 0900Hrs to 1700Hrs	Installation of New Differential relay.
SN	Name of Element	Feb-22																											Time	Remarks
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	
	Interregional/International																													
69	400 kV Bongaigaon-Alipurduar Line#1 TL																												0900Hrs to 1700Hrs	Commissioning of numerical A/R relay in Tie Bay 414 & implementation of auto reclose scheme through Alipurduar#1 protection relays
70	220kV Salakati - Alipurduar #1 TL																												0900Hrs to 1700Hrs	AMP of Bay Equipments
71	220kV Salakati - Alipurduar #2 TL																												0900Hrs to 1700Hrs	AMP of Bay Equipments
72	800KV AGRA BNC - I (S/D proposed by NR3)																												CSD 0900Hrs to 1800Hrs	Transmission Line diversion work due to construction of Gorakhpur Link Expressway - S/D proposed by NR3. During shut down, all 04 poles will be out
73	800KV AGRA BNC - II (S/D proposed by NR3)																												CSD 0900Hrs to 1800Hrs	Transmission Line diversion work due to construction of Gorakhpur Link Expressway - S/D proposed by NR3. During shut down, all 04 poles will be out
SN	Name of Element	Feb-22																											Time	Remarks
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	
	ASSAM																													
1	132 KV PANCHGRAM-HAILAKANDI																												08:00 Hrs - 16:00 Hrs	Restranging of conductor from Loc.62-Loc.72
2	132 KV SRIKONA-PAILAPOOL																												08:00 Hrs - 16:00 Hrs	Preventive Maintenance & Inspection work
3	132 KV HAILAKANDI-DULLAVCHERRA																												08:00 Hrs - 16:00 Hrs	Preventive Maintenance & Inspection work
4	132 KV PANCHGRAM-LUMSINONG																												08:00 Hrs - 16:00 Hrs	Restranging of conductor from Loc.357-Loc.367
5	132 KV DHARMANAGAR-DULLAVCHERRA																												08:00 Hrs - 16:00 Hrs	INSTALLATION OF GROUND WIRE BETWEEN LOCATION NO 277 TO NO 282 ALONGWITH INSTALLATION OF VIBRATION DAMPERS & GROUND WIRE CLAMPS
6	132KV PAILAPOOL-JIRIBUM																												09:00-17:00 HRS	REPAIRING/REPLACEMENT OF BENT TOWER LEG MEMBER AT LOC 48
7	220KV SAMAGURI-JAWAHARNAGAR																												08:00 Hrs - 16:00 Hrs	PREVENTIVE MAINTENANCE
8	220KV SARUSAJAI-JAWAHARNAGAR GIS																												9:00-15:00 HRS	PREVENTIVE MAINTENANCE
9	220KV SARUSAJAI-SONAPUR GIS																												08:00 Hrs - 16:00 Hrs	PREVENTIVE MAINTENANCE
10	220KV SARUSAJAI-SONAPUR GIS																												9:00-12:00 HRS	PREVENTIVE MAINTENANCE
11	220KV SONAPUR-SAMAGURI																												08:00 Hrs - 16:00 Hrs	PREVENTIVE MAINTENANCE
12	220KV AGIA-BTPS CKT 1																												08:00 Hrs - 16:00 Hrs	PREVENTIVE MAINTENANCE, CORRIDOR CLEANING
13	220KV AGIA-BTPS CKT 1																												8:00-16:00 HRS	CORRIDOR CLEANING
14	220KV AGIA-BTPS CKT 2																												08:00 Hrs - 16:00 Hrs	PREVENTIVE MAINTENANCE, CORRIDOR CLEANING
15	220KV AGIA-BTPS CKT 2																												8:00-16:00 HRS	CORRIDOR CLEANING
16	220KV SAMAGURI-MARIANI-2																												08:00 Hrs - 16:00 Hrs	PERIODIC LINE MAINTENANCE
17	220KV SAMAGURI-SONABIL-1																												08:00 Hrs - 16:00 Hrs	PERIODIC LINE MAINTENANCE
18	220KV SAMAGURI-SONABIL-2																												08:00 Hrs - 16:00 Hrs	PERIODIC LINE MAINTENANCE
19	132KV MARIANI-GOLAGHAT																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
20	132KV GOLAGHAT-BOKAJAN																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
21	220KV TINSUKIA-KATHALGURI CKT 1																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
22	220KV TINSUKIA-KATHALGURI CKT 2																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
23	132KV BOKAJAN-DIMAPUR																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
24	220KV SARUSAJAI-MIRZA-1																												9:00-12:00 HRS	PREVENTIVE MAINTENANCE
25	220KV SARUSAJAI-MIRZA-1																												8:00-16:00HRS	PERIODIC TESTING OF BAY EQUIPMENTS
26	220KV SARUSAJAI-MIRZA-2																												9:00-12:00 HRS	PREVENTIVE MAINTENANCE
27	220KV SARUSAJAI-MIRZA-2																												8:00-16:00HRS	PERIODIC TESTING OF BAY EQUIPMENTS
28	220KV MIRZA-BOKO																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
29	220KV MIRZA - BOKO																												8:00-16:00 HRS	PERIODIC TESTING OF BAY EQUIPMENTS
30	220KV AGIA-BOKO																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEANING & PREVENTIVE MAINTENANCE
31	220KV AGIA - MIRZA																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEANING & PREVENTIVE MAINTENANCE
32	220KV AGIA- MIRZA																												08:00 Hrs - 16:00 Hrs	CORRIDOR CLEARANCE
33	220KV NAMRUP-MARIANI																												8:00-16:00HRS	JUMPER CHECKING AND PREVENTIVE MAINTENANCE
34	400kVMIRZA-BONGAIGAON																												8:00-16:00HRS	PERIODIC TESTING OF BAY EQUIPMENTS
35	63MVA± BUS REACTOR AT MIRZA																												8:00-16:00HRS	PERIODIC TESTING OF BAY EQUIPMENTS
36	63MVA± line reactor of SILCHAR MIRZA																												10:00 HRS - 9:59 HRS	PERIODIC TESTING OF BAY EQUIPMENTS
	ARUNACHAL PRADESH																													
1	132kV D/C Hoj (Ranganadi) -Managar Transmission line																												00:00 Hrs from 21.02.2022 to 24:00 of 15.04.2022.	Truncating of partially eroded hillock for tower foundation and erection of a new alternate tower.

SN	Name of Element	Feb-22																												Mar-22					Time	Remarks
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	1	2	3	4	5		
	NEEPCO																																			
1	Doyang HPS Unit-II							CSD w.e.f. 00:00 Hrs of 07.02.2022 to 24:00 Hrs of 03.03.2022																						w.e.f. 00:00 Hrs of 07.02.2022 to 24:00 Hrs of 03.03.2022	Annual Planned Maintenance (APM)					
2	Pare HPS Unit-II							CSD w.e.f. 00:00 Hrs of 08.02.2022 to 24:00 Hrs of 01.03.2022																						w.e.f. 00:00 Hrs of 08.02.2022 to 24:00 Hrs of 01.03.2022	Annual Planned Maintenance (APM)					
	NTPC BONGAIGAON																																			
1	400 KV Bus 1 & 400KV Bay 410(Unit92)																																	09:00 Hrs to 18:00 Hrs	Over-hauling of Bus 1 Pantograph Isolator (89A) of Bay 410 UH2	
2	400 KV Bus 2 & 400KV Bay 410(Unit92)																																	09:00 Hrs to 18:00 Hrs	Over-hauling of Bus 2 Pantograph Isolator (89B) of Bay 410 UH2	
	INDIGRID (400KV)																																			
1	MAIN BAY (410) OF 400KV-SURAJMANINAGAR (STERLITE)-PALATANA-2 @SURAJMANINAGAR (STERLITE) - 400KV																																	09:00 Hrs to 18:00 Hrs	Grading ring was found damaged on long rod insulator of R-phase in bay 410 bay gantry tower	
2	TIE BAY (411) OF 400KV-SURAJMANINAGAR (STERLITE)-PALATANA-2 AND 400KV/132KV SURAJMANINAGAR (STERLITE)-JCT-2 @SURAJMANINAGAR (STERLITE) - 400KV																																	09:00 Hrs to 18:00 Hrs	Grading ring was found damaged on long rod insulator of R-phase in bay 410 bay gantry tower	
3	132KV Bus-coupler Coupler Bay at Surajmaninagar																																	09:00 Hrs to 18:00 Hrs	Leakage arresting of BC bay CT	