



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/1277-1299

Dt: 22nd May, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 14.11.2022 to 11.12.2022 (4 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 14.11.2022 to 11.12.2022 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16 Paise/KVARH w.e.f from 1st April 2022, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

Reactive Energy (VArH) Charge Statement
for the period 11/14/2022 to 11/20/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	4,611
ASSAM	0	374,175
MANIPUR	0	3,431
MEGHALAYA	0	803,523
MIZORAM	6,595	0
NAGALAND	0	38,362
TRIPURA	0	1,812


REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	5,480
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	31
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 संयुक्त वि.सं./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 11/14/2022 to 11/20/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	27461.6	43.6	27648.3	43.6	33.61	0.00	5,377	0	5,377
	132kV Khupi-Balipara	NP-9606-A	AS-55	35511	79.9	35026.6	79.9	-174.38	0.00	27,901	0	27,901
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1133.4	26097	1133.7	26097	0.22	0.00	35	0	35
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6311.2	458.8	6312	0.00	0.29	0	46	46
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6041.2	546.2	6041.6	0.00	0.14	0	23	23
	132kV Tenga-Balipara	NP-9696-A	AR-17	49911.6	6.3	49601.6	6.3	-223.20	0.00	-35,712	0	-35,712
	132kV Lekhi-Pare	NP-9607-A	PA-01	55476	206.3	55504.7	206.3	13.78	0.00	-2,204	0	-2,204
	132kV Chimpu-Pare	NP-9411-A	PA-05	2254.4	99991.6	2257	99991.6	1.25	0.00	-200	0	-200
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	641.4	99914.4	641.9	99914.4	0.48	0.00	77	0	77
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	270.2	99917.8	270.5	99917.8	0.29	0.00	46	0	46
TOTAL												-4,611
ASSAM	220kV BTSP-II - SALAKATI	NP-9435-A	AS-31	49819.6	80.3	50177.7	80.3	572.96	0.00	-91,674	0	-91,674
	220kV BTSP-I - SALAKATI	NP-9434-A	AS-30	18390.6	6862.6	18531.5	6862.6	225.44	0.00	-36,070	0	-36,070
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86755.9	98611.9	86802.6	98611.9	46.70	0.00	7,472	0	7,472
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	97060.2	99216.4	97233.9	99216.4	173.70	0.00	27,792	0	27,792
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	36510.2	64	36730.4	64	352.32	0.00	-56,371	0	-56,371
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	12476.4	79846.2	12391.8	79846.2	-60.91	0.00	-9,746	0	-9,746
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	6080	19.8	6097.6	19.8	12.67	0.00	-2,028	0	-2,028
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	82685.3	99490	82617.3	0.00	-24.48	0	3,917	3,917
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21876.5	3282.5	21876.5	3285	0.00	0.45	0	72	72
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78327.3	91177.4	78316.9	91177.3	-3.74	-0.04	-599	6	-593
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83060.7	99934.6	83051.1	99934.6	-3.46	0.00	-553	0	-553
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83224.2	99980.4	83203.7	99980.4	-7.38	0.00	-1,181	0	-1,181
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	73998.1	99985.7	73962.6	99985.7	-12.78	0.00	-2,045	0	-2,045
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29714.1	1522.5	29716.7	1522.5	2.50	0.00	-399	0	-399
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	97220.6	99796.4	96915.7	99796.4	-2,217.45	0.00	-354,793	0	-354,793
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	8219	97922.6	915.6	97922.6	681.45	0.00	109,033	0	109,033
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	86327.6	92931.6	86338.6	92926.5	3.96	-1.84	634	294	927
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95406.8	98995.6	95395.8	98995.6	-7.92	0.00	-1,267	0	-1,267
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4483.4	5738.2	4483.5	5810.8	0.07	52.27	12	-8,364	-8,352
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	74308.6	98907	74355.1	98908.8	22.32	0.86	3,571	-138	3,433
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	85033.9	99496.8	85012.2	99488.7	-10.42	-3.89	-1,667	622	-1,044
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	15388.3	73527.2	15388.6	73527.2	0.11	0.00	17	0	17
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	50020.8	68710.7	50020.9	68710.7	0.04	0.00	6	0	6
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	93682.7	99951	93673.5	99951	-33.45	0.00	5,353	0	5,353
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	92737.4	2.1	92679.1	2.1	-212.00	0.00	33,920	0	33,920
TOTAL												-374,175
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96487.6	99123.5	96487.4	99123.5	-0.14	0.00	-23	0	-23
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	547.5	99940.1	547.2	99940.1	-0.14	0.00	-23	0	-23
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98421.4	99869.4	98448.1	99869.4	9.61	0.00	-1,538	0	-1,538
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21816.2	384.5	21820	384.5	1.37	0.00	-219	0	-219
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19316.5	383.9	19320.2	383.9	1.33	0.00	-213	0	-213
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42876.4	99420.4	42873.5	99420.3	-1.04	-0.04	167	-6	161
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94049	19.4	94047.2	19.4	-1.30	0.00	207	0	207
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2175.4	0.2	2188.8	0.2	97.45	0.00	-15,593	0	-15,593
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	99611.2	2	99583.2	2	-6.72	0.00	-1,075	0	-1,075
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	99115.1	99999.5	99502.7	99999.5	93.02	0.00	14,884	0	14,884
TOTAL												-3,431


 (S.M. Aisool)
 निदेशक/Director
 वजु क्षेत्र/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94064.7	80849.1	94064.7	80841.9	0.00	-5.18	0	829	829
	132kV KHLRT S-PG II	NP-6880-A	ME-09	213	21184.3	213	21208.8	0.00	17.64	0	2,822	2,822
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89996.4	85966.1	89995.4	85966.1	-1.60	0.00	256	0	256
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84225.5	96033.3	84224.3	96033.3	-1.92	0.00	307	0	307
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	46689.4	99953.8	44637.4	99953.8	-7,461.82	0.00	-1,193,891	0	-1,193,891
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	15946.2	99864	16609.9	99864	2,413.45	0.00	386,153	0	386,153
TOTAL												-803,523
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	398.1	3615.8	398.4	3616.4	0.11	0.22	-17	35	17
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	72650.7	51481.1	72536.5	51481.1	-41.11	0.00	6,578	0	6,578
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												6,595
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16506.8	9418.5	16513.4	9418.5	6.34	0.00	-1,014	0	-1,014
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	73083.4	4414.8	73096	4414.8	9.07	0.00	-1,452	0	-1,452
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7631.9	98298.6	7627.1	98298.6	-1.73	0.00	276	0	276
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44504.6	3086.8	44499.8	3394	-1.73	110.59	-276	-17,695	-17,971
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43919.6	3118.7	43915.2	3430.3	-1.58	112.18	-253	-17,948	-18,202
TOTAL												-38,362
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97105.3	84658.6	97105.3	84658.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8844.7	6224.9	8831.1	6224.9	-13.06	0.00	-2,089	0	-2,089
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48772.6	93754.9	48772.6	93754.9	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68784.3	72313.3	68784.3	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10252.5	99994.9	10250.6	99994.9	-1.82	0.00	292	0	292
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4478.8	99999.7	4479.7	99999.7	0.86	0.00	-138	0	-138
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1260.7	99980.8	1260.8	99980.8	0.10	0.00	15	0	15
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1156.8	99997.2	1157.5	99997.2	0.67	0.00	108	0	108
TOTAL												-1,812

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पु.नि.वि.म/NERPC
 बिजुत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 11/14/2022 to 11/20/2022

									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NE-0089-A	AS-02	99578	99925.1	99563.8	99925.1	-6.816	0	-1,091	0	0	
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NE-0088-A	AS-01	99445.3	99872.7	99429.4	99872.6	-7.632	-0.048	-1,221	8	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	93405.5	99820.4	93388.2	99820.4	-8.304	0	-1,329	0		0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0	0
			NP-8491-A	ME-05	94287.8	99794.8	94271	99794.8	-8.064	0	-1,290	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92067.2	1085.1	92020.8	1085.1	-22.272	0	-3,564	0	0	0
			NP-8384-A	ME-01	94277.1	61578.1	94277.1	61540.2	0	-18.192	0	2,911	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	84543.9	6287.4	84457.1	6320.8	-41.664	16.032	-6,666	-2,565	-4,040	-4,040
			NP-9071-A	ME-16	85718.5	23278.9	85737.7	23211.9	9.216	-32.16	1,475	5,146	-1,440	
132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	80028.2	321.4	79945.1	346.4	-29.916	9	-4,787	-1,440	-1,440	-1,440	
		NP-9945-A	ME-17	300.8	95409.8	284.8	95279.6	-5.76	-46.872	-922	7,500	7,500		
TOTAL													-5,480	

ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	16136.8	99654.8	16164.4	99654.8	13.248	0	2,120	0	0
			NP-6892-B	TR-06	76269	69480.3	76269	69177.4	0	-145.392	0	23,263	0
TOTAL													0

MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92504.8	99292.3	92504.4	99267.3	-0.192	-12	-31	1,920	-31
			NP-9947-A	NG-02	959.9	99677.4	962.9	99675	1.44	-1.152	230	184	
TOTAL													-31

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एच.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.के.वि.न/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 11/21/2022 to 11/27/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	837	0
ASSAM	0	28,290
MANIPUR	0	38,950
MEGHALAYA	0	750,316
MIZORAM	17,384	0
NAGALAND	0	31,423
TRIPURA	0	7,768

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	8,227
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	8
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइनोल/S.M. Ainol)
 निदेशक/Director
 उ.पु.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 11/21/2022 to 11/27/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	27820.9	43.6	28583.3	43.6	137.23	0.00	21,957	0	21,957
	132kV Khupi-Balipara	NP-9606-A	AS-55	34938	79.9	34518.3	79.9	-151.09	0.00	24,175	0	24,175
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1133.7	26097	1133.7	26097	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6312	458.8	6325.9	0.00	5.00	0	801	801
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6041.6	546.2	6055.2	0.00	4.90	0	783	783
	132kV Tenga-Balipara	NP-9696-A	AR-17	49552.7	6.3	49255.3	6.3	-214.13	0.00	-34,260	0	-34,260
	132kV Lekhi-Pare	NP-9607-A	PA-01	55547.7	206.3	55738.6	206.3	91.63	0.00	-14,661	0	-14,661
	132kV Chimpu-Pare	NP-9411-A	PA-05	2259.9	99991.6	2298.5	99991.6	18.53	0.00	-2,964	0	-2,964
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	642.5	99914.4	664.4	99914.4	21.02	0.00	3,364	0	3,364
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	270.9	99917.8	281.6	99917.8	10.27	0.00	1,644	0	1,644
TOTAL												837
ASSAM	220kV BTSP-II - SALAKATI	NP-9435-A	AS-31	50279.8	80.3	50790.1	80.3	816.48	0.00	-130,637	0	-130,637
	220kV BTSP-I - SALAKATI	NP-9434-A	AS-30	0	0	0	0	0.00	0.00	0	0	0
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86887.3	98611.9	87237.4	98611.9	350.10	0.00	56,016	0	56,016
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	97365.6	99216.4	97874.1	99216.4	508.50	0.00	81,360	0	81,360
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	36758.3	64	36878.3	64	192.00	0.00	-30,720	0	-30,720
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	12315.7	79846.2	11995.4	79846.2	-230.62	0.00	-36,899	0	-36,899
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	6141.7	19.8	6248.4	19.8	76.82	0.00	-12,292	0	-12,292
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	82605.8	99488.7	82535.4	-0.47	-25.34	-75	4,055	3,980
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21876.9	3285	21876.9	3285.9	0.00	0.16	0	26	26
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78270.6	91177.3	78147.7	91177.3	-44.24	0.00	-7,079	0	-7,079
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83006.5	99934.6	82889.6	99934.6	-42.08	0.00	-6,733	0	-6,733
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83158.2	99980.4	83034.9	99980.4	-44.39	0.00	-7,102	0	-7,102
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	73907.6	99985.7	73741	99985.7	-59.98	0.00	-9,596	0	-9,596
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29724.2	1522.6	29726	1522.6	1.73	0.00	-276	0	-276
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	96856.5	99796.4	96638.8	99796.4	-1,583.27	0.00	-253,324	0	-253,324
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	929.9	97922.6	976.3	97922.6	337.45	0.00	53,993	0	53,993
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	86338.6	92926.5	86345.4	92925.8	2.45	-0.25	392	40	432
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95317.9	98995.6	95137.1	98995.6	-130.18	0.00	-20,828	0	-20,828
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4492.5	5810.8	4559.1	5810.8	47.95	0.00	7,672	0	7,672
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	74393.4	98908.8	74469.6	98908.8	36.58	0.00	5,852	0	5,852
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	84984.1	99488.7	84923.2	99481.6	-29.23	-3.41	-4,677	545	-4,132
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	15388.6	73527.2	15395.1	73527.2	2.34	0.00	374	0	374
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	50020.9	68710.7	50022.2	68710.6	0.47	-0.04	75	6	81
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	93623.6	99951	93421.3	99951	-735.64	0.00	117,702	0	117,702
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	92590.1	2.1	92308.5	2.1	-1,024.00	0.00	163,840	0	163,840
TOTAL												-28,290
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96491.6	99123.5	96496.1	99123.5	3.24	0.00	518	0	518
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	549.3	99940.1	546.1	99940.1	-1.54	0.00	-246	0	-246
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98470.7	99869.4	98479.9	99869.4	3.31	0.00	-530	0	-530
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21826.2	384.5	21846.1	384.5	7.16	0.00	-1,146	0	-1,146
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19326.3	383.9	19345.9	383.9	7.06	0.00	-1,129	0	-1,129
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42858.5	99420.3	42791.2	99420.3	-24.23	0.00	3,876	0	3,876
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94040.3	19.4	94027.6	19.4	-9.14	0.00	1,463	0	1,463
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2200.1	0.2	2239.1	0.2	283.64	0.00	-45,382	0	-45,382
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	99577.7	2	99553.5	2	-5.81	0.00	-929	0	-929
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	99572.6	99999.5	99691.2	99999.5	28.46	0.00	4,554	0	4,554
TOTAL												-38,950


 (J. M. Aimal) (J.M.Aimal)
 Director/Director
 उ.पु.के.वि.म./NERPC
 बिजुत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94065	80841.9	94063.4	80836.5	-1.15	-3.89	-184	622	438
	132kV KHLRT S-PG II	NP-6880-A	ME-09	213	21209.7	213	21238.3	0.00	20.59	0	3,295	3,295
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89990.2	85966.1	89942.3	85966.1	-76.64	0.00	12,262	0	12,262
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84216.9	96033.3	84155.3	96033.3	-98.56	0.00	15,770	0	15,770
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	44306.6	99953.8	42623	99953.8	-6,122.18	0.00	-979,549	0	-979,549
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	16718.8	99864	17058.2	99864	1,234.18	0.00	197,469	0	197,469
TOTAL												-750,316
MIZORAM	132kV LAUNGMAU-AIZWAL PG	NP-9495-A	MZ-02	402.4	3616.4	441.4	3655.3	14.04	14.00	-2,246	2,241	-6
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	72408.3	51481.1	72117.8	51492.5	-104.58	4.10	16,733	657	17,389
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												17,384
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16526.4	9419	16529.9	9419	3.36	0.00	-538	0	-538
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	73119.7	4415.5	73128.8	4415.5	6.55	0.00	-1,048	0	-1,048
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7613.3	98298.6	7611.2	98298.6	-0.76	0.00	121	0	121
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44496.1	3495.3	44493.9	3751.6	-0.79	92.27	-127	-14,763	-14,890
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43911.5	3532.1	43909.6	3791.8	-0.68	93.49	-109	-14,959	-15,068
TOTAL												-31,423
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97110.7	84658.6	97166.4	84658.6	40.10	0.00	-6,417	0	-6,417
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8826.7	6224.9	8772.5	6224.9	-52.03	0.00	-8,325	0	-8,325
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48772.6	93754.9	48748.2	93754.8	-23.42	-0.10	-3,748	15	-3,732
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68784.3	72313.3	68784.3	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10246.5	99994.9	10204.3	99994.9	-40.51	0.00	6,482	0	6,482
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4481.3	99999.7	4491.8	99999.7	10.08	0.00	-1,613	0	-1,613
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1262.7	99980.8	1281.7	99980.8	18.24	0.00	2,918	0	2,918
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1159.4	99997.2	1178.4	99997.2	18.24	0.00	2,918	0	2,918
TOTAL												-7,768

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(S.M. Aimal/S.M. Aimal)
निदेशक/Director
उप क्षेत्र/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 11/21/2022 to 11/27/2022

									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NE-0089-A	AS-02	99555.8	99925.1	99521.1	99925.1	-16.656	0	-2,665	0	0	
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0			
	KAHELIPARA-UMTRU I	MEGHALAYA	NE-0088-A	AS-01	99418.6	99872.6	99368.9	99872.6	-23.856	0	-3,817	0	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	93376.8	99820.4	93343.6	99820.4	-15.936	0	-2,550	0		
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0	0
			NP-8491-A	ME-05	94259.7	99794.8	94227.3	99794.8	-15.552	0	-2,488	0		
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91932.3	1085.1	91799.7	1085.1	-63.648	0	-10,184	0	0	0
			NP-8384-A	ME-01	94277.1	61540.2	94277.1	61468.7	0	-34.32	0	5,491		
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	84421.8	6321.6	84168.6	6329.5	-121.536	3.792	-19,446	-607	-7,357	-7,357
			NP-9071-A	ME-16	85743.1	23205.9	85831	23190.3	42.192	-7.488	6,751	1,198		
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	79920.1	345	79560.7	360.1	-129.384	5.436	-20,701	-870	-870	-870
			NP-9945-A	ME-17	283.7	95257.1	239	95210.8	-16.092	-16.668	-2,575	2,667		
TOTAL													-8,227	
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	16272.9	99654.8	16596.6	99654.8	155.376	0	24,860	0	0	
			NP-6892-B	TR-06	76269	69127.3	76269	67407.4	0	-825.552	0	132,088		
TOTAL													0	
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92491.1	99246.8	92492.7	99246.9	0.768	0.048	123	-8	-8	
			NP-9947-A	NG-02	973.9	99688.5	976.6	99684.5	1.296	-1.92	207	307		
TOTAL													-8	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(S.M. Aimol/S.M. Aimol)
निदेशक/Director
उप क्षेत्र/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 11/28/2022 to 12/4/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	14,469	0
ASSAM	0	20,587
MANIPUR	0	18,139
MEGHALAYA	0	719,232
MIZORAM	5,979	0
NAGALAND	0	23,303
TRIPURA	0	1,359

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	7,127
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	3,233
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 डी.पू.रे.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 11/28/2022 to 12/4/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	28776.9	43.6	29749.3	43.6	175.03	0.00	28,005	0	28,005
	132kV Khupi-Balipara	NP-9606-A	AS-55	34431.9	79.9	34070.5	79.9	-130.10	0.00	20,817	0	20,817
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1133.7	26097	1133.7	26097	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6325.9	458.8	6325.9	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6055.2	546.2	6055.2	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	49203.6	6.3	48980.6	6.3	-160.56	0.00	-25,690	0	-25,690
	132kV Lekhi-Pare	NP-9607-A	PA-01	55777.3	206.3	55894.1	206.3	56.06	0.00	-8,970	0	-8,970
	132kV Chimpu-Pare	NP-9411-A	PA-05	2305.1	99991.6	2323.5	99991.6	8.83	0.00	-1,413	0	-1,413
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	667.9	99914.4	675.3	99914.4	7.10	0.00	1,137	0	1,137
TOTAL												14,469
ASSAM	220kV BTSP-II - SALAKATI	NP-9435-A	AS-31	50890.8	80.3	51168.2	80.3	443.84	0.00	-71,014	0	-71,014
	220kV BTSP-I - SALAKATI	NP-9434-A	AS-30	19043.2	6862.6	19339	6862.6	473.28	0.00	-75,725	0	-75,725
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	87321.8	98611.9	87628.2	98611.9	306.40	0.00	49,024	0	49,024
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	98015.7	99216.4	98659.6	99216.4	643.90	0.00	103,024	0	103,024
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	36913.1	64	37028.4	64	184.48	0.00	-29,517	0	-29,517
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	11928.2	79846.2	11689.9	79846.2	-171.58	0.00	-27,452	0	-27,452
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	6268.9	19.8	6314	19.8	32.47	0.00	-5,196	0	-5,196
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99488.7	82519.4	99488.7	82417.8	0.00	-36.58	0	5,852	5,852
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21876.9	3286	21876.9	3287.8	0.00	0.32	0	52	52
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78136	91177.3	78101.8	91177.3	-12.31	0.00	-1,970	0	-1,970
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	82881.3	99934.6	82852.1	99934.6	-10.51	0.00	-1,682	0	-1,682
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83020.7	99980.4	82959.5	99980.4	-22.03	0.00	-3,525	0	-3,525
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	73714.1	99985.7	73583.8	99985.7	-46.91	0.00	-7,505	0	-7,505
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29727.2	1522.6	29728.9	1523.9	1.63	1.25	-261	200	-61
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	96574.7	99796.4	96382.1	99796.4	-1,400.73	0.00	-224,116	0	-224,116
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1001.2	97922.6	1078.1	97922.6	559.27	0.00	89,484	0	89,484
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	86345.7	92925.8	86349.2	92923.3	1.26	-0.90	202	144	346
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95112.6	98995.6	95046.1	98995.6	-47.88	0.00	-7,661	0	-7,661
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4560.8	5810.8	4565.5	5810.8	3.38	0.00	541	0	541
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	74485.1	98908.8	74542.4	98909.2	27.50	0.19	4,401	-31	4,370
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	84922.5	99481.6	84916.6	99472.8	-2.83	-4.22	-453	676	223
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	15395.1	73527.2	15395.1	73527.2	0.00	0.00	0	0	0
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	50022.2	68710.6	50022.2	68709.8	0.00	-0.29	0	46	46
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	93381.4	99951	93291.4	99950.9	-327.27	-0.36	52,364	-58	52,305
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	92234.6	2.1	92011.9	2.1	-809.82	0.00	129,571	0	129,571
TOTAL												-20,587
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96496.1	99123.5	96496.1	99123.5	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	546.1	99940.1	546.1	99940.1	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98441.7	99869.4	98440.4	99869.4	-0.47	0.00	75	0	75
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21847.7	384.5	21848.5	384.5	0.29	0.00	-46	0	-46
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19347.4	383.9	19348.1	383.9	0.25	0.00	-40	0	-40
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42790.5	99420.3	42790.3	99420.3	-0.07	0.00	12	0	12
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94026.5	19.4	94026	19.4	-0.36	0.00	58	0	58
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2244.1	0.2	2256.2	0.2	88.00	0.00	-14,080	0	-14,080
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	99549.5	2	99527.5	2	-5.28	0.00	-845	0	-845
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	99670.5	99999.5	99585.3	99999.5	-20.45	0.00	-3,272	0	-3,272
TOTAL												-18,139


(एस.एम. आइमल/S.M. Aimal)
निदेशक/Director
उ.पु.से.वि.स./NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94063.4	80836.2	94063.4	80832	0.00	-3.02	0	484	484
	132kV KHLRT S-PG II	NP-6880-A	ME-09	213	21241.6	213	21267.8	0.00	18.86	0	3,018	3,018
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89942.3	85966.1	89942.3	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84155.3	96033.3	84155.3	96033.3	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	42307.6	99953.8	40736.7	99953.7	-5,712.36	-0.36	-913,978	58	-913,920
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	17151	99864	17479.6	99864	1,194.91	0.00	191,185	0	191,185
TOTAL												-719,232
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	441.4	3655.3	441.4	3733.7	0.00	28.22	0	4,516	4,516
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	72117.8	51492.5	72117.8	51517.9	0.00	9.14	0	1,463	1,463
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												5,979
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16534.3	9419	16536.4	9422.8	2.02	3.65	-323	584	261
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	73136.8	4415.5	73142.3	4420.8	3.96	3.82	-634	611	-23
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7608.3	98298.6	7604.1	98299.8	-1.51	0.43	242	69	311
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44492.2	3802.2	44490.7	4006.9	-0.54	73.69	-86	-11,791	-11,877
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43908	3842.8	43906.6	4049.3	-0.50	74.34	-81	-11,894	-11,975
TOTAL												-23,303
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97168.6	84658.6	97176.4	84658.6	5.62	0.00	-899	0	-899
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8769.1	6224.9	8749.6	6224.9	-18.72	0.00	-2,995	0	-2,995
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48748	93754.8	48744	93754.8	-3.84	0.00	-614	0	-614
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68784.3	72313.3	68784.3	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10201.9	99994.9	10188.9	99994.9	-12.48	0.00	1,997	0	1,997
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4492.6	99999.7	4495.6	99999.7	2.88	0.00	-461	0	-461
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1282.9	99980.8	1288.4	99980.8	5.28	0.00	845	0	845
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1179.6	99997.2	1184.6	99997.2	4.80	0.00	768	0	768
TOTAL												-1,359

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(S.M. Almol/S.M. Almol)
निदेशक/Director
उप क्षेत्रीय/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 11/28/2022 to 12/4/2022

									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NE-0089-A	AS-02	99512.5	99925.1	99467.6	99925.1	-21.552	0	-3,448	0	0	
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NE-0088-A	AS-01	99356.3	99872.6	99290.8	99872.6	-31.44	0	-5,030	0	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	93335.5	99820.4	93294.3	99820.4	-19.776	0	-3,164	0		0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0	0
			NP-8491-A	ME-05	94219.4	99794.8	94179	99794.8	-19.392	0	-3,103	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91783.6	1085.1	91698.6	1085.1	-40.8	0	-6,528	0	0	0
			NP-8384-A	ME-01	94277.1	61460.8	94277.1	61400.2	0	-29.088	0	4,654	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	84117.6	6329.5	83878.1	6329.5	-114.96	0	-18,394	0	0	-7,127
			NP-9071-A	ME-16	85846.1	23190.3	85938.9	23190.3	44.544	0	7,127	0	0	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	79490.5	360.1	79109.6	360.1	-137.124	0	-21,940	0	0	0
NP-9945-A			ME-17	220.5	95210.8	136.5	95198.8	-30.24	-4.32	-4,838	691	0	0	
TOTAL													-7,127	
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	16623.8	99654.8	16700.2	99654.8	36.672	0	5,868	0	0	
			NP-6892-B	TR-06	76269	67077.9	76269	65276	0	-864.912	0	138,386		0
TOTAL														0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92491.7	99246.9	92490.9	99155.1	-0.384	-44.064	-61	7,050	-3,233	
			NP-9947-A	NG-02	979	99684.5	985.3	99725.8	3.024	19.824	484	-3,172		0
TOTAL														-3,233

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(एस.एम. अलम/S.M. Alam)
निर्देशक/Director
उत्प्रेक्षित/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 12/5/2022 to 12/11/2022**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	19,430	0
ASSAM	286	0
MANIPUR	0	42,874
MEGHALAYA	0	534,272
MIZORAM	9,487	0
NAGALAND	0	30,534
TRIPURA	0	21,719

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	11,013
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	691
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.न/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 12/5/2022 to 12/11/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	29892.9	43.6	30603.3	43.6	127.87	0.00	20,460	0	20,460
	132kV Khupi-Balipara	NP-9606-A	AS-55	34029.6	79.9	33567.7	79.9	-166.28	0.00	26,605	0	26,605
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1133.7	26097	1133.7	26098.9	0.00	1.37	0	-219	-219
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6325.9	458.8	6336.2	0.00	3.71	0	593	593
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6055.2	546.2	6063.8	0.00	3.10	0	495	495
	132kV Tenga-Balipara	NP-9696-A	AR-17	48958.6	6.3	48737.1	6.3	-159.48	0.00	-25,517	0	-25,517
	132kV Lekhi-Pare	NP-9607-A	PA-01	55898.3	206.3	55933.9	206.3	17.09	0.00	-2,734	0	-2,734
	132kV Chimpu-Pare	NP-9411-A	PA-05	2323.8	99991.6	2330.7	99991.6	3.31	0.00	-530	0	-530
TOTAL	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	675.3	99914.4	676.5	99914.4	1.15	0.00	184	0	184
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	287.2	99917.8	287.8	99917.8	0.58	0.00	92	0	92
TOTAL												19,430
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	51200.5	80.3	51359.6	80.3	254.56	0.00	-40,730	0	-40,730
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	19460.4	6862.6	19684.6	6862.7	358.72	0.16	-57,395	26	-57,370
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	87696.4	98611.9	87968	98611.9	271.60	0.00	43,456	0	43,456
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	98771	99216.4	99350.1	99216.4	579.10	0.00	92,656	0	92,656
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	37039.7	64	37128.3	64	141.76	0.00	-22,682	0	-22,682
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	11645.8	79846.2	11459.6	79846.2	-134.06	0.00	-21,450	0	-21,450
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	6329	19.8	6396.2	19.8	48.38	0.00	-7,741	0	-7,741
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99488.7	82405.9	99488.7	82350.4	0.00	-19.98	0	3,197	3,197
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21876.9	3287.8	21876.9	3301.6	0.00	2.48	0	397	397
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78095.3	91177.3	78040.7	91177.3	-19.66	0.00	-3,145	0	-3,145
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	82847.1	99934.6	82797.4	99934.6	-17.89	0.00	-2,863	0	-2,863
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	82950.4	99980.4	82839.1	99980.4	-40.07	0.00	-6,411	0	-6,411
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	73558.7	99985.7	73391.4	99985.7	-60.23	0.00	-9,636	0	-9,636
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29730.2	1523.9	29734.5	1523.9	4.13	0.00	-660	0	-660
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	96337.4	99796.4	96192.8	99796.4	-1,051.64	0.00	-168,262	0	-168,262
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1097.3	97922.6	1160.9	97922.6	462.55	0.00	74,007	0	74,007
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	86349.2	92912.9	86349.2	92872.6	0.00	-14.51	0	2,321	2,321
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95040.2	98995.6	94910.6	98995.6	-93.31	0.00	-14,930	0	-14,930
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4565.5	5810.8	4595.7	5810.8	21.74	0.00	3,479	0	3,479
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	74561.5	98909.2	74612.2	98929.3	24.34	9.65	3,894	-1,544	2,350
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	84913.1	99472.8	84891.9	99415.1	-10.18	-27.70	-1,628	4,431	2,803
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	15395.1	73527.2	15395.1	73514.6	0.00	-4.54	0	726	726
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	50022.2	68709.8	50022.2	68696	0.00	-4.97	0	795	795
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	93284.5	99950.9	93230.8	99950.9	-195.27	0.00	31,244	0	31,244
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	91964.9	2.1	91795.2	2.1	-617.09	0.00	98,735	0	98,735
TOTAL												286
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96496.1	99123.5	96496.5	99123.5	0.29	0.00	46	0	46
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	546.1	99940.1	546.2	99940.1	0.05	0.00	8	0	8
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98435.5	99869.4	98442	99869.4	2.34	0.00	-374	0	-374
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21849.2	384.5	21853.1	384.5	1.40	0.00	-225	0	-225
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19348.6	383.9	19352.4	383.9	1.37	0.00	-219	0	-219
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42789	99420.3	42786.6	99420.3	-0.86	0.00	138	0	138
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94025.4	19.4	94022.2	19.4	-2.30	0.00	369	0	369
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2259.2	0.2	2292.9	0.2	245.09	0.00	-39,215	0	-39,215
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	99522.8	2	99495.4	2	-6.58	0.00	-1,052	0	-1,052
TOTAL												-42,874


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94063.4	80832	94063.3	80786.4	-0.07	-32.83	-12	5,253	5,242
	132kV KHLRT S-PG II	NP-6880-A	ME-09	213	21268.2	213	21370.8	0.00	73.87	0	11,820	11,820
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89942.3	85966.1	89942.3	85966	0.00	-0.16	0	-26	-26
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84155.3	96033.3	84154.3	96033.3	-1.60	0.00	256	0	256
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	40457.7	99953.7	39262	99953.7	-4,348.00	0.00	-695,680	0	-695,680
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	17570.3	99864	17818	99864	900.73	0.00	144,116	0	144,116
TOTAL												-534,272
MIZORAM	132kV LAUNGMAU-AIZWAL PG	NP-9495-A	MZ-02	441.4	3735.7	441.6	3858.8	0.07	44.32	-12	7,091	7,079
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	72117.7	51518.9	72096.8	51539.8	-7.52	7.52	1,204	1,204	2,408
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												9,487
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16539.3	9422.8	16544.5	9422.9	4.99	0.10	-799	15	-783
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	73147.2	4420.8	73159.7	4420.9	9.00	0.07	-1,440	12	-1,428
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7599.2	98299.8	7585.3	98299.8	-5.00	0.00	801	0	801
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44490.4	4021.5	44488.5	4270.9	-0.68	89.78	-109	-14,365	-14,475
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43906.5	4064.1	43904.8	4316.7	-0.61	90.94	-98	-14,550	-14,648
TOTAL												-30,534
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97176.4	84658.6	97243.6	84658.6	48.38	0.00	-7,741	0	-7,741
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8749.6	6224.9	8629.2	6224.9	-115.58	0.00	-18,493	0	-18,493
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48744	93754.8	48696.2	93754.8	-45.89	0.00	-7,342	0	-7,342
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68784.3	72313.3	68785.5	72313.3	1.44	0.00	230	0	230
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10188.9	99994.9	10148.6	99994.9	-38.69	0.00	6,190	0	6,190
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4495.6	99999.7	4507.3	99999.7	11.23	0.00	-1,797	0	-1,797
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1288.4	99980.8	1312.2	99980.7	22.85	-0.10	3,656	15	3,671
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1184.6	99997.2	1207.8	99997.2	22.27	0.00	3,564	0	3,564
TOTAL												-21,719

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.व.वि.सं./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 12/5/2022 to 12/11/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NE-0089-A	AS-02	99512.5	99925.1	99467.6	99925.1	-21.552	0	-3,448	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NE-0088-A	AS-01	99356.3	99872.6	99290.8	99872.6	-31.44	0	-5,030	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93281.9	99820.4	93246.4	99820.4	-17.04	0	-2,726	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94166.7	99794.8	94131.9	99794.8	-16.704	0	-2,673	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91672.7	1085.1	91569.9	1085.1	-49.344	0	-7,895	0	0
			NP-8384-A	ME-01	94277.1	61400.9	94277.1	61282	0	-57.072	0	9,132	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	83814.4	6329.5	83524.6	6329.5	-139.104	0	-22,257	0	-11,013
			NP-9071-A	ME-16	85972.5	23190.3	86115.9	23190.3	68.832	0	11,013	0	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	79017.6	360.1	78565.2	360.1	-162.864	0	-26,058	0	0
			NP-9945-A	ME-17	135.1	95198.8	108.7	95153.3	-9.504	-16.38	-1,521	2,621	
TOTAL													-11,013
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	16719.7	99654.8	16832.4	99654.8	54.096	0	8,655	0	0
			NP-6892-B	TR-06	76269	64966.5	76269	64000	0	-463.92	0	74,227	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92490.2	99155.1	92480.3	99154.2	-4.75	-0.43	-760	69	-691
TOTAL													-691

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(एस.एम.आइमोल/S.M.Aimol)
निदेशक/Director
उ.सू.श्रेष्ठि/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong