



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/ 898-920

Dt: 10th May, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 19.09.2022 to 16.10.2022 (4 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 19.09.2022 to 16.10.2022 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16 Paise/KVARH w.e.f from 1st April 2022, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,


(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

Reactive Energy (VArH) Charge Statement
for the period 9/19/2022 to 9/25/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	27,827
ASSAM	0	185,164
MANIPUR	0	38,523
MEGHALAYA	0	486,606
MIZORAM	11,514	0
NAGALAND	41,393	0
TRIPURA	0	169

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	972
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उद्योग विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 9/19/2022 to 9/25/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	25041.1	43.6	25041.1	43.6	0.00	0.00	0	0	0
	132kV Khupi-Balipara	NP-9606-A	AS-55	39542.8	79.9	38999.5	79.9	-195.59	0.00	31,294	0	31,294
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1129.2	26078.3	1129.2	26078.3	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6273.3	458.8	6277.5	0.00	1.51	0	242	242
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6003.7	546.2	6007.9	0.00	1.51	0	242	242
	132kV Tenga-Balipara	NP-9696-A	AR-17	52814.4	6.3	52297	6.3	-372.53	0.00	-59,604	0	-59,604
	132kV Lekhi-Pare	NP-9607-A	PA-01	54844	206.3	54844	206.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	2132.8	99991.6	2132.8	99991.6	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	589.6	99934.6	589.6	99934.6	0.00	0.00	0	0	0
TOTAL												-27,827

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	12869.8	6862.6	13035.3	6862.6	264.80	0.00	-42,368	0	-42,368
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86058	98614.5	86074.1	98614.5	16.10	0.00	2,576	0	2,576
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	95303.3	99217.7	95339.3	99217.7	36.00	0.00	5,760	0	5,760
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	35866.8	63.9	35939.7	64	116.64	0.16	-18,662	26	-18,637
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	14209.9	79846.2	14060.4	79846.2	-107.64	0.00	-17,222	0	-17,222
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5660	17.8	5696.7	17.8	26.42	0.00	-4,228	0	-4,228
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	83636.3	99490	83636.3	0.00	0.00	0	0	0
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21865.2	3258.1	21865.3	3258.9	0.02	0.14	-3	23	20
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78742.1	91177.5	78706.3	91177.5	-12.89	0.00	-2,062	0	-2,062
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83441.5	99934.7	83406.6	99934.7	-12.56	0.00	-2,010	0	-2,010
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83940.8	99980.5	83874.5	99980.5	-23.87	0.00	-3,819	0	-3,819
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75118.9	99985.8	75032.4	99985.8	-31.14	0.00	-4,982	0	-4,982
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.5	1452.3	29691.5	1479.1	0.00	25.73	0	4,116	4,116
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98400.3	99796.5	98392.6	99796.4	-56.00	-0.73	-8,960	116	-8,844
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	495.7	97922.6	491.2	97922.6	-32.73	0.00	-5,236	0	-5,236
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85872.9	92842.4	85879.7	92895.7	2.45	19.19	392	-3,070	-2,678
	220kV Mariani-AGBPP	NP-6888-A	AS-03	30546.9	96335.3	29912	96335.3	-1,015.84	0.00	-162,534	0	-162,534
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95693.1	99006.1	95668.4	99006.1	-17.78	0.00	-2,845	0	-2,845
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5290.7	4443.5	5284.2	0.00	-4.68	0	749	749
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73749.5	98891.5	73777	98891.5	13.20	0.00	2,112	0	2,112
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	85804.3	99562.9	85761	99562.9	-20.78	0.00	-3,325	0	-3,325
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15385.6	75626.9	15385.6	74960.3	0.00	-239.98	0	38,396	38,396
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50019.2	71054.4	50019.2	70327	0.00	-261.86	0	41,898	41,898
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94175.1	99951	94175.1	99951	0.00	0.00	0	0	0
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93701.7	2.1	93701.7	2.1	0.00	0.00	0	0	0
TOTAL												-185,164

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96465.3	99123.5	96467.1	99123.5	1.30	0.00	207	0	207
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	523.4	99940.1	526.3	99940.1	1.39	0.00	223	0	223
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98399.8	99869.3	98379.1	99869.3	-7.45	0.00	1,192	0	1,192
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21749.5	384.5	21754.9	384.5	1.94	0.00	-311	0	-311
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19252.5	383.9	19257.7	383.9	1.87	0.00	-300	0	-300
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	43019.6	99420.4	42977.2	99420.4	-15.26	0.00	2,442	0	2,442
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94099.4	19.4	94095.1	19.4	-3.10	0.00	495	0	495
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1923.2	0.2	1959.7	0.2	265.45	0.00	-42,473	0	-42,473
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-38,523


 (J. M. Almol) / J. M. Almol
 Director / Director
 NERPC / NERPC
 Ministry of Power / Min. of Power
 Govt. of India / Govt. of India
 Shillong / Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94172.3	80889	94167	80889	-3.82	0.00	-611	0	-611
	132kV KHLRT S-PG II	NP-6880-A	ME-09	206.4	21060.8	206.4	21062.9	0.00	1.51	0	242	242
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90017.8	85966.1	90017.8	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84266.9	96033.4	84249.9	96033.4	-27.20	0.00	4,352	0	4,352
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	60282.3	99953.8	59402.8	99953.8	-3,198.18	0.00	-511,709	0	-511,709
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13687	99864	13723.3	99864	132.00	0.00	21,120	0	21,120
TOTAL												-486,606
MIZORAM	132kV LAUNGUAL-AIZWAL PG	NP-9495-A	MZ-02	352.8	3160.5	361.9	3280.8	3.28	43.31	-524	6,929	6,405
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73488.9	51451.9	73390.2	51441.9	-35.53	-3.60	5,685	-576	5,109
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												11,514
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16451.6	9215.9	16451.6	9338.5	0.00	117.70	0	18,831	18,831
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72973	4067.2	72973	4275.2	0.00	149.76	0	23,962	23,962
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7696.3	98372.4	7696.3	98309.3	0.00	-22.72	0	-3,635	-3,635
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	516.6	44549.1	497.9	0.00	-6.73	0	1,077	1,077
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	520.9	43962.3	500.8	0.00	-7.24	0	1,158	1,158
TOTAL												41,393
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.6	97103.3	84658.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt I	NP-6850-A	TR-01	8944.8	6225	8944.2	6225	-0.58	0.00	-92	0	-92
	132kV Agartala-AGTTP Ckt II	NP-6851-A	TR-02	48794.6	93755	48794.6	93755	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68775.6	72313.3	68775.6	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10230.9	99994.8	10231.4	99994.9	0.48	0.10	-77	15	-61
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4465.1	99999.7	4465.2	99999.7	0.10	0.00	-15	0	-15
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1155	99997.2	1155	99997.2	0.00	0.00	0	0	0
TOTAL												-169

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (ए.एस.आइमल/S.M. Aimal)
 निदेशक/Director
 उच्च वोल्टेज/NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 9/19/2022 to 9/25/2022

for the period 01/01/2021 to 31/03/2021									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93601.8	99820.9	93596.4	99822.7	-2.592	0.864	-415	-138	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94481.1	99795.4	94475.7	99797	-2.592	0.768	-415	-123	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92417.9	1085.2	92420.8	1085.2	1.392	0	223	0	0
			NP-8384-A	ME-01	94276.8	61971.2	94276.8	61936.8	0	-16.512	0	2,642	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86001.4	6264.2	85974.8	6267.1	-12.768	1.392	-2,043	-223	-730
			NP-9071-A	ME-16	85225.5	23533.2	85232.1	23444.4	3.168	-42.624	507	6,820	
132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82058.9	298.6	82020.3	302.8	-13.896	1.512	-2,223	-242	-242	
		NP-9945-A	ME-17	674.9	96140.6	666	95959.2	-3.204	-65.304	-513	10,449		
TOTAL													-972
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15553.4	99654.8	15590.8	99654.8	17.952	0	2,872	0	0
			NP-6892-B	TR-06	76269	73035.5	76269	72994.9	0	-19.488	0	3,118	
TOTAL													0
MANIPUR	132kv KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92845.1	99289.4	92844.4	99289	-0.336	-0.192	-54	31	0
			NP-9947-A	NG-02	50.8	99722	47.6	99719.2	-1.536	-1.344	-246	215	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available

(एस.एस.आइमोल/S.M.Aimol)
निदेशक/Director
उ.पू.वे.वि.स./NERPC
बिजुत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 9/26/2022 to 10/2/2022**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	2,514
ASSAM	16,388	0
MANIPUR	0	10,467
MEGHALAYA	0	472,805
MIZORAM	7,154	0
NAGALAND	15,026	0
TRIPURA	0	0

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	657
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 एस.एम. आइमोल/S.M.Aimol
 निदेशक/Director
 उत्तु.रे.वि.स/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 9/26/2022 to 10/2/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	25053.4	43.6	25061.7	43.6	1.49	0.00	239	0	239
	132kV Khupi-Balipara	NP-9606-A	AS-55	38685.8	79.9	37728.8	79.9	-344.52	0.00	55,123	0	55,123
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1129.2	26078.3	1129.2	26078.3	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6277.5	458.8	6277.6	0.00	0.04	0	6	6
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6007.9	546.2	6008	0.00	0.04	0	6	6
	132kV Tenga-Balipara	NP-9696-A	AR-17	52153.3	6.3	51651.2	6.3	-361.51	0.00	-57,842	0	-57,842
	132kV Lekhi-Pare	NP-9607-A	PA-01	54844	206.3	54844.6	206.3	0.29	0.00	-46	0	-46
	132kV Chimpu-Pare	NP-9411-A	PA-05	2132.8	99991.6	2132.8	99991.6	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	589.6	99934.6	589.6	99934.6	0.00	0.00	0	0	0
TOTAL												-2,514

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	13119.3	6862.6	13230.9	6862.6	178.56	0.00	-28,570	0	-28,570
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86091.2	98614.5	86091.2	98614.5	0.00	0.00	0	0	0
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	95380.6	99217.7	95392.4	99217.7	11.80	0.00	1,888	0	1,888
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	35983.5	64	36318	64	535.20	0.00	-85,632	0	-85,632
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	14016.1	79846.2	14016.1	79846.2	0.00	0.00	0	0	0
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5702.5	17.8	5702.5	19.8	0.00	1.44	0	230	230
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	83613.2	99490	83227.7	0.00	-138.78	0	22,205	22,205
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21865.3	3258.9	21865.3	3260.4	0.00	0.27	0	43	43
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78706.3	91177.5	78706.3	91177.4	0.00	-0.04	0	6	6
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83406.6	99934.7	83406.6	99934.6	0.00	-0.04	0	6	6
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83870.6	99980.5	83870.6	99980.4	0.00	-0.04	0	6	6
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75012.7	99985.8	75012.7	99985.7	0.00	-0.04	0	6	6
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.5	1479.1	29691.5	1489.3	0.00	9.79	0	1,567	1,567
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98392.6	99796.4	98390.1	99796.4	-18.18	0.00	-2,909	0	-2,909
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	491.2	97922.6	490.7	97922.6	-3.64	0.00	-582	0	-582
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85903.9	92895.7	85928.1	92918.3	8.71	8.14	1,394	-1,302	92
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95668.4	99006.1	95668.4	98995.7	0.00	-7.49	0	1,198	1,198
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5284.2	4443.5	5258.9	0.00	-18.22	0	2,915	2,915
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73786.4	98891.5	73789.2	98892.2	1.34	0.34	215	-54	161
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	85738	99562.9	85736.9	99561.4	-0.53	-0.72	-84	115	31
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15385.6	74960.3	15385.6	74100.1	0.00	-309.67	0	49,548	49,548
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50019.2	70327	50019.2	69399.5	0.00	-333.90	0	53,424	53,424
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94175.1	99951	94175.1	99951	0.00	0.00	0	0	0
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93701.7	2.1	93700.4	2.1	-4.73	0.00	756	0	756
TOTAL												16,388

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96467.1	99123.5	96467.1	99123.5	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	526.3	99940.1	526.3	99940.1	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98370.6	99869.3	98370.6	99869.4	0.00	0.04	0	6	6
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21758.6	384.5	21758.6	384.5	0.00	0.00	0	0	0
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19261.3	383.9	19261.3	383.9	0.00	0.00	0	0	0
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42972.4	99420.4	42972.4	99420.4	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94092.2	19.4	94092.2	19.4	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1982.6	0.2	1991.6	0.2	65.45	0.00	-10,473	0	-10,473
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-10,467


(Sd/-) M. A. Ahsan / Sd/- M. A. Ahsan
Director / Director
Ministry of Power / Min. of Power
Government of India / Govt. of India
Shillong / Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94164.1	80889	94164.1	80887.7	0.00	-0.94	0	150	150
	132kV KHLRT S-PG II	NP-6880-A	ME-09	206.4	21062.9	206.4	21068.5	0.00	4.03	0	645	645
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90017.8	85966.1	90017.8	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84247.8	96033.4	84247.8	96033.4	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	59235.8	99953.8	58331.6	99953.8	-3,288.00	0.00	-526,080	0	-526,080
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13736.8	99864	13827	99864	328.00	0.00	52,480	0	52,480
TOTAL												-472,805
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	361.9	3280.8	361.3	3407.7	-0.22	45.68	35	7,309	7,344
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73390.2	51441.9	73380.1	51428.5	-3.64	-4.82	582	-772	-190
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												7,154
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16451.6	9338.5	16451.6	9382.4	0.00	42.14	0	6,743	6,743
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72973	4275.2	72973	4353.2	0.00	56.16	0	8,986	8,986
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7696.3	98309.3	7696.3	98305.2	0.00	-1.48	0	-236	-236
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	497.9	44549.1	501.7	0.00	1.37	0	-219	-219
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	500.8	43962.3	505.1	0.00	1.55	0	-248	-248
TOTAL												15,026
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.6	97103.3	84658.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8944.2	6225	8944.1	6225	-0.10	0.00	-15	0	-15
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48794.6	93755	48794.6	93754.9	0.00	-0.10	0	15	15
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68775.6	72313.3	68775.6	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10231.4	99994.9	10231.4	99994.9	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4465.2	99999.7	4465.2	99999.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1155	99997.2	1155	99997.2	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन एम. आइमल/S.M. Aimal)
 निदेशक/Director
 उ.पू.के. वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 9/26/2022 to 10/2/2022

									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0	
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	93595.2	99822.7	93595.2	99822.7	0	0	0	0		0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0	0
			NP-8491-A	ME-05	94474.5	99797	94474.5	99797	0	0	0	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92421.9	1085.2	92421.9	1085.2	0	0	0	0	0	0
			NP-8384-A	ME-01	94276.8	61936.8	94276.8	61890.1	0	-22.416	0	3,587		
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	85974.8	6267.1	85956.9	6271.6	-8.592	2.16	-1,375	-346		-415
			NP-9071-A	ME-16	85232.1	23444.3	85233	23389.4	0.432	-26.352	69	4,216		
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82019.4	302.8	81989.7	307	-10.692	1.512	-1,711	-242		-242
			NP-9945-A	ME-17	666	95959.2	663.4	95844.9	-0.936	-41.148	-150	6,584		
TOTAL													-657	
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15590.8	99654.8	15590.8	99654.8	0	0	0	0	0	
			NP-6892-B	TR-06	76269	72994.9	76269	72961.8	0	-15.888	0	2,542		
TOTAL													0	
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92844.4	99289	92844.4	99288.9	0	-0.048	0	8	0	
			NP-9947-A	NG-02	47.6	99719.2	38.6	99712.4	-4.32	-3.264	-691	522		
TOTAL													0	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उपकुलेश्वर/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 10/3/2022 to 10/9/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	25,307
ASSAM	0	125,076
MANIPUR	0	14,876
MEGHALAYA	0	682,250
MIZORAM	3,992	0
NAGALAND	0	943
TRIPURA	0	783

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	1,315
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	1,021
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एसएम आइमोल/S.M.Aimol)
 निदेशक/Director
 ऊर्जा क्षेत्र/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 10/3/2022 to 10/9/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	25061.7	43.6	25097.8	43.6	6.50	0.00	1,040	0	1,040
	132kV Khupi-Balipara	NP-9606-A	AS-55	37518.3	79.9	37257.9	79.9	-93.74	0.00	14,999	0	14,999
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1129.2	26078.3	1129.2	26078.3	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6277.6	458.8	6279.4	0.00	0.65	0	104	104
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6008	546.2	6009.6	0.00	0.58	0	92	92
	132kV Tenga-Balipara	NP-9696-A	AR-17	51544.7	6.3	51189.5	6.3	-255.74	0.00	-40,919	0	-40,919
	132kV Lekhi-Pare	NP-9607-A	PA-01	54844.6	206.3	54851.5	206.3	3.31	0.00	-530	0	-530
	132kV Chimpu-Pare	NP-9411-A	PA-05	2132.8	99991.6	2134	99991.6	0.58	0.00	-92	0	-92
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	589.6	99934.6	589.6	99934.6	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	244.8	99936.3	244.8	99936.3	0.00	0.00	0	0	0
TOTAL												-25,307

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	13264.1	6862.6	13597.9	6862.6	534.08	0.00	-85,453	0	-85,453
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86093.8	98614.5	86108.2	98614.5	14.40	0.00	2,304	0	2,304
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	95402.5	99217.7	95439.4	99217.7	36.90	0.00	5,904	0	5,904
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	36383.8	64	36390.7	64	11.04	0.00	-1,766	0	-1,766
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	14010.1	79846.2	13962.8	79846.2	-34.06	0.00	-5,449	0	-5,449
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5702.5	19.8	5721.1	19.8	13.39	0.00	-2,143	0	-2,143
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	83165.8	99490	83038.4	0.00	-45.86	0	7,338	7,338
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21865.3	3260.4	21871.2	3260.4	1.06	0.00	-170	0	-170
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78706.3	91177.4	78679.6	91177.4	-9.61	0.00	-1,538	0	-1,538
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83406.6	99934.6	83381	99934.6	-9.22	0.00	-1,475	0	-1,475
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83867.5	99980.4	83816.3	99980.4	-18.43	0.00	-2,949	0	-2,949
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75007.3	99985.7	74943.6	99985.7	-22.93	0.00	-3,669	0	-3,669
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.5	1489.3	29692.8	1489.3	1.25	0.00	-200	0	-200
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98387.7	99796.4	98308	99796.4	-579.64	0.00	-92,742	0	-92,742
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	489.7	97922.6	512.2	97922.6	163.64	0.00	26,182	0	26,182
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85928.1	92918.3	86009.2	92931	29.20	4.57	4,671	-732	3,940
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95668.4	98995.7	95644.5	98995.7	-17.21	0.00	-2,753	0	-2,753
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5258.9	4444.2	5198.9	0.50	-43.20	81	6,912	6,993
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73790.4	98892.2	73956.4	98892.2	79.68	0.00	12,749	0	12,749
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	85735.6	99561.4	85546	99561.4	-91.01	0.00	-14,561	0	-14,561
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15385.6	73961.2	15385.6	73834.9	0.00	-45.47	0	7,275	7,275
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50019.2	69249.1	50019.2	69102.6	0.00	-52.74	0	8,438	8,438
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94175.1	99951	94169.9	99951	-18.91	0.00	3,025	0	3,025
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93698.5	2.1	93688.8	2.1	-35.27	0.00	5,644	0	5,644
TOTAL												-125,076

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96467.1	99123.5	96470.1	99123.5	2.16	0.00	346	0	346
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	526.3	99940.1	530.3	99940.1	1.92	0.00	307	0	307
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98370.6	99869.4	98370.2	99869.4	-0.14	0.00	23	0	23
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21758.6	384.5	21766	384.5	2.66	0.00	-426	0	-426
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19261.3	383.9	19268.2	383.9	2.48	0.00	-397	0	-397
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42972.4	99420.4	42949.6	99420.4	-8.21	0.00	1,313	0	1,313
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94092.2	19.4	94087	19.4	-3.74	0.00	599	0	599
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1993	0.2	2007.3	0.2	104.00	0.00	-16,640	0	-16,640
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-14,876


 (S.M. Aimon) / S.M. Aimon
 निदेशक/Director
 उ.पु.से.वि.म./Min. of Power
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94164.1	80887.7	94141.3	80887.7	-16.42	0.00	-2,627	0	-2,627
	132kV KHLRT S-PG II	NP-6880-A	ME-09	206.4	21068.5	207.4	21068.9	0.72	0.29	-115	46	-69
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90015.6	85966.1	89996.5	85966.1	-30.56	0.00	4,890	0	4,890
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84245.4	96033.4	84225.6	96033.4	-31.68	0.00	5,069	0	5,069
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	58191.2	99953.8	56738	99953.8	-5,284.36	0.00	-845,498	0	-845,498
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13821.4	99864	14089.5	99864	974.91	0.00	155,985	0	155,985
TOTAL												-682,250
MIZORAM	132kV LAUNGMAU-AIZWAL PG	NP-9495-A	MZ-02	361.3	3407.7	362.5	3428.9	0.43	7.63	-69	1,221	1,152
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73380.1	51428.5	73339	51436.7	-14.80	2.95	2,367	472	2,840
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												3,992
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16451.6	9382.4	16456.9	9384.6	5.09	2.11	-814	338	-476
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72973	4353.2	72983.5	4356.4	7.56	2.30	-1,210	369	-841
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7696.3	98305.2	7692.3	98305.1	-1.44	-0.04	230	-6	225
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	501.7	44550.5	501.7	0.50	0.00	81	0	81
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	505.1	43963.5	505.1	0.43	0.00	69	0	69
TOTAL												-943
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.6	97103.3	84658.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt I	NP-6850-A	TR-01	8934.1	6225	8934.1	6225	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt II	NP-6851-A	TR-02	48789.7	93754.9	48789.7	93754.9	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68775.6	72313.3	68775.6	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10231.4	99994.9	10234.2	99994.9	2.69	0.00	-430	0	-430
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4465.2	99999.7	4467.5	99999.7	2.21	0.00	-353	0	-353
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1155	99997.2	1155	99997.2	0.00	0.00	0	0	0
TOTAL												-783

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 अ.पु.रे.वि.म./NERPC
 बिजुत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 10/3/2022 to 10/9/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93594.8	99822.7	93584.2	99822.7	-5.088	0	-814	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94474	99797	94463.4	99797	-5.088	0	-814	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92420.6	1085.2	92347.4	1085.2	-35.136	0	-5,622	0	-23
			NP-8384-A	ME-01	94276.8	61890.1	94277.1	61889.1	0.144	-0.48	23	77	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	85953.7	6271.6	85853.5	6272.5	-48.096	0.432	-7,695	-69	-1,229
			NP-9071-A	ME-16	85233.2	23389.4	85248.3	23373.2	7.248	-7.776	1,160	1,244	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	81983.6	307	81889.8	308.1	-33.768	0.396	-5,403	-63	-63
			NP-9945-A	ME-17	661.9	95844.9	651.9	95784.9	-3.6	-21.6	-576	3,456	
TOTAL													-1,315
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15590.8	99654.8	15627	99654.8	17.376	0	2,780	0	0
			NP-6892-B	TR-06	76269	72961.8	76269	72961.8	0	0	0	0	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92844.4	99288.9	92831.1	99288.9	-6.384	0	-1,021	0	-1,021
			NP-9947-A	NG-02	38.6	99712.4	52.5	99712.4	6.672	0	1,068	0	
TOTAL													-1,021

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. आइमोल/S.M. Aimol)
 निदेशक/Director
 उत्तु.रे.वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 10/10/2022 to 10/16/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	10,092
ASSAM	9,203	0
MANIPUR	0	59,748
MEGHALAYA	0	792,959
MIZORAM	7,505	0
NAGALAND	6,751	0
TRIPURA	0	0

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	4,712
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	3,195
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आनमोल/S.M. Anmol)
 निदेशक/Director
 उ.सू.के.वि.स./NERPC
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिमांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 10/10/2022 to 10/16/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	25097.8	43.6	25097.8	43.6	0.00	0.00	0	0	0
	132kV Khupi-Balipara	NP-9606-A	AS-55	37257.1	79.9	37223	79.9	-12.28	0.00	1,964	0	1,964
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1129.2	26078.3	1129.2	26078.3	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6279.4	458.8	6279.5	0.00	0.04	0	6	6
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	6009.6	546.2	6009.6	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	51164.6	6.3	51059.9	6.3	-75.38	0.00	-12,061	0	-12,061
	132kV Lekhi-Pare	NP-9607-A	PA-01	54851.5	206.3	54851.5	206.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	2134	99991.6	2134	99991.6	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	589.6	99934.6	589.6	99934.6	0.00	0.00	0	0	0
TOTAL												-10,092

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.5	80.3	-0.48	0.00	77	0	77
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	13667.7	6862.6	14116	6862.6	717.28	0.00	-114,765	0	-114,765
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	86108.2	98614.5	86108.2	98611.9	0.00	-2.60	0	416	416
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	95439.4	99217.7	95439.4	99216.4	0.00	-1.30	0	208	208
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	36390.7	64	36390	64	-1.12	0.00	179	0	179
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	13967.2	79846.2	13846.5	79846.2	-86.90	0.00	-13,905	0	-13,905
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5721.1	19.8	5739.4	19.8	13.18	0.00	-2,108	0	-2,108
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99490	83038.4	99490	83012	0.00	-9.50	0	1,521	1,521
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21871.2	3260.4	21872.7	3260.8	0.27	0.07	-43	12	-32
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78679.6	91177.4	78663.4	91177.4	-5.83	0.00	-933	0	-933
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83381	99934.6	83367.5	99934.6	-4.86	0.00	-778	0	-778
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	83816.3	99980.4	83784.1	99980.4	-11.59	0.00	-1,855	0	-1,855
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	74943.6	99985.7	74891.4	99985.7	-18.79	0.00	-3,007	0	-3,007
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29692.8	1489.3	29692.8	1519.1	0.00	28.61	0	4,577	4,577
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98308.3	99796.4	98292.4	99796.4	-115.64	0.00	-18,502	0	-18,502
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	535.7	97922.6	651.2	97922.6	840.00	0.00	134,400	0	134,400
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	86017.1	92931	86145.9	92938.7	46.37	2.77	7,419	-444	6,975
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95644.5	98995.7	95642.2	98995.6	-1.66	-0.07	-265	12	-253
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4444.2	5203.5	4444.2	5202.5	0.00	-0.72	0	115	115
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73977.9	98892.2	74064.1	98892.2	41.38	0.00	6,620	0	6,620
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	85517.7	99561.4	85392.5	99561.4	-60.10	0.00	-9,615	0	-9,615
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15385.6	73834.9	15385.6	73681	0.00	-55.40	0	8,865	8,865
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50019.2	69102.6	50019.2	68911.6	0.00	-68.76	0	11,002	11,002
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94169.9	99951	94169.9	99951	0.00	0.00	0	0	0
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93688.8	2.1	93688.8	2.1	0.00	0.00	0	0	0
TOTAL												9,203

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96470.1	99123.5	96468.8	99123.5	-0.94	0.00	-150	0	-150
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	530.3	99940.1	531.9	99940.1	0.77	0.00	123	0	123
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98370.2	99869.4	98373.6	99869.4	1.22	0.00	-196	0	-196
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21766	384.5	21783.7	384.5	6.37	0.00	-1,020	0	-1,020
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19268.2	383.9	19285.2	383.9	6.12	0.00	-979	0	-979
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42949.6	99420.4	42942.9	99420.4	-2.41	0.00	386	0	386
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94087	19.4	94078.6	19.4	-6.05	0.00	968	0	968
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2007.3	0.2	2057.9	0.2	368.00	0.00	-58,880	0	-58,880
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-59,748


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.म./NERPC
 बिजुल मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94141.3	80887.7	94119.5	80887.7	-15.70	0.00	-2,511	0	-2,511
	132kV KHLRT S-PG II	NP-6880-A	ME-09	207.4	21068.9	208.3	21070.4	0.65	1.08	-104	173	69
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89996.5	85966.1	89996.5	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84225.6	96033.3	84225.6	96033.3	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	56463.6	99953.8	54956.3	99953.8	-5,481.09	0.00	-876,975	0	-876,975
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	14130.6	99864	14279.2	99864	540.36	0.00	86,458	0	86,458
TOTAL												-792,959
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	362.5	3428.9	362.1	3469.3	-0.14	14.54	23	2,327	2,350
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73339	51436.7	73253.6	51440.8	-30.74	1.48	4,919	236	5,155
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												7,505
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16456.9	9384.6	16456.9	9404.1	0.00	18.72	0	2,995	2,995
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72983.5	4356.4	72983.5	4389.7	0.00	23.98	0	3,836	3,836
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7692.3	98305.1	7692.3	98302	0.00	-1.12	0	-179	-179
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44550.5	501.9	44550.5	501.2	0.00	-0.25	0	40	40
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43963.5	505.4	43963.5	504.4	0.00	-0.36	0	58	58
TOTAL												6,751
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.6	97103.3	84658.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8934.1	6225	8934.1	6225	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48789.7	93754.9	48789.7	93754.9	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68775.6	72313.3	68775.6	72313.3	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.7	26.2	14536.7	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10234.2	99994.9	10234.2	99994.9	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4467.5	99999.7	4467.5	99999.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1155	99997.2	1155	99997.2	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पु.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 10/10/2022 to 10/16/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93583.5	99822.7	93576.1	99822.7	-3.552	0	-568	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94462.6	99797	94455.3	99797	-3.504	0	-561	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92344.1	1085.2	92299.3	1085.1	-21.504	-0.048	-3,441	8	0
			NP-8384-A	ME-01	94277.1	61889.1	94277.1	61886.3	0	-1.344	0	215	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	85787.4	6272.5	85646.4	6285.2	-67.68	6.096	-10,829	-975	-3,410
			NP-9071-A	ME-16	85283.2	23373.2	85314.9	23325.3	15.216	-22.992	2,435	3,679	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	81804	308.1	81634.6	330.7	-60.984	8.136	-9,757	-1,302	-1,302
			NP-9945-A	ME-17	656	95784.9	624.3	95666	-11.412	-42.804	-1,826	6,849	
TOTAL													-4,712
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15627	99654.8	15628.9	99654.8	0.912	0	146	0	0
			NP-6892-B	TR-06	76269	72961.8	76269	72961.6	0	-0.096	0	15	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92831.1	99288.9	92789.5	99288.9	-19.968	0	-3,195	0	-3,195
			NP-9947-A	NG-02	52.5	99712.4	126.7	99712	35.616	-0.192	5,699	31	
TOTAL													-3,195

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Aimol)
 निदेशक/Director
 ऊ.पु.सि.स/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong