



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/ 552-574

Dt: 28th April, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 25.07.2022 to 21.08.2022 (4 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 25.07.2022 to 21.08.2022 (4 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16 Paise/KVARH w.e.f from 1st April 2022, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

**Reactive Energy (VArH) Charge Statement
for the period 7/25/2022 to 7/31/2022**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	63,138
ASSAM	0	141,473
MANIPUR	0	45,711
MEGHALAYA	0	803,672
MIZORAM	1,048	0
NAGALAND	4,746	0
TRIPURA	0	3,932

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	1,778
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M. Aimal)
 निदेशक/Director
 उत्तर क्षेत्रीय/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 7/25/2022 to 7/31/2022

								Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	24132.2	44	24133.5	44	1.13	0.00	181	0	181
	132kV Khupi-Balipara	NP-9606-A	AS-55	47560.6	79.9	46481	79.9	-519.73	0.00	83,157	0	83,157
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1128.1	26078.1	1128.1	26078.1	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6154.4	458.8	6154.4	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	5891.6	546.2	5891.6	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	60221.8	6.3	59156.9	6.3	-914.33	0.00	-146,292	0	-146,292
	132kV Lekhi-Pare	NP-9607-A	PA-01	54629.4	206.3	54629.4	206.3	1.15	0.00	-184	0	-184
	132kV Chimpu-Pare	NP-9411-A	PA-05	2103.9	99991.5	2103.9	99991.5	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.7	99934.6	585.7	99934.6	0.00	0.00	0	0	0
132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	243.7	99936.3	243.7	99936.3	0.00	0.00	0	0	0	
TOTAL												-63,138

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.7	80.2	49089.7	80.3	0.16	0.16	-26	26	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	10709.8	6862.6	11043.3	6862.6	722.88	0.00	-115,661	0	-115,661
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85786.6	98616.4	85818.5	98616.4	56.80	0.00	9,088	0	9,088
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	94739.3	99217.7	94831.6	99217.7	135.50	0.00	21,680	0	21,680
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	33540.7	63.9	33848	63.9	707.20	0.00	-113,152	0	-113,152
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	14729.7	79846.3	14694.8	79846.3	-81.00	0.00	-12,960	0	-12,960
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5600.7	17.8	5600.7	17.8	4.10	0.00	-657	0	-657
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99426.5	85414.4	99426.5	85338	0.00	-36.32	0	5,812	5,812
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21835.6	3255.5	21844.9	3255.5	2.20	0.00	-351	0	-351
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78860.2	91177.6	78854.5	91177.6	-14.40	0.00	-2,304	0	-2,304
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83548.5	99934.7	83543.6	99934.7	-14.04	0.00	-2,246	0	-2,246
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84214.6	99980.6	84195.9	99980.6	-23.90	0.00	-3,825	0	-3,825
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75596.2	99985.9	75570.7	99985.9	-31.03	0.00	-4,965	0	-4,965
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1374.1	29691.4	1374.1	0.00	0.00	0	0	0
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98410.2	99796.5	98410.2	99796.5	-58.91	0.00	-9,425	0	-9,425
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	512.6	97928.3	512.2	97928.3	-80.73	0.00	-12,916	0	-12,916
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85000.9	92636.4	85207.7	92615.3	107.78	-7.60	17,245	1,215	18,461
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95757.4	99006.2	95757.4	99006.2	-13.54	0.00	-2,166	0	-2,166
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.1	5131.6	4443.1	5131.6	0.29	0.00	46	0	46
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	72520.2	98891.5	72809.5	98891.5	176.45	0.00	28,232	0	28,232
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	87106.5	99563.9	86828.7	99563.9	-176.69	0.00	-28,270	0	-28,270
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	80662.9	15357.7	80028.5	0.00	-228.38	0	36,541	36,541
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	76516.9	50000.2	75830.5	0.00	-247.10	0	39,537	39,537
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94350.4	99951	94350.4	99951	-6.18	0.00	989	0	989
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94065.5	2.1	94064.7	2.1	-44.00	0.00	7,040	0	7,040
TOTAL												-141,473

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96470.6	99123.6	96470.6	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.1	99940.1	516.1	99940.1	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kv JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98369.7	99869.2	98383.4	99869.2	6.41	0.00	-1,025	0	-1,025
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21693.9	384.4	21695.9	384.4	3.74	0.00	-599	0	-599
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19201.7	383.9	19203.8	383.9	3.71	0.00	-593	0	-593
	132kv NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42994.5	99420.4	42994	99420.4	2.02	0.00	-323	0	-323
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94099.1	19.4	94099.3	19.4	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1711.9	0.2	1726.3	0.2	269.82	0.00	-43,171	0	-43,171
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-45,711


 (एसएम आइमल/S.M.Aimal)
 निदेशक/Director
 नए नु के सिन/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

								Actual*CT*PT		Amount in Rs.		
	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG II	NP-6880-A	ME-09	138.7	21047.7	162.3	21047.7	39.82	0.00	-6,371	0	-6,371
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90029.9	85966.1	90029.9	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84319.4	96033.4	84319.4	96033.4	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	69643.9	99953.8	68433.4	99953.8	-5,168.73	0.00	-826,996	0	-826,996
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13435.2	99864	13504.6	99864	285.82	0.00	45,731	0	45,731
TOTAL												-803,672
MIZORAM	132kV LAUNGMAIAL-AIZWAL PG	NP-9495-A	MZ-02	352.8	2682.2	352.8	2699.4	0.00	6.19	0	991	991
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73489.5	51437.8	73489.5	51438.8	0.00	0.36	0	58	58
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												1,048
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	9000.5	16450.9	9007.7	0.00	6.91	0	1,106	1,106
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3666.6	72971.3	3679.5	0.00	9.29	0	1,486	1,486
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98417.5	7694.8	98416.3	0.00	-0.43	0	-69	-69
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542.3	44549.1	523.1	0.00	-6.91	0	1,106	1,106
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	547.1	43962.3	527.7	0.00	-6.98	0	1,117	1,117
TOTAL												4,746
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.7	97103.3	84658.7	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8975.8	99634.8	8975.8	99634.8	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48798.7	93755	48798.7	93755	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68769.6	72313.4	68769.6	72313.4	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7280.4	99970.6	7280.4	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14533.1	26.2	14533.1	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10167.2	99994.8	10167.2	99994.8	17.47	0.00	-2,796	0	-2,796
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4433.6	99999.7	4433.6	99999.7	7.10	0.00	-1,137	0	-1,137
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1154.7	99997.2	1154.7	99997.2	0.00	0.00	0	0	0
TOTAL												-3,932

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन एम. आइमोल/S.M. Aimol)
 निदेशक/Director
 उद्देशी विद्युत/NERPC
 बिजुत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 7/25/2022 to 7/31/2022

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93628.3	99820.9	93628	99820.9	-1.536	0	-246	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94507.9	99795.4	94507.6	99795.4	-1.536	0	-246	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92539.7	1085.2	92545.7	1085.2	22.848	0	3,656	0	0
			NP-8384-A	ME-01	94241.6	62116.6	94241.6	62109.9	0	-37.632	0	6,021	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86011.8	5992.6	86025.8	6038.7	10.272	22.512	1,644	-3,602	-1,644
			NP-9071-A	ME-16	85270.5	24599.8	85269.1	24450.1	-20.88	-84.432	-3,341	13,509	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82114.6	99996.1	82116.3	53.7	-1.368	21.384	-219	-3,421	3,421
TOTAL			NP-9945-A	ME-17	817.1	98071.9	812.4	97828.7	-55.632	-135.984	-8,901	21,757	1,778
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15433.7	99655.1	15435.4	99655.1	13.968	0	2,235	0	0
TOTAL			NP-6892-B	TR-06	76269	77244.2	76269	76882.5	0	-39.7056	0	6,353	0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92846.8	99304.3	92846.8	99304.3	0	0	0	0	0
TOTAL			NP-9947-A	NG-02	49	99750.6	49	99750.6	0	0	0	0	0

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उच्च वोल्टेज/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 8/1/2022 to 8/7/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	76,022
ASSAM	0	62,440
MANIPUR	0	23,670
MEGHALAYA	0	704,449
MIZORAM	3,444	0
NAGALAND	276	0
TRIPURA	0	0

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	184
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम.आइमोल/S.M.Aimol)
 निदेशक/Director
 उत्प्रेक्षित/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 8/1/2022 to 8/7/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	24138.5	44	24138.5	44	-2.23	0.00	-357	0	-357
	132kV Khupi-Balipara	NP-9606-A	AS-55	46116.9	79.9	45098.3	79.9	-464.22	0.00	74,275	0	74,275
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1128.1	26078.1	1128.1	26078.1	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6154.4	458.8	6154.4	0.00	0.00	0	0	0
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	5891.6	546.2	5891.6	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	58951.9	6.3	57819.8	6.3	-936.36	0.00	-149,818	0	-149,818
	132kV Lekhi-Pare	NP-9607-A	PA-01	54631.8	206.3	54631.8	206.3	0.77	0.00	-123	0	-123
	132kV Chimpu-Pare	NP-9411-A	PA-05	2103.9	99991.5	2103.9	99991.5	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.7	99934.6	585.7	99934.6	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	243.7	99936.3	243.7	99936.3	0.00	0.00	0	0	0
TOTAL												-76,022

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	11161.6	6862.6	11473.5	6862.6	603.84	0.00	-96,614	0	-96,614
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85843.4	98616.4	85843.4	98616.4	22.70	0.00	3,632	0	3,632
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	94874.8	99217.7	94875.6	99217.7	42.60	0.00	6,816	0	6,816
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	33982.7	63.9	34309.7	63.9	861.60	0.00	-137,856	0	-137,856
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	14617.2	79846.3	14603.4	79846.3	-25.85	0.00	-4,136	0	-4,136
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5606.4	17.8	5606.4	17.8	0.36	0.00	-58	0	-58
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99426.5	85313.5	99426.5	85128.3	0.00	-99.32	0	15,892	15,892
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21847.8	3255.5	21854.1	3255.5	1.37	0.00	-219	0	-219
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78820.2	91177.6	78820.2	91177.6	0.00	0.00	0	0	0
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83509.5	99934.7	83509.5	99934.7	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84148.2	99980.6	84148.2	99980.5	-3.13	-0.04	-501	6	-495
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75510	99985.9	75510	99985.9	-10.26	0.00	-1,642	0	-1,642
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1374.1	29691.4	1374.1	0.00	0.00	0	0	0
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98402.1	99796.5	98402.1	99796.5	-10.18	0.00	-1,629	0	-1,629
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	501.5	97928.3	501.5	97928.3	-22.55	0.00	-3,607	0	-3,607
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85300.3	92615.3	85396.8	92641.4	35.06	11.09	5,610	-1,774	3,836
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95738.6	99006.2	95738.6	99006.2	0.00	0.00	0	0	0
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5131.6	4443.5	5124.3	0.00	-5.26	0	841	841
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	72887.8	98891.5	73151.4	98891.5	141.36	0.00	22,618	0	22,618
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	86738.4	99563.9	86463.3	99563.9	-149.86	0.00	-23,977	0	-23,977
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	80028.5	15357.7	79559	0.00	-224.78	0	35,965	35,965
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	75830.5	50000.2	75316.4	0.00	-246.71	0	39,473	39,473
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94348.7	99951	94329.9	99951	-208.36	0.00	33,338	0	33,338
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94053.4	2.1	94016.9	2.1	-283.64	0.00	45,382	0	45,382
TOTAL												-62,440

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96470.6	99123.6	96470.6	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.1	99940.1	516.1	99940.1	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98387.5	99869.2	98387.5	99869.2	-1.15	0.00	184	0	184
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21704.3	384.4	21704.3	384.4	0.00	0.00	0	0	0
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19212	383.9	19212	383.9	0.00	0.00	0	0	0
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	43000.1	99420.4	43000.1	99420.4	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94099.1	19.4	94099.1	19.4	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1749	0.2	1749.2	0.2	149.09	0.00	-23,855	0	-23,855
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-23,670


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उद्गुले वि.स/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94361.4	80889.9	94279.1	80889.9	-62.64	0.00	-10,022	0	-10,022
	132kV KHLRT S-PG II	NP-6880-A	ME-09	194	21047.7	199	21047.7	3.60	0.00	-576	0	-576
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90029.9	85966.1	90029.9	85966.1	-1.92	0.00	307	0	307
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84319.4	96033.4	84319.4	96033.4	-2.24	0.00	358	0	358
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	68222.5	99953.8	67155.5	99953.8	-4,389.09	0.00	-702,255	0	-702,255
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13513.8	99864	13533.4	99864	48.36	0.00	7,738	0	7,738
TOTAL												-704,449
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	352.8	2699.4	352.8	2761.1	0.00	22.21	0	3,554	3,554
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73489.5	51438.8	73489.5	51436.9	0.00	-0.68	0	-109	-109
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												3,444
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	9007.7	16450.9	9008.3	0.00	0.58	0	92	92
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3679.5	72971.3	3681.1	0.00	1.15	0	184	184
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98416.3	7694.8	98416.2	0.00	-0.04	0	-6	-6
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	523.1	44549.1	523.1	0.00	0.00	0	0	0
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	527.7	43962.3	527.6	0.00	-0.04	0	6	6
TOTAL												276
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.7	97103.3	84658.7	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt I	NP-6850-A	TR-01	8975.9	6225.1	8975.9	6225.1	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt II	NP-6851-A	TR-02	48798.7	93755	48798.7	93755	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68769.6	72313.4	68769.6	72313.4	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7280.4	99970.6	7280.4	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14533.1	26.2	14533.1	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10185.4	99994.8	10185.4	99994.8	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4441	99999.7	4441	99999.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1154.7	99997.2	1154.7	99997.2	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पु.रे.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 8/1/2022 to 8/7/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93625.1	99820.9	93625.1	99820.9	-0.192	0	-31	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94504.7	99795.4	94504.7	99795.4	-0.24	0	-38	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92587.3	1085.2	92588.5	1085.2	-1.248	0	-200	0	0
			NP-8384-A	ME-01	94241.6	62038.2	94241.6	61996.5	0	-20.016	0	3,203	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86033.2	6039.5	86033.2	6121.6	1.008	46.848	161	-7,496	-161
			NP-9071-A	ME-16	85227	24423.9	85227	24171.6	0	-133.584	0	21,373	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82110.8	55.5	82110.8	169.1	0.144	43.92	23	-7,027	-23
			NP-9945-A	ME-17	701.2	97788.6	700.7	97425.5	-0.24	-192.816	-38	30,851	
TOTAL													-184
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15462.8	99655.1	15462.9	99655.1	0.048	0	8	0	0
			NP-6892-B	TR-06	76269	76830.6	76269	75993.8	0	-102.3552	0	16,377	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	0	0	0	0	0	0	0	0	0
			NP-9947-A	NG-02	49	99750.6	49	99750.6	0	0	0	0	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पू.वि.वि./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 8/8/2022 to 8/14/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	58,023
ASSAM	40,514	0
MANIPUR	0	72,434
MEGHALAYA	0	756,452
MIZORAM	3,220	0
NAGALAND	7,346	0
TRIPURA	0	11,432

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	407
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक / Director
 उ.पु.के.वि.मि./NERPC
 विद्युत मंत्रालय /Min. of Power
 भारत सरकार /Govt. of India
 शिलांग/Shillong


DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 8/8/2022 to 8/14/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	24126.1	44	24252.2	44	22.70	0.00	3,632	0	3,632
	132kV Khupi-Balipara	NP-9606-A	AS-55	44827.4	79.9	43666.2	79.9	-475.09	0.00	76,015	0	76,015
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1128.1	26078.1	1126.3	26078.1	-1.30	0.00	-207	0	-207
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6154.4	458.8	6154.8	0.00	0.18	0	29	29
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	5891.6	546.2	5891.9	0.00	0.14	0	23	23
	132kV Tenga-Balipara	NP-9696-A	AR-17	57651.4	6.3	56630	6.3	-860.76	0.00	-137,722	0	-137,722
	132kV Lekhi-Pare	NP-9607-A	PA-01	54633.4	206.3	54629.9	206.3	-1.68	0.00	269	0	269
	132kV Chimpu-Pare	NP-9411-A	PA-05	2103.9	99991.5	2103.3	99991.5	-0.29	0.00	46	0	46
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.7	99934.6	585.4	99934.6	-0.29	0.00	-46	0	-46
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	243.7	99936.3	243.3	99936.3	-0.38	0.00	-61	0	-61
TOTAL												-58,023

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	11539	6862.6	11827.4	6862.6	609.76	0.00	-97,562	0	-97,562
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85866.1	98616.4	85967.7	98616.4	101.60	0.00	16,256	0	16,256
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	94917.4	99217.7	95039.1	99217.7	121.70	0.00	19,472	0	19,472
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	34521.2	63.9	34752.4	63.9	383.68	0.00	-61,389	0	-61,389
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	14581.3	79846.3	14541.8	79846.3	-28.44	0.00	-4,550	0	-4,550
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5606.9	17.8	5616.9	17.8	7.20	0.00	-1,152	0	-1,152
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99426.5	85037.6	99507.7	84593.2	29.23	-167.40	4,677	26,784	31,461
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21855.4	3255.5	21858.3	3255.5	0.52	0.00	-84	0	-84
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78820.2	91177.6	78809.3	91177.6	-3.92	-0.04	-628	6	-622
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83509.5	99934.7	83499.4	99934.7	-3.64	0.00	-582	0	-582
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84139.5	99980.5	84091.1	99980.5	-17.42	0.00	-2,788	0	-2,788
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75481.5	99985.9	75408.2	99985.8	-26.39	-0.04	-4,222	6	-4,216
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1374.1	29691.4	1378.4	0.00	4.13	0	660	660
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98400.7	99796.5	98400.7	99796.5	0.00	0.00	0	0	0
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	498.4	97928.3	498.4	97928.3	0.00	0.00	0	0	0
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85397.7	92646.1	85476.2	92653.9	28.26	2.84	4,522	-455	4,067
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95738.6	99006.2	95734.5	99006.2	-2.95	0.00	-472	0	-472
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5124.3	4443.5	5124.3	0.00	0.00	0	0	0
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73182.3	98891.5	73276.1	98891.5	57.36	0.00	9,178	0	9,178
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	86426.2	99563.9	86349.5	99563.9	-48.86	0.00	-7,818	0	-7,818
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	79404.1	15369.8	78781	4.36	-234.04	697	37,446	38,143
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	75145.2	50008.4	74468.9	2.95	-255.20	472	40,833	41,305
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94291.4	99951	94247.4	99951	-160.00	0.00	25,600	0	25,600
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93975.4	2.1	93916.2	2.1	-222.55	0.00	35,607	0	35,607
TOTAL												40,514

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96470.6	99123.6	96470.3	99123.6	-0.22	0.00	-35	0	-35
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.1	99940.1	516.6	99940.1	0.24	0.00	38	0	38
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98384.3	99869.2	98401.2	99869.2	6.08	0.00	-973	0	-973
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21704.3	384.4	21713	384.4	3.13	0.00	-501	0	-501
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19212	383.9	19220.6	383.9	3.10	0.00	-495	0	-495
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	43000.1	99420.4	43004.5	99420.4	1.58	0.00	-253	0	-253
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94099.1	19.4	94098.5	19.4	-0.43	0.00	69	0	69
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1769.5	0.2	1826.7	0.2	439.27	0.00	-70,284	0	-70,284
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-72,434


 (एस एम आइमल/S.M.Aimal)
 निदेशक/Director
 उद्गुल्लेखित/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94274.4	80889.9	94265.3	80889.9	-6.55	0.00	-1,048	0	-1,048
	132kV KHLRT S-PG II	NP-6880-A	ME-09	199	21047.7	200.2	21047.7	0.86	0.00	-138	0	-138
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90028.7	85966.1	90025.3	85966.1	-5.44	0.00	870	0	870
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84318	96033.4	84296.2	96033.4	-34.88	0.00	5,581	0	5,581
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	67015.5	99953.8	65987.8	99953.8	-4,606.18	0.00	-736,989	0	-736,989
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13527.1	99864	13470.7	99864	-154.55	0.00	-24,727	0	-24,727
TOTAL												-756,452
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	352.8	2761.1	352.8	2819.8	0.00	21.13	0	3,381	3,381
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73489.5	51436.9	73489.5	51434.1	0.00	-1.01	0	-161	-161
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												3,220
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	9008.3	16450.9	9024.4	0.00	15.46	0	2,473	2,473
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3681.1	72971.3	3712.3	0.00	22.46	0	3,594	3,594
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98416.2	7694.8	98413.8	0.00	-0.86	0	-138	-138
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	523.1	44549.1	511.2	0.00	-4.28	0	685	685
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	527.6	43962.3	514.9	0.00	-4.57	0	732	732
TOTAL												7,346
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.7	97103.3	84658.7	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt I	NP-6850-A	TR-01	8975.9	6225.1	8968	6225.1	-7.58	0.00	-1,213	0	-1,213
	132kV Agartala-AGTTP Ckt II	NP-6851-A	TR-02	48798.7	93755	48798.7	93755	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68769.6	72313.4	68772.7	72313.4	3.72	0.00	595	0	595
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7280.4	99970.6	7289.5	99970.6	8.74	0.00	-1,398	0	-1,398
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14533.1	26.2	14536.8	26.2	3.55	0.00	-568	0	-568
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10185.4	99994.8	10222.9	99994.8	36.00	0.00	-5,760	0	-5,760
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4441	99999.7	4461.4	99999.7	19.58	0.00	-3,133	0	-3,133
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1154.7	99997.2	1155	99997.2	0.29	0.00	46	0	46
TOTAL												-11,432

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (ए.एम.आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पू.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 8/8/2022 to 8/14/2022

									Actual*CT*PT		Amount in Rs.			
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0	
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0	
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0		0
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0	
			NP-8473-A	ME-07	93624.7	99820.9	93620.1	99820.9	-2.208	0	-353	0		0
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0	0
			NP-8491-A	ME-05	94504.2	99795.4	94499.5	99795.4	-2.256	0	-361	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92584.7	1085.2	92563.3	1085.2	-10.272	0	-1,644	0	0	-46
			NP-8384-A	ME-01	94241.6	61996.5	94242.2	61996.5	0.288	0	46	0	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86035.3	6137.1	86038.5	6166	2.112	13.872	338	-2,220	0	-338
			NP-9071-A	ME-16	85227	24145.6	85222.4	24044.3	-2.448	-48.624	-392	7,780	0	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82111.2	177.5	82111.9	201.8	0.144	8.748	23	-1,400	0	-23
			NP-9945-A	ME-17	700.7	97386.9	691	97223.2	-4.656	-78.576	-745	12,572	0	
TOTAL													-407	
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15462.9	99655.1	15470.4	99655.1	3.6	0	576	0	0	
TOTAL			NP-6892-B	TR-06	76269	75764.4	76269	75276	0	-51.7824	0	8,285	0	
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92846.8	99304.3	92846.7	99304.3	-0.048	0	-8	0	0	
TOTAL			NP-9947-A	NG-02	49	99750.6	49	99747.6	0	-1.44	0	230	0	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एच.एस.आइमोल/S. M. Aimol)
 निदेशक/Director
 उ.पु.के.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 8/15/2022 to 8/21/2022**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	39,865
ASSAM	79,837	0
MANIPUR	0	38,000
MEGHALAYA	0	645,854
MIZORAM	1,809	0
NAGALAND	21,007	0
TRIPURA	0	0

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	165
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.के.पि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 8/15/2022 to 8/21/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	24252.2	44	24506.8	44	60.41	0.00	9,665	0	9,665
	132kV Khupi-Balipara	NP-9606-A	AS-55	43507.7	79.9	42474.8	79.9	-443.95	0.00	71,032	0	71,032
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1126.3	26078.1	1127.2	26078.1	0.65	0.00	104	0	104
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	6154.9	458.8	6201.9	0.00	16.92	0	2,707	2,707
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	5892	546.2	5936.1	0.00	15.88	0	2,540	2,540
	132kV Tenga-Balipara	NP-9696-A	AR-17	56455.9	6.3	55604.6	6.3	-731.38	0.00	-117,020	0	-117,020
	132kV Lekhi-Pare	NP-9607-A	PA-01	54629.9	206.3	54733	206.3	50.16	0.00	-8,026	0	-8,026
	132kV Chimpu-Pare	NP-9411-A	PA-05	2103.3	99991.5	2115.9	99991.5	6.05	0.05	-968	8	-960
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.4	99934.6	586.1	99934.6	0.67	0.00	108	0	108
TOTAL												-39,865

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49089.8	80.3	49089.8	80.3	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	11920.1	6862.6	12156.9	6862.6	427.52	0.00	-68,403	0	-68,403
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85967.7	98616.4	85967.8	98616.4	0.10	0.00	16	0	16
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	95039.1	99217.7	95063.3	99217.7	24.20	0.00	3,872	0	3,872
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	34761	63.9	34923.8	63.9	331.36	0.00	-53,018	0	-53,018
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	14541.8	79846.3	14485.6	79846.3	-40.46	0.00	-6,474	0	-6,474
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5616.9	17.8	5618.9	17.8	1.44	0.00	-230	0	-230
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99507.7	84572.6	99490.1	84111.5	-6.34	-182.05	-1,014	29,128	28,115
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21858.3	3255.5	21858.3	3257.6	0.00	0.38	0	60	60
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	78809.3	91177.5	78809.3	91177.5	0.00	0.00	0	0	0
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83499.4	99934.7	83499.4	99934.7	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84091.1	99980.5	84072.5	99980.5	-6.70	0.00	-1,071	0	-1,071
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	75408.2	99985.8	75350.5	99985.8	-20.77	0.00	-3,324	0	-3,324
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1378.4	29691.4	1394.8	0.00	15.74	0	2,519	2,519
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98400.7	99796.5	98400.7	99796.5	0.00	0.00	0	0	0
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	498.4	97928.3	496.6	97928.3	-13.09	0.00	-2,095	0	-2,095
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	85476.2	92654	85523.8	92725.3	60.41	29.88	9,665	-4,781	4,884
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95734.5	99006.2	95734.5	99006.2	0.00	0.00	0	0	0
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4443.5	5124.3	4443.5	5135	0.00	0.29	0	-46	-46
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	73301.8	98891.5	73352	98891.5	24.10	0.00	3,855	0	3,855
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	86324.4	99563.9	86288.6	99562.9	-17.18	-0.48	-2,749	77	-2,673
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15369.8	78754	15385.6	78123.3	5.69	-285.59	910	45,694	46,604
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50008.4	74436.3	50019.2	73732.7	3.89	-315.76	622	50,521	51,143
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94247.4	99951	94208.9	99951	-140.00	0.00	22,400	0	22,400
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	93914.2	2.1	93824	2.1	-335.64	0.00	53,702	0	53,702
TOTAL												79,837

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96470.3	99123.6	96470.3	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.6	99940.1	516.6	99940.1	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98401.2	99869.2	98419.8	99869.2	6.70	0.00	-1,071	0	-1,071
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21713	384.4	21717.8	384.4	1.73	0.00	-276	0	-276
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19220.6	383.9	19224.9	383.9	1.55	0.00	-248	0	-248
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	43004.5	99420.4	43005.2	99420.4	0.25	0.00	-40	0	-40
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94098.5	19.4	94098	19.4	-0.36	0.00	58	0	58
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1829.9	0.2	1861.2	0.2	227.64	0.00	-36,422	0	-36,422
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-38,000

(Signature)
S. M. Aimal
Director
उप निदेशक / NERPC
विद्युत मंत्रालय / Min. of Power
भारत सरकार / Govt. of India
शिलांग / Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	94265.3	80889.9	94265.3	80889	0.00	-0.65	0	104	104
	132kV KHLRT S-PG II	NP-6880-A	ME-09	200.2	21047.7	200.2	21057.6	0.00	7.13	0	1,140	1,140
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90025.3	85966.1	90025.3	85966.1	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84296.2	96033.4	84296.2	96033.4	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	65748.8	99953.8	64806.4	99953.8	-3,965.45	0.00	-634,473	0	-634,473
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	13484.6	99864	13465.8	99864	-78.91	0.00	-12,625	0	-12,625
TOTAL												-645,854
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	352.8	2819.8	352.8	2852.7	0.00	11.84	0	1,895	1,895
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73489.5	51434.1	73489.5	51432.6	0.00	-0.54	0	-86	-86
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												1,809
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	9024.4	16450.9	9089.5	0.00	62.50	0	9,999	9,999
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3712.3	72971.3	3832.1	0.00	86.26	0	13,801	13,801
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98413.8	7694.8	98408.7	0.00	-1.84	0	-294	-294
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	511.2	44549.1	532.2	0.00	7.56	0	-1,210	-1,210
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	514.9	43962.3	537.3	0.00	8.06	0	-1,290	-1,290
TOTAL												21,007
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97103.3	84658.7	97103.3	84658.7	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt I	NP-6850-A	TR-01	8968	6225.1	8968	6225.1	0.00	0.00	0	0	0
	132kV Agartala-AGTTP Ckt II	NP-6851-A	TR-02	48798.7	93755	48798.7	93755	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68772.7	72313.4	68772.7	72313.4	0.00	0.00	0	0	0
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7289.5	99970.6	7289.5	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14536.8	26.2	14536.8	26.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10222.9	99994.8	10222.9	99994.8	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4461.4	99999.7	4461.4	99999.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1259.5	99980.8	1259.5	99980.8	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1155	99997.2	1155	99997.2	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. आइमल/S.M. Aimal)
 निदेशक/Director
 उ.पु.रे.वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 8/15/2022 to 8/21/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982.6	0.3	99982.6	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93620.1	99820.9	93620.1	99820.9	0	0	0	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94499.5	99795.4	94499.5	99795.4	0	0	0	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92563.3	1085.2	92564.7	1085.2	0.672	0	108	0	0
			NP-8384-A	ME-01	94242.2	61996.5	94242.2	61975.2	0	-10.224	0	1,636	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86039.7	6166	86041.7	6187.8	0.96	10.56	154	-1,690	-154
			NP-9071-A	ME-16	85221.9	24044.3	85221.9	23954.9	0	-50.64	0	8,102	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82111.6	201.8	82111.8	222.5	0.072	7.704	12	-1,233	-12
			NP-9945-A	ME-17	691	97223.2	691	97061.5	0	-93.408	0	14,945	
TOTAL													-165
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15470.4	99655.1	15470.9	99655.1	0.24	0	38	0	0
TOTAL			NP-6892-B	TR-06	76269	75225	76269	74888.6	0	-37.536	0	6,006	0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92846.7	99304.3	92846.7	99304.5	0	0.096	0	-15	0
TOTAL			NP-9947-A	NG-02	49	99745.8	49	99736.3	0	-2.85	0	456	0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (J. M. Aimal) S.M. Aimal
 निदेशक/Director
 उ.पु.वि.भ./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong