Name of Element SHUTDOWNS PROPOSED BY PGCIL 132kV Transmission lines 1 132 KV Kumarghat - PK Bari TL 0800Hrs to 1700Hrs for dismantling of AIS isolators after GIS upgradation 2 132KV Kumarghat - Aizwal TL 0800Hrs to 1700Hrs for dismantling of AIS isolators after GIS upgradation 3 132KV Kumarghat -Karimganj TL 0800Hrs to 1700Hrs for dismantling of AIS isolators after GIS upgradation 4 132KV Kumarghat - Aizwal TL and 132KV Kumarghat -Karimganj TL for dismantling of CVT after GIS upgradation 0800Hrs to 1700Hrs 5 132KV Kumarghat -Karimganj TL 0800Hrs to 1700Hrs for PLCC works under GIS upgradation 6 132KV Kumarghat - RC Nagar TL 0800Hrs to 1700Hrs for PLCC works under GIS upgradation 7 132kV Dimapur-Bokajan TL CSD 0800Hrs to 1700Hrs for upgradation from AIS to GIS 8 132kV Dimapur - Doyang-1 TL CSD 0800Hrs to 1700Hrs for upgradation from AIS to GIS 9 132kV Dimapur - Doyang-2 TL CSD 0800Hrs to 1700Hrs for upgradation from AIS to GIS 10 132kV Khandong-Khelrihat Ckt-2 TL 0800Hrs to 1700Hrs AMP of Khliehriat-2 bay at Khangdong SS 11 132kV Mokokchung-Mokokchung (State) 1 TL 0900Hrs to 1700Hrs misioning of of Line Differential Relay and SCADA communication ommisioning of of Line Differential Relay and SCADA communication 12 132kV Mokokchung-Mokokchung (State) 2 TL 0900Hrs to 1700Hrs 13 132kV Silchar-Srikona-1 TL 0900Hrs to 1700Hrs AMP of Bay equipments at Srikona ASEB end and PG end 14 132kV Silchar-Srikona-2 TL 0900Hrs to 1700Hrs AMP of Bay equipments at Srikona ASEB end and PG end 15 132kV Ziro - Daporijo TL 0900Hrs to 1700Hrs AMP of Bay equipments 16 132 kV Silchar-Hailakandi 0700Hrs to 1800Hrs A/R to be kept in Non- Auto Mode for OPGW works 17 132 kV Kolasib-Turial A/R to be kept in Non- Auto Mode for OPGW works 0700Hrs to 1800Hrs 220kV Transmission lines 19 220KV Old Mariani(AEGCL)-Kathalguri TL 1000Hrs to 1300Hrs Repeat DCRM testing of CB 20 220KV New Mariani-Mokokchung-2 TL 1000Hrs to 1300Hrs Repeat DCRM testing of CB 21 220KV New Mariani-Mokokchung-1 TL 0800Hrs to 1700Hrs AMP of Bay equipments 22 220kV Misa-Samaguri Ckt-1 0800Hrs to 1700Hrs AMP of Bay equipment at samaguri end 23 220kV Salakati-BTPS-1 TL 0800Hrs to 1700Hrs or installation and commissioning of differential relay 24 220kV Salakati-BTPS-2 TL 0800Hrs to 1700Hrs For installation of differential relay 25 400kV Transmission lines 26 400KV New Mariani - Misa -1 TL 0800Hrs to 1700Hrs Insulator replacementwork in major crossings and TWFL commissioning 29 400KV Balipara_Bongaigaon-3 TL and 400KV Balipara_Kameng-2 TL 0800Hrs to 1200Hrs etrofitting of Tie Bay LBB relay(MCTL Areva Make) to Numerical Relay Micom P141 30 400KV Balipara_Bongaigaon-4 TL and 400KV Balipara_Kameng-1 TL 0800Hrs to 1200Hrs Retrofitting of Tie Bay LBB relay(MCTI, Areva Make) to Numerical Relay Micom P141 tetrofitting of Main Bay LBB relay(MCTL Areva Make) to Numerical Relay Micom P141 31 400KV Balipara_BNC-2 TL 0800Hrs to 1200Hrs 32 400KV Balipara-Misa Ckt#1 TL 0800Hrs to 1700Hrs tetrofitting of New DTPC panel with existing Old Tebit Panel 33 400KV Balipara-Misa Ckt#2 TL 0800Hrs to 1700Hrs Retrofitting of New DTPC panel with existing Old Tebit Panel 35 400 kV Bongaigaon-Byrnihat TL A/R to be kept in Non- Auto Mode for OPGW works 0700Hrs to 1800Hrs 36 400 kV Silchar-Pallatna 1 TL 0700Hrs to 1800Hrs A/R to be kept in Non- Auto Mode for OPGW works

											Dec-	21											
		1 2	3 4	5	6	7 8	9	10 11	12 1	3 14	15	16	17 18 19	9 20	21 22	23 24	25	26 27	28	29	30		
	132kV Aizwal SS																						
										-													
	132kV Ziro SS																						
38	132/33kV 15MVA ICT																					0800Hrs to 1600Hrs	AMP of ICT
	220kV Salakati SS																						
39	132kV ICT-2 Main Bay						+		l Ge	Date pro lephu m	posed are nain bay w	tentativ	ve only. In case aken in TBC be and	fore the di	ue date beca	CT-2 main b use there is l of feeder is	huge man-	oleted befor days involv	e the sti vement f	ipulated for serv	d SD time, vice engineer	CSD 0800Hrs to 1700Hrs	For CB pole overhauling due to DCRM violation. ICT-2 LV side will be charged through TBC. Dute proposed are tentative only. In case SD work of 132kV ICT-2 main bay is completed before the signituded SD time, Gelephin main bay will be taken in TBC before the due date because there is huge main-days involvement for service engineer and in this case no outage of feeder is required.
40	132kV Gelephu Main Bay								1			I t	Date proposed : the stipulated S is huge man-day	are tentativ D time, Go s involven	ve only. In c elephu main nent for serv	ase SD work bay will be vice engineer	k of 132kV taken in TI r and in thi	ICT-2 ma BC before t s case no or	in bay is the due utage of	is compi date be f feeder	ecause there r is required.	CSD 0800Hrs to 1700Hrs	For CB pole overhanting due to DCRM violation. Line will be charged through TBC. Date proposed are tentitive only. In case SD work of 13&V ET-2 main bay a completed before the equitated SD tane, Gelsplan main by will be taken in TBC before the due due because there is huge man-days involvement for service engineer and in this case no outage of feeder is required.
	132kV Haflong SS									-	\sqcup						11						
41	132kV Main Bus (All lines will be out)																					CSD 23:00Hrs to 01:00Hrs (for 03 Hrs)	For placing of acrylic sheet in front of gas contactors of all bays at Haflong. Under GIS upgradation work.
	400kV Imphal SS									-	\sqcup						11						
_	400kV Silchar_Imphal 1 Main Bay									-												0800Hrs to 1600Hrs	AMP of Bay equipments
_	400kV Silchar_Imphal 2 Main Bay 400/132/33kV 315MVA ICT 2																					0800Hrs to 1600Hrs 0800Hrs to 1600Hrs	AMP of Bay equipments AMP of ICT
	400kV Silchar I Tie Bay																					0800Hrs to 1600Hrs	AMP of Bay equipments
	400kV Silchar SS									+													3.1.
46	400kV Palatana-l Tie Bay																					0900Hrs to 1700Hrs	AMP of Bay equipments
47	400kV Palatana-2 Tie Bay																					0900Hrs to 1700Hrs	AMP of Bay equipments
48	400kV Palatana-l Main Bay																					0900Hrs to 1700Hrs	AMP of Bay equipments
49	400kV Palatana-2 Main Bay																					0900Hrs to 1700Hrs	AMP of Bay equipments
50	400kV 125MVAR BUS REACTOR-3																					0900Hrs to 1700Hrs	Tuning of CSD and rectification in presence of service engineer. Equipment will be out of service. 3 times close-open operation will be performed for CSD Tuning
		1 2	3 4	5		7 8	,	10 11	12 1	14	Dec-i	16	17 18 19	9 20	21 22	23 24	25	26 27	28	29	30		
	400kV Bongaigaon SS																						
51	400 kV NSLG-2 Main Bay			→			H			+	H								H			CSD 0900Hrs to 1700Hrs	Replacement of 03 Nos of 400 kV CT in NSLG-2 Main Bay
52	400 kV Binaguri-1 Main Bay										H											0900Hrs to 1700Hrs	AMP of Bay equipments
-	400 kV Alipurduar-1 & Balipara-1 Tie Bay						H			1	H											0900Hrs to 1700Hrs	AMP of Bay equipments
	400 kV Alipurduar-1 Main Bay									+	H	\dashv							П			0900Hrs to 1700Hrs	AMP of Bay equipments
-	400 kV BTPS-1 Main Bay									+	H								H			0900Hrs to 1700Hrs	AMP of Bay equipments
	400 kV BTPS-2 Main Bay										+	+							Н			0900Hrs to 1700Hrs	AMP of Bay equipments
							\vdash				\vdash					\vdash	+						
57	400 kV BR#3&4 and BTPS-2 Tie Bay						\sqcup															0900Hrs to 1700Hrs	AMP of Bay equipments
58	400/220/33kV 315MVA ICT#1						Ш															0900Hrs to 1700Hrs	AMP of ICT
59	400kV 63MVAR Azara Line reactor (Line will be out due to system constraints)																					0900Hrs to 1700Hrs	AMP of Line reactor. Line will be out due to safe working clearance while performing AMP.Line will b out due to system constraints
	400kV 50MVAR Balipara-1 Line reactor (Line will be out due to system constraints)																					0900Hrs to 1700Hrs	AMP of Line reactor. Line will be out due to safe working clearance while performing AMP. Line will be out due to system constraints
61	400kV 50MVAR Balipara-2 Line reactor (Line will be out due to system constraints)																					0900Hrs to 1700Hrs	AMP of Line reactor. Line will be out due to safe working clearance while performing AMP. Line will be out due to system constraints
62	400 kV Bryrnihat & BTPS-1 Tie Bay																1					0900Hrs to 1700Hrs	AMP of Bay equipments

	400LV D.E CC	1 1				1 1					Т		1								
-	400kV Balipara SS			+		+					+					+				000011- 170011	Description of To Description of Total Property
63	400KV Bongaigaon-3 and Kameng-2 Tie Bay																			0800Hrs to 1700Hrs	Retrofitting of Tie Bay LBB relay(MCTI, Areva Make) to Numerical Relay Micom P141
64	400KV Bongaigaon-4 and Kameng-l Tie Bay																			0800Hrs to 1700Hrs	Retrofitting of Tie Bay LBB relay(MCTI, Areva Make) to Numerical Relay Micom P141
65	400KV 80MVAR Bus_Reactor-2 and 315MVA ICT-2																			0800Hrs to 1700Hrs	Retrofitting of Tie Bay LBB relay(MCTI, Areva Make) to Numerical Relay Micom P141
66	400KV BNC-2 and Misa-2 Tie Bay				4			\rightarrow												CSD 0800Hrs to 1700Hrs	Replacement of 6 nos of OLD BHEL CT in Tie Bay
67	400KV Bongaigaon-1 and BNC-3 Tie Bay	\Leftarrow		ightharpoons																CSD 0800Hrs to 1700Hrs	Replacement of 3 nos of OLD BHEL CT in Tie Bay
68	400/220KV 315MVA ICT-2													←	\rightarrow					CSD 0800Hrs to 1700Hrs	Installation of Tertiary Insulation Sleeve in 33KV side of the Transformer for increasing safe working clerance.
	400kV Mariani SS																				
69	400KV Bus Reactor -2 and Kohima-1 Tie Bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
70	400kv Kohima -2 and Future Tie Bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
70	400kv Kohima -1 Main Bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
	400kv Kohima -2 Main Bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
71	400KV 125MVAR BUSREACTOR-2																			0900Hrs to 1600Hrs	AMP of Bus Reactor
72	400KV ICT #2 Main bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
73	400KV 500MVA ICT#2																			0900Hrs to 1600Hrs	Differential relay firmware upgradation and operation checking.
sn	Name of Element									Dec-21										Time	Remarks
	±800kV HVDC BNC	1	2 3	4	5	6 7	8 9	10 11	12 13	14 15 16	17	18 19	20	21 22	23 24	25	26	27 28 29	30		
74	SUBANSIRI-2-MAIN-BAY													_						0900Hrs to 1600Hrs	AMP of Bay equipments
75	ICT#1 Main Bay																			0900Hrs to 1600Hrs	AMP of Bay equipments
76	AC-FILTER-1 and AC-FILTER 2 TIE-BAY																			0900Hrs to 1600Hrs	AMP of Bay equipments
77	AC-FILTER-2_MAIN-BAY																			0900Hrs to 1600Hrs	AMP of Bay equipments
78	AC FLITER-1_SUB-BANK-1																			0900Hrs to 1600Hrs	AMP of Bay equipments
79	AC FLITER-1_SUB-BANK-5_SHUNT_CAPACITOR																			0900Hrs to 1600Hrs	AMP of Bay equipments
80	AC FLITER-2_SUB-BANK-4																			0900Hrs to 1600Hrs	AMP of Bay equipments
81	AC FLITER-3_SUB-BANK-3																			0900Hrs to 1600Hrs	AMP of Bay equipments
82	AC FLITER-3_SUB-BANK-4																			0900Hrs to 1600Hrs	AMP of Bay equipments
	400kV Misa SS																				
83	400/220kV 315 MVA ICT-2 along with Main and Tie Bays																			0900Hrs to 1700Hrs	AMP of ICT and Bay equipments
84	400/220kV 500 MVA ICT-3 along with Main and Tie Bays	П																		0900Hrs to 1700Hrs	Instalation of MOG in ICT.
85	400kV 80 MVAR Bus Reactor-1									 										CSD 0900Hrs to 1700Hrs	Offline oil filtration for improving the working life of the Reactor and FDS Testing.
86	400kV 50MVAR Misa-Mariani Ckt-1 Line Reactor																			0900Hrs to 1700Hrs	AMP of LR. Line will be out during switching operation due to system constraints.
				<u> </u>						Dec-21							_				
SN	Name of Element	1	2 3	4	5	6 7	8 9	10 11	12 13	14 15 16	17	18 19	20	21 22	23 24	25	26	27 28 29	30	Time	Remarks
	Interregional/International																				
87	800KV AGRA BNC - I (S/D proposed by NR3)																			CSD 0900Hrs to 1800Hrs	Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA . S/D proposed by NR3. During shut down, all 04 poles will be out
88	800KV AGRA BNC - II (S/D proposed by NR3)	$ \cdot $									H									CSD 0900Hrs to 1800Hrs	Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA . S/D
		Ш																			proposed by NR3. During shut down, all 04 poles will be out

									Dec	-21										
× Name of Element	\vdash		1	Т		\top				×.		1			П	Т			Time	Remarks
	1	2 3	3 4	5	6 7	8	9 10 11	12 1	3 14 15	16 17	18 19	20	21 22	23 24	25	26 1	27 28 29	30		
ASSAM																				
1 220KV SARUSAJAI-SONAPUR																			9:00-11:00	PREVENTIVE MAINTENANCE
2 220KV SARUSAJAI-JAWAHARNAGAR GIS																			9:00-11:00	PREVENTIVE MAINTENANCE
3 220KV MIRZA-BOKO																			9:00-16:00	PREVENTIVE MAINTENANCE
4 220KV MIRZA-AGIA																			9:00-16:00	PREVENTIVE MAINTENANCE
5 132KV PANCHGRAM-LUMSHNONG	\sqcup																		8:00-16:00	PREVENTIVE MAINTENANCE & INSPECTION WORK
6 132KV PANCHGRAM-HAILAKANDI 7 132KV HAILAKANDI-DULLAVCHERRA	+															_			8:00-16:00 8:00-16:00	PREVENTIVE MAINTENANCE & INSPECTION WORK PREVENTIVE MAINTENANCE & INSPECTION WORK
8 132KV SRIKONA-PAILAPOOL																			8:00-16:00	PREVENTIVE MAINTENANCE & INSPECTION WORK PREVENTIVE MAINTENANCE & INSPECTION WORK
9 132KV DULLAVCHERRA-DHARMANAGAR																			9:00-16:00	CORRIDOR CLEANING & LINE MAINTENANCE WORK
10 220KV SAMAGURI-MARIANI CKT-2																			8:00-16:00	CORRIDOR CLEANING
11 220KV SAMAGURI-SONABIL CKT-1																			8:00-16:00	CORRIDOR CLEANING
12 220KV SAMAGURI -SONABIL CKT-2	+		_												-	_			8:00-16:00 8:00-16:00	CORRIDOR CLEANING CORRIDOR CLEANING
13 220KV SAMAGURI-JAWAHARNAGAR 14 220KV SAMAGURI-SONAPUR											_								8:00-16:00 8:00-16:00	CORRIDOR CLEANING CORRIDOR CLEANING
15 220KV AGIA-BTPS-I																			08:00-16:00Hrs	Corridor cleaning
16 220KV AGIA-BTPS-II																			08:00-16:00Hrs	Corridor cleaning
17 220KV AGIA-BOKO 18 220KV AGIA-MIRZA												_							08:00-16:00Hrs 08:00-16:00Hrs	Corridor cleaning
19 132KV BOKAJAN-DIMAPUR			-	_								-				-			9:00-16:00HS	Corridor cleaning Corridor cleaning
20 220KV NAMRUP-MARIANI 21 220KV SAMAGURI-MARIANI CKT-2		-				++	++		+	\vdash	H	-			\vdash	-		\vdash	8:00-16:00 8:00-16:00	CORRIDOR CLEANING AND JUMPER CHECKING CORRIDOR CLEANING AND JUMPER CHECKING
22 400kV Mirza-Silchar		_				+									t				8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT
23 400kV Mirza-Siichar 23 400kV Mirza -Bongaigaon		-	-		 	++	++		+	\vdash		-		\vdash	\vdash	-	+	\vdash	8:00-16:00 8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT PERIODIC TESTING OF BAY EQUIPMENT
23 400kV Mirza -Bongaigaon 24 220kV Mirza Agia	+	-	+		 	++		\blacksquare		 		-		 				\vdash	8:00-16:00 8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT PERIODIC TESTING OF BAY EQUIPMENT
25 220kV Mirza Boko	1 1	_	+			+													8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT
26 220kV Mirza Sarusujai Line 1	⊥†					上十	ユゖ				LF				LĦ				8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT
27 220kV Mirza Sarusujai Line 2																			8:00-16:00	PERIODIC TESTING OF BAY EQUIPMENT
28 220KV TINSUKIA-KATHALGURI CKT-1	\sqcup																		9:00-16:00	CORRIDOR CLEARANCE
29 220KV TINSUKIA-KATHALGURI CKT-2 30 220KV SAMAGURI-JAWAHARNAGAR GIS	\vdash					-						_			-	_			9:00-16:00 8:00-16:00	CORRIDOR CLEARANCE CORRIDOR CLEARANCE
30 220KV SAMAGURI-JAWAHARNAGAR GIS 31 220KV SONAPUR-SARUSAJAI												-				_			8:00-16:00 8:00-16:00	CORRIDOR CLEARANCE CORRIDOR CLEARANCE
32 220KV SONAPUR-SAMAGURI	1		+	_								-				-			8:00-16:00	CORRIDOR CLEARANCE CORRIDOR CLEARANCE
33 132KV MARIANI-GOLAGHAT																			8:00-16:00	CORRIDOR CLEARANCE
34 132KV GOLAGHAT-BOKAJAN																			8:00-16:00	CORRIDOR CLEARANCE
									Dec	-21	<u> </u>									
× Name of Element	1	2 3	3 4	5	6 7	8	9 10 11	12 1	3 14 15	16 17	18 19	20	21 22	23 24	25	26 1	27 28 29	30	Time	Remarks
MEGHALAYA																				
	+					-					_	_								
1 Umtru Kahilipara																				
																			8:30-16:00 Hrs	Checking/replacement of clamps, isolators, CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels
2 Umtru Sarusajai																			8:30-16:00 Hrs 8:30-16:00 Hrs	Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels. Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels.
,																			8:30-16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels
3 132 KV Agia Mendipathar S/C Line																			8:30-16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators, CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees
3 132 KV Agia Mendipathar S/C Line 4 132KV Khliehriat bus shutdown																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs,CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line																			8:30-16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators, CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees
3 132 KV Agia Mendipathar S/C Line 4 132KV Khliehriat bus shutdown																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs,CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line 4 132KV Khliehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators, CTS, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line 4 132KV Khliehriat bus shutdown 5 132KV Lumshnong bus shutdown																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators, CTS, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators, CTS, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs,CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP)																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station																			8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1									be										8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP)		, , ,										22.			24	26	37 39 10		8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1		2 3		5	6 7	s	2 10 11	12 1	Dec	-21 16 17	18 19	20	21 22	23 24	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 Name of Element		2 3	3 4	5	6 7		9 10 11	12 1			18 19	20	21 22	23 24	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments.
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 ** Name of Element KALPATARU		2 3	3 4	5	6 7		9 10 11				18 19	20	21 22	23 24	25	226 1	27 28 29	39	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 ** Name of Element KALPATARU 1 Bay 403 Imphal Clet-1		2 3	3 4	5	6 7	8	9 10 11				18 19	20	21 22 22	23 24	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 00:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Alaintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker & Disconnector
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1		2 3	3 4	s	6 7		9 10 11				18 19	1 20	21 22	23 M	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021,05:00PM But Imphal Ckt	Carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker & Disconnector Circuit Breaker & Disconnector Circuit Breaker, bus Bar & Insulator
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1	1	2 2 3	3 4	5	,		9 10 11				18 19	20	21 22	33 M	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 00:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remets Circuit Breaker & Disconnector Circuit Breaker, bus Bar & Insulator
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 4 Bay 403 Imphal Ckt-1 & Bus Bar-1 8 Bay 403 Imphal Ckt-1 & Bus Bar-1	1	2 3	3 4	s	6 7	s .	9 10 11	12 1			18 19	1 20	21 22	33 M	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 00:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021,05:00PM But Imphal Ckt. Line charge through Tie Bay 402.	Carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker & Disconnector Circuit Breaker & Disconnector Circuit Breaker, bus Bar & Insulator
3 132 KV Agia Mendipathar S/C Line		2 2 3	3 4	s	6 7		9 9 11				18 19	20	21 22	23 24	25	26 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021, 05:00PM But imphal Ckt Line charge through Tie Bay 402. 08:00 to 17:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remets Circuit Breaker & Disconnector Circuit Breaker, bus Bar & Insulator
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 *** Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 4 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 403 Imphal Ckt-1 & Bus Bar-1 6 Bay 403 Imphal Ckt-1 & Bus Bar-1 7 Bay 403 Imphal Ckt-1 & Bus Bar-1 8 Bay 403 Imphal Ckt-1 & Bus Bar-1 9 Bay 403 Imphal Ckt-1 & Bus Bar-1 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Bus Reactor-1	1	2 3	3 4	S	6 7		9 0 11				18 19	20	11 22	23 24	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 hrs of 01:12:2021 to 24:00 of 21:12:2021 Time CSD from 07:12:2021 08:00AM to 12:12:2021, 05:00PM But Imphal Cit Line charge through the Bay 402. 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remets Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bu Bar & Insulator Circuit Breaker, Bd & bus Bar
3 132 KV Agia Mendipathar S/C Line 4 132KV Khiehrirat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasih) Sub-Station NEEPCO (RHEP) 1 Unit-1 ** Name of Element KALPATARU 1 Bay 403 Imphal Cit-1 & Bus Bar-1 2 Bay 403 Imphal Cit-1 & Bus Bar-1 3 Bay 403 Imphal Cit-1 & Bus Bar-1 5 Bay 403 Imphal Cit-1 & Bus Bar-1 5 Bay 403 Imphal Cit-1 & Bus Bar-1 6 Bay 403 Imphal Cit-1 & Bus Bar-1 7 Bay 405 SoboWA in Cit-1 8 Bay 403 Imphal Cit-1 & Bus Bar-1 9 Bay 403 Imphal Cit-1 & Bus Bar-1 9 Bay 404 Bus Reactor-1 9 Bay 405 Bus Reactor-1	1	2 3	3 4	5	4 7		9 10 11	12 1			18 19	20	11 22	3 M	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 9:00-16:00 Hrs 00:00 Hrs to 15:00 hrs 10:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021,05:00PM But Imphal Ckt Line charge through Tre Bay 402. 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remets Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bu Bar & Insulator Circuit Breaker, Bd & bus Bar
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 *** Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 4 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 404 Bus Reactor-11 6 Bay 404 Bus Reactor-11 6 Bay 404 Bus Reactor-11 8 Bay 407 500MVA ICT-1 8 Bay 407 500MVA ICT-1 8 Bay 405 500MVA ICT-1		2 3	3 4	s	. ,		9 9 10 11				18 19	20	31 22	33 M	25	26 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 hrs to 15:00 hrs Time CSD from 07.12.2021 08:00AM to 12.12.2021, 05:00PM But Imphal Ckt Line charge through Tie Bay 402. 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs	Carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker, & Disconnector Circuit Breaker, bus Bar & Insulator Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bu & bus Bar 125 MVAR Bus Reactors at Kohima SS
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Lumshnong bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 *** Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 3 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 403 Imphal Ckt-1 & Bus Bar-1 6 Bay 404 Bus Reactor-1 7 Bay 405 Bus Reactor-1 7 Bay 407 S00MVA ICT-1 8 Bay 406 Imphal Ckt-1 9 Bay 406 Imphal Ckt-1	1	2 3		s	. ,	*	5 II II				18 19	20	21 22	33 34	25	26 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00 - 16:00 Hrs 10:00 - 16:00 Hrs 9:00-16:00 Hrs 10:00 Hrs to 15:00 hrs 10:00 Hrs of 01.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021, 05:00PM But Imphal Ckt Line charge through Tie Bay 402. 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs 08:00 to 17:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Alaintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker, bus Bar & Insulator Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bd & Bus Bar 125 MVAR Bus Reactors at Kohima SS - 500 MVA ICTs at Kohima SS
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 ™ Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 4 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 401 Bus Reactor-1 5 Bay 401 Bus Reactor-1 6 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 9 Bay 403 Imphal Ckt-1 II 10 Bay 403 Imphal Ckt-1 10 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 10 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 12 Bay 403 Imphal Ckt-1 13 Bay 403 Imphal Ckt-1 14 Bay 403 Imphal Ckt-1 15 Bay 403 Imphal Ckt-1 16 Bay 403 Imphal Ckt-1 17 Bay 403 Imphal Ckt-1 18 Bay 403 Imphal Ckt-1	1	2 3	3 4	5	6 7		9 9 10 11				18 19	20	21 22	23 24	25	26 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 hrs to 15:00 hrs CSD from 07.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00 AM to 12.12.2021, 05:00 PM But imphal Ckt. Line charge through Tie Bay 402. 08:00 to 17:00 Hrs	Carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker, & Disconnector Circuit Breaker, bus Bar & Insulator Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bu & bus Bar 125 MVAR Bus Reactors at Kohima SS
3 132 KV Agia Mendipathar S/C Line 4 132KV Khiliehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 *** Name of Element KALPATARU 1 8ay 403 imphal Ckt-1 & Bus Bar-1 2 Bay 403 imphal Ckt-1 & Bus Bar-1 3 Bay 403 imphal Ckt-1 & Bus Bar-1 5 Bay 403 imphal Ckt-1 & Bus Bar-1 5 Bay 404 Bus Reactor-1 6 Bay 404 Bus Reactor-1 7 Bay 407 SOMWA ICT-1 8 Bay 410 SOMWA ICT-1 8 Bay 410 SOMWA ICT-1 9 Bay 405 SOMWA ICT-1 8 Bay 401 imphal Ckt-1 1 Bay 403 imphal Ckt-1 1 Bay 403 imphal Ckt-1 1 Bay 404 Imphal Ckt-1 1 Bay 405 Imphal Ckt-1 1 Bay 405 Imphal Ckt-1 1 Bay 406 Imphal Ckt-1 1 Bay 407 SOMWA ICT-1 1 Bay 407 SOMWA ICT-1 1 Bay 408 Imphal Ckt-1 1 Bay 408 Imphal Ckt-1	1	2 3	3 4	5	6 7		y y y 10 11				18 19	20	21 22	33 M	25	26 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 9:00-16:00 Hrs 00:00 Hrs of 01:12.2021 to 24:00 of 21:12.2021 Time CSD from 07.12.2021 08:00AM to 12.12.2021, 05:00PM But imphal Ckt Line charge through Tie Bay 402. 08:00 to 17:00 Hrs	Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Maintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker & Disconnector Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bd & bus Bar 125 MVAR Bus Reactors at Kohima SS 500 MVA ICTs at Kohima SS Line from Imphal to New Kohima & New Kohima to New Mariani
3 132 KV Agia Mendipathar S/C Line 4 132KV Khilehriat bus shutdown 5 132KV Lumshnong bus shutdown 6 132KV Mendipathar bus shutdown MIZORAM 1 132/33 kV Bawktlang (Kolasib) Sub-Station NEEPCO (RHEP) 1 Unit-1 ™ Name of Element KALPATARU 1 Bay 403 Imphal Ckt-1 & Bus Bar-1 2 Bay 403 Imphal Ckt-1 & Bus Bar-1 4 Bay 403 Imphal Ckt-1 & Bus Bar-1 5 Bay 401 Bus Reactor-1 5 Bay 401 Bus Reactor-1 6 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 8 Bay 407 S00MVA ICT-1 9 Bay 403 Imphal Ckt-1 II 10 Bay 403 Imphal Ckt-1 10 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 10 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 11 Bay 403 Imphal Ckt-1 12 Bay 403 Imphal Ckt-1 13 Bay 403 Imphal Ckt-1 14 Bay 403 Imphal Ckt-1 15 Bay 403 Imphal Ckt-1 16 Bay 403 Imphal Ckt-1 17 Bay 403 Imphal Ckt-1 18 Bay 403 Imphal Ckt-1	1	2 3	3 4	5	. ,		5 D II				18 19	20	21 22	33 34	25	226 1	27 28 29	30	8:30-16:00 Hrs 9:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 10:00-16:00 Hrs 9:00-16:00 Hrs 10:00 hrs to 15:00 hrs 10:00 hrs to 15:00 hrs CSD from 07.12.2021 to 24:00 of 21.12.2021 Time CSD from 07.12.2021 08:00 AM to 12.12.2021, 05:00 PM But imphal Ckt. Line charge through Tie Bay 402. 08:00 to 17:00 Hrs	carried out in the control relay and breaker panels Checking/replacement of clamps, isolators,CTs, CBs, replacement of damaged conductors, greasing of Isolators blades and other preventive maintenance works and works to be carried out in the control relay and breaker panels trimming of trees For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work For attending lose connection and pre winter maintenance work Alaintenance of Bus and Bay Equipments. APM Remarks Circuit Breaker, bus Bar & Insulator Circuit Breaker, bus Bar & Insulator Circuit Breaker, Bd & Bus Bar 125 MVAR Bus Reactors at Kohima SS - 500 MVA ICTs at Kohima SS