



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/8707-8729

Dt: 29th March, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 16.05.2022 to 19.06.2022 (5 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 16.05.2022 to 19.06.2022 (5 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16 Paise/KVARH w.e.f from 1st April 2022, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer
वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.

भवदीय / Yours faithfully,



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

वाणिज्य / Commercial

Reactive Energy (VArH) Charge Statement
for the period 5/16/2022 to 5/22/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	5,201.28
ASSAM	0	6,89,935.65
MANIPUR	0	23,307.80
MEGHALAYA	0	9,11,490.90
MIZORAM	21,928.32	0
NAGALAND	109.44	0
TRIPURA	0	6,289.92

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	3,709.44
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M. Aimal)
 निदेशक/Director
 उ.पु.के.वि.न./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 5/16/2022 to 5/22/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs		
								MVAR High for week	MVAR Low for week	MVAR High charge	MVAR Low charge	Net reactive charge
ARUNACHAL PRADESH	132 kv Ziro-Ranganadi	NP-9704-A	AR-06	23392.6	44	23392.6	44	0	0	0	0	0
	132 KV Khupi-Balipara	NP-9606-A	AS-55	51060.9	79.9	51025.3	79.9	-12.816	0	2050.56	0	2050.56
	132 KV Lekhi-Nirjuli	NP-9665-A	AR-10	1127.9	26070.1	1127.9	26070.1	0	0	0	0	0
	Nirjuli TRF 1	NP-9661-A	AR-01	458.8	4559.3	458.8	4579.8	0	7.38	0	1180.8	1180.8
	Nirjuli TRF 2	NP-9662-A	AR-02	546.2	4274.6	546.2	4293	0	6.624	0	1059.84	1059.84
	132 kv Tenga-Balipara	NP-9696-A	AR-17	64398.8	6.3	64316.4	6.3	-59.328	0	-9492.48	0	-9492.48
	132 kv Lekhi-Pare	NP-9607-A	PA-01	54571	206.3	54571	206.3	0	0	0	0	0
	132 kv Chimpu-Pare	NP-9411-A	PA-05	2101.5	99991.5	2101.5	99991.5	0	0	0	0	0
	132 kv Itanagar-BNC FDR 1	NP-9935-A	AR-19	584.7	99978.2	584.7	99978.2	0	0	0	0	0
	132 kv Itanagar-BNC FDR 2	NP-9939-A	AR-20	243.7	99977.6	243.7	99977.6	0	0	0	0	0
TOTAL												-5201.28
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	48916.3	80.2	49038.3	80.2	195.2	0	-31232	0	-31232
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	5611.2	6862.6	6393.1	6862.6	1251.04	0	-200166.4	0	-200166.4
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	84950.5	98616.4	85076.2	98616.4	125.7	0	20112	0	20112
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	93238.1	99217.7	93435.8	99217.7	197.7	0	31632	0	31632
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	30045.3	63.9	29983.3	63.9	-99.2	0	15872	0	15872
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0	0	0	0	0
	132kV PANCHGRAM-BPUR(PG)	NP-6872-A	AS-07	18885.1	79846.5	18251.5	79846.5	-456.192	0	-72990.72	0	-72990.72
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	5474.3	17.7	5510.1	17.7	25.776	0	-4124.16	0	-4124.16
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99427	86289.7	99427	86295.9	0	2.232	0	-357.12	-357.12
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21782.2	3255	21788.8	3255	1.188	0	-190.08	0	-190.08
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	79671.7	91177.6	79532.8	91177.6	-50.004	0	-8000.64	0	-8000.64
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	84313.1	99934.8	84183	99934.8	-46.836	0	-7493.76	0	-7493.76
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69669.5	0	-96	0	-15360	-15360
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0	0	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	85721.1	99980.7	85518.3	99980.7	-73.008	0	-11681.28	0	-11681.28
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	77725.4	99986.1	77473.1	99986.1	-90.828	0	-14532.48	0	-14532.48
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1353.1	29691.4	1353.2	0	0.096	0	15.36	15.36
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98780.1	99796.5	98629.6	99796.5	-1094.545444	0	-175127.271	0	-175127.271
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	732	97928.3	751.3	97928.3	140.363635	0	22458.18159	0	22458.18159
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84057.5	92669.1	84082.3	92663.2	8.928	-2.124	1428.48	339.84	1768.32
	220kV Mariani-AGBPP	NP-6888-A	AS-03	44999.6	96335.3	43807.2	96335.3	-1907.84	0	-305254.4	0	-305254.4
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95957.5	99006.6	95846.2	99006.6	-80.136	0	-12821.76	0	-12821.76
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4248.7	5168.2	4337	5168.2	63.576	0	10172.16	0	10172.16
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	70765.8	98891.2	70978.7	98891.2	102.192	0	16350.72	0	16350.72
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	89463.3	99565.8	89135.9	99565.8	-157.152	0	-25144.32	0	-25144.32
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	85675.5	15357.7	85675.5	0	0	0	0	0
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	81971.4	50000.2	81971.4	0	0	0	0	0
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94611.3	99951	94570.3	99951	-149.0909076	0	23854.54522	0	23854.54522
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94699.6	2.2	94609.7	2.2	-326.9090876	0	52305.45402	0	52305.45402
TOTAL												-689935.6501
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96472.7	99123.6	96474.6	99123.6	1.368	0	218.88	0	218.88
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	504.3	99940.2	510.9	99940.2	3.168	0	506.88	0	506.88
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0	0	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)		MN-12	97663.3	99869.2	97626.7	99869.2	-13.176	0	2108.16	0	2108.16
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21634.1	384.4	21641.4	384.4	2.628	0	-420.48	0	-420.48
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19144.3	383.9	19151.5	383.9	2.592	0	-414.72	0	-414.72
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42996.3	99420.4	42998.9	99420.4	0.936	0	-149.76	0	-149.76
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94116.6	19.4	94109.9	19.4	-4.824	0	771.84	0	771.84
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0	0	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1224.7	0.2	1246.6	0.2	159.2727257	0	-25483.63611	0	-25483.63611
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	98699.1	2	98684.2	2	-1.341	0	-214.56	0	-214.56
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	98231.5	2.2	98215.5	2.2	-1.44	0	-230.4	0	-230.4
TOTAL												-23307.79611


 (एस.एम. आइमल/S.M. Aimal)
 निदेशक/Director
 उ.पु.के.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95463.9	80893.6	95328.6	80893.6	-97.416	0	-15586.56	0	-15586.56
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99859.4	21033.3	99909.6	21033.3	36.144	0	-5783.04	0	-5783.04
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90055.8	85966.2	90055.8	85966.2	0	0	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84404.7	96033.4	84395.6	96033.4	-14.56	0	2329.6	0	2329.6
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	83257	99953.8	81438.5	99953.8	-6612.727207	0	-1058036.353	0	-1058036.353
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	12072.7	99864	12357.3	99864	1034.909081	0	165585.4529	0	165585.4529
TOTAL												-911490.9002
MIZORAM	132kV LAUNGMUAL-AIZWAL PG	NP-9495-A	MZ-02	181.7	2518.7	293.8	2518.5	40.356	-0.072	-6456.96	-11.52	-6468.48
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	74414.3	51430.5	73921.3	51430.5	-177.48	0	28396.8	0	28396.8
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0	0	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0	0	0	0	0
TOTAL												21928.32
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	8982.5	16450.9	8982.5	0	0	0	0	0
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3631.5	72971.3	3631.5	0	0	0	0	0
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7696.7	98419.8	7694.8	98419.8	-0.684	0	109.44	0	109.44
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542	44549.1	542	0	0	0	0	0
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	546.6	43962.3	546.6	0	0	0	0	0
TOTAL												109.44
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97141.1	84659.1	97141.2	84659.1	0.072	0	-11.52	0	-11.52
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0	0	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0	0	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	9391	99634.9	9260	99634.8	-125.76	-0.096	-20121.6	15.36	-20106.24
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49019.2	93755	48937.3	93755	-78.624	0	-12579.84	0	-12579.84
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68694.2	72313.4	68759.9	72313.4	78.84	0	12614.4	0	12614.4
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7204.6	99970.5	7193	99970.5	-11.136	0	1781.76	0	1781.76
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14458.6	26.1	14429	26.1	-28.416	0	4546.56	0	4546.56
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9643.1	99994.8	9619.5	99994.8	-22.656	0	3624.96	0	3624.96
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4191.2	99999.7	4204.4	99999.7	12.672	0	-2027.52	0	-2027.52
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1235.9	99999.7	1254.1	99999.7	17.472	0	2795.52	0	2795.52
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1109.1	99999.3	1129.1	99999.3	19.2	0	3072	0	3072
TOTAL												-6289.92

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVAHt

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(ए.एम. आइमल/S.M.Aimal)
निदेशक/Director
उ.पु.के.वि.स./NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 5/16/2022 to 5/22/2022

for the period 01/01/2022 to 01/12/2022										Actual*CT*PT		Amount in Rs		
Beneficiary	Line Name	Meter No.	Location Id	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	CT RATIO	PT RATIO	MVAR High for week	MVAR Low for week	MVAR High charge	MVAR Low charge	Net reactive charge
ASSAM	KAHELIPARA-UMTRU II	NP-8488-A	AS-02	0	0	0	0	400	1200	0	0	0	0	0
		NE-0016-A	ME-04	0.6	0	0.6	0	400	1200	0	0	0	0	
	KAHELIPARA-UMTRU I	NP-8490-A	AS-01	0	0	0	0	400	1	0	0	0	0	0
		NP-8474-A	ME-03	99244	99984.8	99244	99984.8	400	1200	0	0	0	0	
	S'SUJAI-UMTRU I	NP-9921-A	AS-09	99982	0.3	99982	0.3	400	1200	0	0	0	0	0
		NP-8473-A	ME-07	93748.7	99821.3	93729.9	99821.3	400	1200	-9.024	0	-1443.84	0	
	S'SUJAI-UMTRU II	NP-9922-A	AS-50	99987.8	0	99987.8	0	400	1200	0	0	0	0	0
		NP-8491-A	ME-05	94631.5	99795.7	94612.5	99795.7	400	1200	-9.12	0	-1459.2	0	
	PANCHGRAM-LUMSHONG	NP-7595-A	AS-06	91527.9	1085.2	91692.8	1085.2	400	1200	79.152	0	12664.32	0	2396.16
		NP-8384-A	ME-01	94379.1	62133	94347.9	62133	400	1200	-14.976	0	-2396.16	0	
	AGIA-Mendhipathar	NP-9455-A	AS-86	87304.7	5989.8	87005.5	5989.8	400	1200	-143.616	0	-22978.56	0	-6105.6
		NP-9071-A	ME-16	84825.4	24835.5	84904.9	24835.5	400	1200	38.16	0	6105.6	0	
	132 KV AGIA-NANGALBIBRA	NP-9920-A	AM-58	83815.5	99998.6	83407.1	99998.6	300	1200	-147.024	0	-23523.84	0	0
		NP-9945-A	ME-17	1721.7	98794.6	1423.4	98794.6	400	1200	-143.184	0	-22909.44	0	
TOTAL														-3709.44
ASSAM	D'CHERRA - D'NAGAR	NP-9904-A	AS-08	14455.3	99958.3	14761.7	99958.3	400	1200	147.072	0	23531.52	0	0
		NP-6892-B	TR-06	76269	80049.7	76269	79688.6	80	1200	0	-34.6656	0	-5546.496	
TOTAL														0
MANIPUR	132kv KARONG-KOHIMA	NP-9667-A	MN-03	92879.9	99309.8	92864.4	99309.8	400	1200	-7.44	0	-1190.4	0	0
		NP-9947-A	NG-02	99989.2	99789.9	12	99789.9	250	1200	-29993.16	0	-4798905.6	0	
TOTAL														

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एच.एम. आइमोल/S. M. Aimol)
 निदेशक/Director
 उ.पु.के.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 5/23/2022 to 5/29/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	13,024	0
ASSAM	0	6,39,621
MANIPUR	0	1,23,016
MEGHALAYA	0	8,27,608
MIZORAM	5,507	0
NAGALAND	194	0
TRIPURA	0	62,811


REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	48
MEGHALAYA	ASSAM	599
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (S.M. Alimol) / S.M. Alimol
 निदेशक/Director
 न.पु.से.वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 5/23/2022 to 5/29/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	23392.6	44	23560.3	44	30.19	0.00	4,830	0	4,830
	132kV Khupi-Balipara	NP-9606-A	AS-55	51025.3	79.9	50938	79.9	-31.43	0.00	5,028	0	5,028
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1127.9	26070.1	1127.9	26078	0.00	5.69	0	-910	-910
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	4585.7	458.8	4642.4	0.00	20.41	0	3,266	3,266
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	4298	546.2	4348.6	0.00	18.22	0	2,915	2,915
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	54571	206.3	54600.7	206.3	14.26	0.00	-2,281	0	-2,281
	132kV Chimpu-Pare	NP-9411-A	PA-05	2101.5	99991.5	2100.6	99991.5	-0.43	0.00	69	0	69
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	584.7	99978.2	585.5	99978.2	0.77	0.00	123	0	123
TOTAL												13,024
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49040.8	80.2	49085.2	80.2	71.04	0.00	-11,366	0	-11,366
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	6518.5	6862.6	7394	6862.6	1,400.80	0.00	-2,24,128	0	-2,24,128
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85076.2	98616.4	85118.6	98616.4	42.40	0.00	6,784	0	6,784
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	93435.8	99217.7	93499.3	99217.7	63.50	0.00	10,160	0	10,160
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	29983.3	63.9	30078.7	63.9	152.64	0.00	-24,422	0	-24,422
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	18131.2	79846.5	17452.1	79846.5	-488.95	0.00	-78,232	0	-78,232
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5520.3	17.7	5534.9	17.7	10.51	0.00	-1,682	0	-1,682
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99427	86296.3	99427	86132.7	0.00	-58.90	0	9,423	9,423
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21788.9	3255	21793.6	3255	0.85	0.00	-135	0	-135
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	79515.7	91177.6	79352.4	91177.6	-58.79	0.00	-9,406	0	-9,406
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	84166.8	99934.8	84011.6	99934.8	-55.87	0.00	-8,940	0	-8,940
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	85514.9	99980.7	85194.1	99980.7	-115.49	0.00	-18,478	0	-18,478
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	77461.5	99986.1	77037.7	99986.1	-152.57	0.00	-24,411	0	-24,411
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1353.2	29691.4	1353.3	0.00	0.10	0	15	15
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98598.8	99796.5	98567.3	99796.5	-229.09	0.00	-36,655	0	-36,655
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	759.7	97928.3	679.1	97928.3	-586.18	0.00	-93,789	0	-93,789
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84082.3	92655.4	84185.4	92612.7	37.12	-15.37	5,939	2,460	8,398
	220kV Mariani-AGBPP	NP-6888-A	AS-03	43551.5	96335.3	42424	96335.3	-1,804.00	0.00	-2,88,640	0	-2,88,640
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95846.2	99006.6	95819.4	99006.6	-19.30	0.00	-3,087	0	-3,087
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4346.7	5168.2	4370.9	5168.2	17.42	0.00	2,788	0	2,788
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	70992	98891.2	71103.5	98891.2	53.52	0.00	8,563	0	8,563
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	89108.2	99565.8	88911.6	99565.8	-94.37	0.00	-15,099	0	-15,099
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	85675.5	15357.7	85185.9	0.00	-176.26	0	28,201	28,201
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	81971.4	50000.2	81414.7	0.00	-200.41	0	32,066	32,066
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94570.3	99951	94502.3	99951	-247.27	0.00	39,564	0	39,564
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94609.7	2.2	94518.8	2.2	-330.55	0.00	52,887	0	52,887
TOTAL												-6,39,621
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96474.6	99123.6	96474.9	99123.6	0.22	0.00	35	0	35
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	510.9	99940.2	512.3	99940.2	0.67	0.00	108	0	108
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	97570.7	99869.2	97772.5	99869.2	72.65	0.00	-11,624	0	-11,624
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21641.4	384.4	21651.7	384.4	3.71	0.00	-593	0	-593
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19151.5	383.9	19161.1	383.9	3.46	0.00	-553	0	-553
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42998.9	99420.4	42995.2	99420.4	-1.33	0.00	213	0	213
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94109.9	19.4	94102.3	19.4	-5.47	0.00	876	0	876
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1246.6	0.2	1342.4	0.2	696.73	0.00	-1,11,476	0	-1,11,476
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
	132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-1,23,016


(J.S.M. Aimal/J.S.M. Aimal)
Director/Director
उप नि. नि. / NEPC
विद्युत मंत्रालय/Min. of Power
शासन सरकार/Govt. of India
शिल्लोंग/Shillong


								Actual*CT*PT		Amount in Rs.		
	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG II	NP-6880-A	ME-09	99909.6	21033.3	99922.6	21033.3	9.36	0.00	-1,498	0	-1,498
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90055.8	85966.2	90044.6	85966.2	-17.92	0.00	2,867	0	2,867
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84395.6	96033.4	84365.4	96033.4	-48.32	0.00	7,731	0	7,731
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	81125.9	99953.8	79739.7	99953.8	-5,040.73	0.00	-8,06,516	0	-8,06,516
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	12404	99864	12364.7	99864	-142.91	0.00	-22,865	0	-22,865
TOTAL												-8,27,608
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	310.8	2518.5	337.5	2522.2	9.61	1.33	-1,538	213	-1,325
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73832.3	51430.5	73713.2	51430	-42.88	-0.18	6,860	-29	6,831
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												5,507
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	8982.5	16450.9	8982.9	0.00	0.38	0	61	61
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3631.5	72971.3	3632.8	0.00	0.94	0	150	150
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98419.8	7694.8	98419.7	0.00	-0.04	0	-6	-6
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542	44549.1	542	0.00	0.00	0	0	0
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	546.6	43962.3	546.8	0.00	0.07	0	-12	-12
TOTAL												194
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97141.2	84659.1	97120.3	84659.1	-15.05	0.00	2,408	0	2,408
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	9260	99634.8	9128.3	99634.8	-126.43	0.00	-20,229	0	-20,229
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48937.3	93755	48863.1	93755	-71.23	0.00	-11,397	0	-11,397
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68759.9	72313.4	68765.5	72313.4	6.72	0.00	1,075	0	1,075
	132kV BUDHJUNG NAGAR - SM NAGAR (STERLITE)	NP-9893-A	TR-28	7193	99970.5	7218.8	99970.5	24.77	0.00	-3,963	0	-3,963
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14429	26.1	14448.3	26.1	18.53	0.00	-2,964	0	-2,964
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9619.5	99994.8	9743.5	99994.8	119.04	0.00	-19,046	0	-19,046
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4204.4	99999.7	4274.5	99999.7	67.30	0.00	-10,767	0	-10,767
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1254.1	99999.7	1254.3	99999.7	0.19	0.00	31	0	31
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1129.1	99999.3	1142.4	99999.3	12.77	0.00	2,043	0	2,043
TOTAL												-62,811

Note: 1) Rate of Reactive Energy Charge has been considered @ 160 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एकतम आदमी/ S.M. Aimal)
 निदेशक/Director
 उद्गुलेक्षित/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 5/23/2022 to 5/29/2022

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93729.9	99821.3	93714.1	99821.3	-7.584	0	-1,213	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94612.5	99795.7	94596.6	99795.7	-7.632	0	-1,221	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91763.7	1085.2	91959.8	1085.2	94.128	0	15,060	0	599
			NP-8384-A	ME-01	94347.9	62133	94340.1	62129.6	-3.744	-1.632	-599	261	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	87016.7	5989.8	87006.3	5989.8	-4.992	0	-799	0	0
			NP-9071-A	ME-16	84899.7	24835.5	84896	24810.8	-1.776	-11.856	-284	1,897	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	83409.8	99998.6	83391.8	99998.6	-6.48	0	-1,037	0	0
			NP-9945-A	ME-17	1404.8	98794.6	1399.2	98701.7	-2.688	-44.592	-430	7,135	
TOTAL													599
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	14818.2	99958.3	14988.1	99958.3	81.552	0	13,048	0	0
			NP-6892-B	TR-06	76269	79667	76269	79073.7	0	-56.9568	0	9,113	
TOTAL													0
MANIPUR	132kv KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92864.4	99309.8	92858.4	99309.7	-2.88	-0.048	-461	8	-48
			NP-9947-A	NG-02	12	99789.9	13	99789.9	0.3	0	48	0	
TOTAL													-48

Note: 1) Rate of Reactive Energy Charge has been considered @ 160paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एम.एस. आइमल/S.M. Aimal)
 निदेशक/Director
 उ.पु.के.वि.अ./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 5/30/2022 to 6/5/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	20,978
ASSAM	0	5,20,304
MANIPUR	0	1,57,848
MEGHALAYA	0	6,61,430
MIZORAM	2,506	0
NAGALAND	10	0
TRIPURA	0	40,808

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	180
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	722
TRIPURA	ASSAM	0


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 5/30/2022 to 6/5/2022

								Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	23560.3	44	23565.1	44	0.86	0.00	138	0	138
	132kV Khupi-Balipara	NP-9606-A	AS-55	50938	79.9	50830.8	79.9	-38.59	0.00	6,175	0	6,175
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1127.9	26078	1127.9	26078	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	4642.4	458.8	4646.3	0.00	1.40	0	225	225
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	4348.6	546.2	4351.5	0.00	1.04	0	167	167
	132kV Tenga-Balipara	NP-9696-A	AR-17	64235.6	6.3	63995.3	6.3	-173.02	0.00	-27,683	0	-27,683
	132kV Lekhi-Pare	NP-9607-A	PA-01	54600.7	206.3	54600.7	206.3	0.00	0.00	0	0	0
	132kV Chimpu-Pare	NP-9411-A	PA-05	2100.6	99991.5	2100.6	99991.5	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.5	99978.2	585.5	99978.2	0.00	0.00	0	0	0
132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	243.6	99977.6	243.6	99977.6	0.00	0.00	0	0	0	
TOTAL												-20,978

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49085.2	80.2	49090.4	80.2	8.32	0.00	-1,331	0	-1,331
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	7394	6862.6	7852.4	6862.6	733.44	0.00	-1,17,350	0	-1,17,350
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85118.6	98616.4	85130.6	98616.4	12.00	0.00	1,920	0	1,920
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	93499.3	99217.7	93538.2	99217.7	38.90	0.00	6,224	0	6,224
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	30078.7	63.9	30191.7	63.9	180.80	0.00	-28,928	0	-28,928
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	17452.1	79846.5	16643.8	79846.5	-581.98	0.00	-93,116	0	-93,116
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5534.9	17.7	5553.1	17.7	13.10	0.00	-2,097	0	-2,097
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99427	86132.7	99427	85867.7	0.00	-95.40	0	15,264	15,264
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21793.6	3255	21800	3255.1	1.15	0.02	-184	3	-181
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	79352.4	91177.6	79172.2	91177.6	-64.87	0.00	-10,380	0	-10,380
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	84011.6	99934.8	83841.5	99934.8	-61.24	0.00	-9,798	0	-9,798
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	85194.1	99980.7	84855.2	99980.7	-122.00	0.00	-19,521	0	-19,521
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	77037.7	99986.1	76576.8	99986.1	-165.92	0.00	-26,548	0	-26,548
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1353.3	29691.4	1353.3	0.00	0.00	0	0	0
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98567.3	99796.5	98571.9	99796.5	33.45	0.00	5,353	0	5,353
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	679.1	97928.3	586.1	97928.3	-676.36	0.00	-1,08,218	0	-1,08,218
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84185.4	92612.7	84310.3	92607.5	44.96	-1.87	7,194	300	7,494
	220kV Mariani-AGBPP	NP-6888-A	AS-03	42424	96335.3	41483.5	96335.3	-1,504.80	0.00	-2,40,768	0	-2,40,768
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95819.4	99006.6	95805.7	99006.6	-9.86	0.00	-1,578	0	-1,578
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4370.9	5168.2	4380.7	5168.2	7.06	0.00	1,129	0	1,129
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	71103.5	98891.2	71246.4	98891.2	68.59	0.00	10,975	0	10,975
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	88911.6	99565.8	88662	99565.8	-119.81	0.00	-19,169	0	-19,169
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	85185.9	15357.7	84290.3	0.00	-322.42	0	51,587	51,587
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	81414.7	50000.2	80484.9	0.00	-334.73	0	53,556	53,556
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94502.3	99951	94502.2	99951	-0.36	0.00	58	0	58
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94518.8	2.2	94510	2.2	-32.00	0.00	5,120	0	5,120
TOTAL				-5,20,304								

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96474.9	99123.6	96474.9	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	512.3	99940.2	512.4	99940.2	0.05	0.00	8	0	8
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	97772.5	99869.2	98071.9	99869.2	107.78	0.00	-17,245	0	-17,245
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21651.7	384.4	21673.5	384.4	7.85	0.00	-1,256	0	-1,256
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19161.1	383.9	19182.6	383.9	7.74	0.00	-1,238	0	-1,238
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42995.2	99420.4	42992.7	99420.4	-0.90	0.00	144	0	144
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94102.3	19.4	94095.4	19.4	-4.97	0.00	795	0	795
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1342.4	0.2	1461.9	0.2	869.09	0.00	-1,39,055	0	-1,39,055
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
				132/33 50 MVA IMPHAL ICT 2 LV SIDE	NE-0018-A	ZZ-72	0	0	0	0	0	0
TOTAL				-1,57,848								


(एस.एम.आइमल/S.M.Aimal)
डिरेक्टर/Director
उ.पु.व.वि.सं./UPVSPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

								Actual*CT*PT		Amount in Rs.		
MEGHALAYA	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99922.6	21033.3	99995.4	21033.3	52.42	0.00	-8,387	0	-8,387
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90044.6	85966.2	90042.5	85966.2	-3.36	0.00	538	0	538
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84365.4	96033.4	84361.8	96033.4	-5.76	0.00	922	0	922
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	79739.7	99953.8	78860.9	99953.8	-3,195.64	0.00	-5,11,302	0	-5,11,302
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	12364.7	99864	12145.6	99864	-796.73	0.00	-1,27,476	0	-1,27,476
TOTAL												-6,61,430
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	337.5	2522.2	338.2	2542.1	0.25	7.16	-40	1,146	1,106
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73713.2	51430	73701.7	51442.8	-4.14	4.61	662	737	1,400
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
	TOTAL											2,506
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	8982.9	16450.9	8983	0.00	0.10	0	15	15
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3632.8	72971.3	3632.8	0.00	0.00	0	0	0
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98419.7	7694.8	98419.7	0.00	0.00	0	0	0
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542	44549.1	542	0.00	0.00	0	0	0
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	546.8	43962.3	546.9	0.00	0.04	0	-6	-6
TOTAL												10
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97120.3	84659.1	97114.4	84659.1	-4.25	0.00	680	0	680
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	9128.3	99634.8	9042.9	99634.8	-81.98	0.00	-13,117	0	-13,117
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48863.1	93755	48819.4	93755	-41.95	0.00	-6,712	0	-6,712
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68765.5	72313.4	68768.3	72313.4	3.36	0.00	538	0	538
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7218.8	99970.5	7222.8	99970.5	3.84	0.00	-614	0	-614
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14448.3	26.1	14454.5	26.1	5.95	0.00	-952	0	-952
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9743.5	99994.8	9835.7	99994.8	88.51	0.00	-14,162	0	-14,162
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4274.5	99999.7	4321.7	99999.7	45.31	0.00	-7,250	0	-7,250
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1254.3	99999.7	1255.8	99999.7	1.44	0.00	230	0	230
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1142.4	99999.3	1146	99999.3	3.46	0.00	553	0	553
TOTAL												-40,808

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पु.के.वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 5/30/2022 to 6/5/2022

									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93714.1	99821.3	93703.1	99821	-5.28	-0.144	-845	23	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94596.6	99795.7	94585.3	99795.5	-5.424	-0.096	-868	15	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91959.8	1085.2	92236.8	1085.2	132.96	0	21,274	0	3,325
			NP-8384-A	ME-01	94340.1	62129.6	94296.8	62129.5	-20.784	-0.048	-3,325	8	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	87006.3	5989.8	86923	5989.8	-39.984	0	-6,397	0	-3,564
			NP-9071-A	ME-16	84896	24810.8	84942.4	24769.5	22.272	-19.824	3,564	3,172	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	83391.8	99998.6	83271.5	99999.6	-43.308	0.36	-6,929	-58	58
			NP-9945-A	ME-17	1399.2	98701.7	1395.9	98593.6	-1.584	-51.888	-253	8,302	
TOTAL													-180
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	14988.1	99958.3	15184.7	99958.3	94.368	0	15,099	0	0
			NP-6892-B	TR-06	76269	79073.7	76269	77978.7	0	-105.12	0	16,819	
TOTAL													0
MANIPUR	132kv KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92858.4	99309.7	92849	99309.7	-4.512	0	-722	0	722
			NP-9947-A	NG-02	13	99789.9	30.5	99789.9	5.25	0	840	0	
TOTAL													722

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(S.M. Aimal, Joint Secretary/S.M. Aimal)
निदेशक/Director
उ.पु. वि. म./NEERC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

Reactive Energy (VArH) Charge Statement
for the period 6/6/2022 to 6/12/2022

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	23,530
ASSAM	0	6,03,858
MANIPUR	0	80,594
MEGHALAYA	0	7,17,906
MIZORAM	789	0
NAGALAND	6	0
TRIPURA	0	12,461


REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	9,370
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 (एस.एम. आइमोल/S.M. Aimol)
 निदेशक/Director
 उ.पु.के.वि.म./NERPC
 बिहार सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/6/2022 to 6/12/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	23565.1	44	23626.1	44	10.98	0.00	1,757	0	1,757
	132kV Khupi-Balipara	NP-9606-A	AS-55	50830.8	79.9	50392.2	79.9	-157.90	0.00	25,263	0	25,263
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1127.9	26078	1128	26078	0.07	0.00	12	0	12
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	4646.3	458.8	4650.7	0.00	1.58	0	253	253
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	4351.5	546.2	4355.5	0.00	1.44	0	230	230
	132kV Tenga-Balipara	NP-9696-A	AR-17	63995.3	6.3	63568.2	6.3	-307.51	0.00	-49,202	0	-49,202
	132kV Lekhi-Pare	NP-9607-A	PA-01	54600.7	206.3	54623.4	206.3	10.90	0.00	-1,743	0	-1,743
	132kV Chimpur-Pare	NP-9411-A	PA-05	2100.6	99991.5	2102.5	99991.5	0.91	0.00	-146	0	-146
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.5	99978.2	585.7	99978.2	0.19	0.00	31	0	31
TOTAL												-23,530
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49090.4	80.2	49101.9	80.2	18.40	0.00	-2,944	0	-2,944
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	7852.4	6862.6	8485.5	6862.6	1,012.96	0.00	-1,62,074	0	-1,62,074
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85130.6	98616.4	85199.2	98616.4	68.60	0.00	10,976	0	10,976
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	93538.2	99217.7	93642.9	99217.7	104.70	0.00	16,752	0	16,752
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	30191.7	63.9	30712.4	63.9	833.12	0.00	-1,33,299	0	-1,33,299
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	16643.8	79846.5	16281	79846.5	-261.22	0.00	-41,795	0	-41,795
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5553.1	17.7	5559	17.7	4.25	0.00	-680	0	-680
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99427	85867.7	99427	85724	0.00	-51.73	0	8,277	8,277
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21800	3255.1	21802.7	3255.1	0.49	0.00	-78	0	-78
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	79172.2	91177.6	79138	91177.6	-12.31	0.00	-1,970	0	-1,970
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83841.0	99934.8	83810.5	99934.8	-11.16	0.00	-1,786	0	-1,786
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84855.2	99980.7	84745.1	99980.7	-39.64	0.00	-6,342	0	-6,342
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	76576.8	99986.1	76387	99986.1	-68.33	0.00	-10,932	0	-10,932
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1353.3	29691.4	1353.3	0.00	0.00	0	0	0
	400kV AZARA-BONGAIGAOON	NP-9983-A	AM-01	98571.9	99796.5	98559.9	99796.5	-87.27	0.00	-13,964	0	-13,964
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	586.1	97928.3	512	97928.3	-538.91	0.00	-86,225	0	-86,225
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84310.3	92607.5	84411.2	92637.1	36.32	10.66	5,812	-1,705	4,107
	220kV Mariani-AGBPP	NP-6888-A	AS-03	41483.5	96335.3	40551	96335.3	-1,492.00	0.00	-2,38,720	0	-2,38,720
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95805.7	99006.6	95805.7	99006.6	0.00	0.00	0	0	0
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4380.7	5168.2	4382.3	5168.2	1.15	0.00	184	0	184
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	71246.4	98891.2	71408.9	98891.2	78.00	0.00	12,480	0	12,480
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	88662	99565.8	88413.4	99565.8	-119.33	0.00	-19,092	0	-19,092
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.7	84290.3	15357.7	84244.8	0.00	-16.38	0	2,621	2,621
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	80484.9	50000.2	80428	0.00	-20.48	0	3,277	3,277
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94502.2	99951	94483.7	99951	-67.27	0.00	10,764	0	10,764
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94510	2.2	94429.9	2.2	-291.27	0.00	46,604	0	46,604
TOTAL												-6,03,858
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96474.9	99123.6	96474.9	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	512.4	99940.2	512.4	99940.2	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98071.9	99869.2	98099.7	99869.2	10.01	0.00	-1,601	0	-1,601
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21673.5	384.4	21674.6	384.4	0.40	0.00	-63	0	-63
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19182.6	383.9	19183.4	383.9	0.29	0.00	-46	0	-46
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42992.7	99420.4	42992.7	99420.4	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94095.4	19.4	94095.3	19.4	-0.07	0.00	12	0	12
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1461.9	0.2	1529.7	0.2	493.09	0.00	-78,895	0	-78,895
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-80,594


(एस.एम.आमीन/S.M.Amini)
निदेशक/Director
उत्तुके बिजु/NERPC
विद्युत संचालन/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

								Actual*CT*PT		Amount in Rs.		
	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG II	NP-6880-A	ME-09	99995.4	21033.3	8.3	21033.3	9.29	0.00	-1,486	0	-1,486
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90042.5	85966.2	90042.5	85966.2	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84361.8	96033.4	84361.8	96033.4	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	78860.9	99953.8	77618.5	99953.8	-4,517.82	0.00	-7,22,851	0	-7,22,851
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	12145.6	99864	12177.8	99864	117.09	0.00	18,735	0	18,735
TOTAL												-7,17,906
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	338.2	2542.1	338.2	2551.6	0.00	3.42	0	547	547
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73701.7	51442.8	73701.7	51447	0.00	1.51	0	242	242
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
TOTAL												789
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	8983	16450.9	8983	0.00	0.00	0	0	0
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3632.8	72971.3	3632.9	0.00	0.07	0	12	12
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98419.7	7694.8	98419.7	0.00	0.00	0	0	0
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542	44549.1	542.1	0.00	0.04	0	-6	-6
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	546.9	43962.3	546.9	0.00	0.00	0	0	0
TOTAL												6
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97114.4	84659.1	97114.3	84659	-0.07	-0.07	12	-12	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	9042.9	99634.8	9032.6	99634.8	-9.89	0.00	-1,582	0	-1,582
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48819.4	93755	48817.4	93755	-1.92	0.00	-307	0	-307
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68768.3	72313.4	68767.8	72313.4	-0.60	0.00	-96	0	-96
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7222.8	99970.5	7225.9	99970.5	2.98	0.00	-476	0	-476
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14454.5	26.1	14458.1	26.1	3.46	0.00	-553	0	-553
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9835.7	99994.8	9884.5	99994.8	46.85	0.00	-7,496	0	-7,496
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4321.7	99999.7	4334.8	99999.7	12.58	0.00	-2,012	0	-2,012
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1255.8	99999.7	1255.9	99999.6	0.10	-0.10	15	15	31
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1146	99999.3	1146.2	99999.3	0.19	0.00	31	0	31
TOTAL												-12,461

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IECG, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एन एम. आइमल/S. M. Aimal)
 निदेशक/Director
 उ.पु.नि./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/6/2022 to 6/12/2022

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0		
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93703.1	99821	93673.8	99820.9	-14.064	-0.048	-2,250	8	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94585.3	99795.5	94553.7	99795.4	-15.168	-0.048	-2,427	8	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92236.8	1085.2	92280.2	1085.2	20.832	0	3,333	0	0
			NP-8384-A	ME-01	94296.8	62129.5	94297.1	62129.5	0.144	0	23	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86923	5989.8	86626.2	5989.8	-142.464	0	-22,794	0	-9,370
			NP-9071-A	ME-16	84942.4	24769.5	85064.4	24761	58.56	-4.08	9,370	653	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	83271.5	99999.6	82905.9	99999.6	-131.616	0	-21,059	0	0
			NP-9945-A	ME-17	1395.9	98593.6	1347.5	98573.2	-23.232	-9.792	-3,717	1,567	
TOTAL													-9,370
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15184.7	99958.3	15212.6	99958.3	13.392	0	2,143	0	0
			NP-6892-B	TR-06	76269	77978.7	76269	77942.8	0	-3.4464	0	551	
TOTAL													0
MANIPUR	132kV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92849	99309.7	92849	99309.7	0	0	0	0	0
			NP-9947-A	NG-02	30.5	99789.9	30.5	99789.9	0	0	0	0	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.के.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

**Reactive Energy (VArH) Charge Statement
for the period 6/13/2022 to 6/19/2022**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	18,846
ASSAM	0	5,20,683
MANIPUR	0	47,695
MEGHALAYA	0	7,55,315
MIZORAM	380	0
NAGALAND	0	6
TRIPURA	0	1,417

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	5,983
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	207
TRIPURA	ASSAM	0


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/13/2022 to 6/19/2022

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	23626.1	44	23681	44	9.88	0.00	1,581	0	1,581
	132kV Khupi-Balipara	NP-9606-A	AS-55	50392.2	79.9	49316.5	79.9	-387.25	0.00	61,960	0	61,960
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1128	26078	1128	26078	0.00	0.00	0	0	0
	Nirjuli-TRF 1	NP-9661-A	AR-01	458.8	4650.7	458.8	4695	0.00	15.95	0	2,552	2,552
	Nirjuli-TRF 2	NP-9662-A	AR-02	546.2	4355.5	546.2	4399.4	0.00	15.80	0	2,529	2,529
	132kV Tenga-Balipara	NP-9696-A	AR-17	63568.2	6.3	62808.2	6.3	-547.20	0.00	-87,552	0	-87,552
	132kV Lekhi-Pare	NP-9607-A	PA-01	54623.4	206.3	54622.3	206.3	-0.53	0.00	84	0	84
	132kV Chimpu-Pare	NP-9411-A	PA-05	2102.5	99991.5	2102.5	99991.5	0.00	0.00	0	0	0
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	585.7	99978.2	585.7	99978.2	0.00	0.00	0	0	0
TOTAL												-18,846
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	49101.9	80.2	49087.9	80.2	-22.40	0.00	3,584	0	3,584
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	8485.5	6862.6	8932.6	6862.6	715.36	0.00	-1,14,458	0	-1,14,458
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	85199.2	98616.4	85678.4	98616.4	479.20	0.00	76,672	0	76,672
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	93642.9	99217.7	94532.7	99217.7	889.80	0.00	1,42,368	0	1,42,368
	220KV SONABIL-BALIPARA	NP-9487-A	AS-42	30712.4	63.9	31808.3	63.9	1,753.44	0.00	-2,80,550	0	-2,80,550
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	16281	79846.5	15800.4	79846.5	-346.03	0.00	-55,365	0	-55,365
	132kV P*pool-JIRIBAM	NE-0039-A	MN-06	5559	17.7	5564.7	17.7	4.10	0.00	-657	0	-657
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99427	85724	99427	85672.8	0.00	-18.43	0	2,949	2,949
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	21802.7	3255.1	21811.9	3255.1	1.66	0.00	-265	0	-265
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	79138	91177.6	79056.1	91177.6	-29.48	0.00	-4,717	0	-4,717
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	83810.5	99934.8	83735	99934.8	-27.18	0.00	-4,349	0	-4,349
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	84745.1	99980.7	84611.6	99980.6	-48.06	-0.04	-7,690	6	-7,684
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	76387	99986.1	76186.1	99986	-72.32	-0.04	-11,572	6	-11,566
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29691.4	1353.3	29691.4	1353.3	0.00	0.00	0	0	0
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	98559.9	99796.5	98466	99796.5	-682.91	0.00	-1,09,265	0	-1,09,265
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	512	97928.3	525.1	97928.3	95.27	0.00	15,244	0	15,244
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	84411.2	92637.1	84416.1	92582.2	1.76	-19.76	282	3,162	3,444
	220kV Mariani-AGBPP	NP-6888-A	AS-03	40551	96335.3	39482.1	96335.3	-1,710.24	0.00	-2,73,638	0	-2,73,638
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	95805.7	99006.6	95803.4	99006.6	-1.66	0.00	-265	0	-265
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4382.3	5168.2	4400.5	5168.2	13.10	0.00	2,097	0	2,097
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	71408.9	98891.2	71657.5	98891.2	119.33	0.00	19,092	0	19,092
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	88413.4	99565.8	88086.4	99565.8	-156.96	0.00	-25,114	0	-25,114
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15357.5	84244.8	15357.7	84244.8	0.00	0.00	0	0	0
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50000.2	80428	50000.2	80428	0.00	0.00	0	0	0
	Balipara end of 400 kV Bongaigaon-1	NE-0043-A	ZZ-16	94483.7	99951	94453.6	99951	-109.45	0.00	17,513	0	17,513
	Balipara end of 400 kV Bongaigaon-2	NE-0047-A	ZZ-17	94429.9	2.2	94285	2.1	-526.91	-0.36	84,305	-58	84,247
TOTAL												-5,20,683
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96474.9	99123.6	96474.9	99123.6	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	512.4	99940.2	512.4	99940.2	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98099.7	99869.2	98135.4	99869.2	12.85	0.00	-2,056	0	-2,056
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	21674.6	384.4	21679.6	384.4	1.80	0.00	-288	0	-288
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19183.4	383.9	19188.2	383.9	1.73	0.00	-276	0	-276
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	42992.7	99420.4	42992.6	99420.4	-0.04	0.00	6	0	6
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	94095.3	19.4	94094.7	19.4	-0.43	0.00	69	0	69
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	1529.7	0.2	1568.5	0.2	282.18	0.00	-45,149	0	-45,149
	132/33 50 MVA IMPHAL ICT 1 LV SIDE	NE-0048-A	ZZ-71	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-47,695


 (S. M. Aismol) S. M. Aismol
 Director/Director
 of the Ministry/Min.
 of Power
 Govt. of India
 Shillong

								Actual*CT*PT		Amount in Rs.		
MEGHALAYA	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
	132kV KHLRT S-PG II	NP-6880-A	ME-09	8.3	21033.3	74.9	21033.3	47.95	0.00	-7,672	0	-7,672
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90042.5	85966.2	90042.3	85966.1	-0.32	-0.16	51	-26	26
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	84361.8	96033.4	84361.1	96033.4	-1.12	0.00	179	0	179
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	77618.5	99953.8	75661.2	99953.8	-7,117.45	0.00	-11,38,793	0	-11,38,793
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	12177.8	99864	12887.1	99864	2,579.27	0.00	4,12,684	0	4,12,684
TOTAL												-7,55,315
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	338.2	2551.6	338.8	2551.7	0.22	0.04	-35	6	-29
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	73701.7	51447	73694.6	51447	-2.56	0.00	409	0	409
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
	TOTAL											380
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	16450.9	8983	16450.9	8983	0.00	0.00	0	0	0
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	72971.3	3632.9	72971.3	3632.9	0.00	0.00	0	0	0
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	7694.8	98419.7	7694.8	98419.7	0.00	0.00	0	0	0
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44549.1	542.1	44549.1	542.1	0.00	0.00	0	0	0
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43962.3	546.9	43962.3	547	0.00	0.04	0	-6	-6
TOTAL												-6
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97114.3	84659	97113	84659	-0.94	0.00	150	0	150
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	9032.6	99634.8	9028.8	99634.8	-3.65	0.00	-584	0	-584
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48817.4	93755	48816.4	93755	-0.96	0.00	-154	0	-154
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68767.8	72313.4	68767.4	72313.4	-0.48	0.00	-77	0	-77
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7225.9	99970.5	7227.3	99970.5	1.34	0.00	-215	0	-215
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14458.1	26.1	14460	26.1	1.82	0.00	-292	0	-292
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	9884.5	99994.8	9886.6	99994.8	2.02	0.00	-323	0	-323
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4334.8	99999.7	4335.9	99999.7	1.06	0.00	-169	0	-169
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1255.9	99999.6	1256.7	99999.6	0.77	0.00	123	0	123
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1146.2	99999.3	1147	99999.3	0.77	0.00	123	0	123
TOTAL												-1,417

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


(एस एम अदनाम/ S.M.Amlol)
निदेशक/Director
उत्तु क्षेत्र/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/13/2022 to 6/19/2022

Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Effective Net Reactive Charge
									MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NE-0016-A	ME-04	0.6	0	0.6	0	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99982	0.3	99982	0.3	0	0	0	0	0
			NP-8473-A	ME-07	93673.8	99820.9	93638.6	99820.9	-16.896	0	-2,703	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.8	0	99987.8	0	0	0	0	0	0
			NP-8491-A	ME-05	94553.7	99795.4	94518.3	99795.4	-16.992	0	-2,719	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	92280.2	1085.2	92341.8	1085.2	29.568	0	4,731	0	1,144
			NP-8384-A	ME-01	94297.1	62129.5	94282.2	62129.5	-7.152	0	-1,144	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	86626.2	5989.8	86205.6	5989.8	-201.888	0	-32,302	0	-7,127
			NP-9071-A	ME-16	85064.4	24761	85157.2	24761	44.544	0	7,127	0	
	132 KV AGIA-NANGALBIBRA	MEGHALAYA	NP-9920-A	AM-58	82905.9	99999.6	82335.7	99999.6	-205.272	0	-32,844	0	0
			NP-9945-A	ME-17	1347.5	98573.2	880.3	98573.2	-224.256	0	-35,881	0	
TOTAL													-5,983
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	15212.6	99958.3	15338.9	99958.4	60.624	0.048	9,700	-8	0
			NP-6892-B	TR-06	76269	77942.8	76269	77942.8	0	0	0	0	
TOTAL													0
MANIPUR	132kv KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	92849	99309.7	92846.3	99309.7	-1.296	0	-207	0	207
			NP-9947-A	NG-02	30.5	99789.9	49	99789.9	5.55	0	888	0	
TOTAL													207

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम.आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.म./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong