



भारत सरकार Government of India

विद्युत मंत्रालय Ministry of Power

उत्तर पूर्वी क्षेत्रीय विद्युत समिति

North Eastern Regional Power Committee

एन ई आर पी सी कॉम्प्लेक्स, डोंग पारमाओ, लापालाङ, शिल्लोंग-७९३००६, मेघालय
NERPC Complex, Dong Parmaw, Lapalang, Shillong - 793006, Meghalaya

SPEED POST/FAX

Ph : 0364-2534077

Fax: 0364-2534040

Email: nerpc@ymail.com

website: www.nerpc.nic.in

No. NERPC/COM/REACTIVE/2020/395 - 417

07-04-2022

To,

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33,Faridabad, Haryana-121003

विषय: संशोधित-01 एबीटी रेजिम के तहत दिनांक 25.01.2021 से 04.04.2021 का रिएक्टिव एनर्जी का लेखा |

Sub: Revised Reactive Energy under ABT regime-for the period 25.01.2021 to 04.04.2021(Rev 1)- Reg.

महोदय,

Sir,

दिनांक 25.01.2021 से 04.04.2021 की अवधि का संशोधित-01 रिएक्टिव एनर्जी लेखा जिसमें पूल और हितधारियों के बीच देय / प्राप्तियोग्य विवरणों को इसके साथ भेजा जा रहा है | रिएक्टिव एनर्जी के प्रभार/ भुगतान IEGC-April 2010 के उपबंध 6.6(2) के अनुसार शासित होंगे जो कि 1 अप्रैल 2020 से 15.0 पैसे/केवीएआरएच होग,इसके बाद प्रति वर्ष 0.5 पैसे परिकलित किया जाएगा जबतक कि अन्यथा आयोग द्वारा संशोधित न किया जाए |

The statement of revised Reactive Energy account (Rev-1) giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 25.01.2021 to 04.04.2021 is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 15.0 Paise/KVARH w.e.f from 1st April 2020, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

इसके अतिरिक्त बिल राशि के लिए आयोग द्वारा भुगतान को बिल की तारीख के दस दिनों के अंदर किया जाए | इन बिलों के भुगतान में बारह दिनों के बाद विलंब होने पर दोषी सदस्यों को प्रत्येक विलंब के लिए IEGC-April 2010 के प्रकाशन के कोम्प्लीमेंटरी कमर्शियल मकेनिज्म के उपबंध 11 एवं 12 के तहत 0.04% की दर से साधारण ब्याज देना होगा |

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

रिएक्टिव एनर्जी लेखा का विवरण www.nerpc.nic.in में उपलब्ध हैं |

The details of Reactive Energy Accounts are available on www.nerpc.nic.in.

धन्यवाद.,

Thanking you,

संलग्नक: उपरोक्तानुसार

Encl.: As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल / S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता / Superintending Engineer

वाणिज्य / Commercial

Copy to:

1. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
2. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
3. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
4. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
5. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
6. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
7. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
8. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
9. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
10. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
11. Sr. GM (AM), PGCIL, Dongtiah, Lower Nongrah, Lapalang, Shillong-793006
12. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
13. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल / S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता / Superintending Engineer

वाणिज्य / Commercial

**Reactive Energy (VArH) Charge Statement
for the period 25-01-2021 to 31-01-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	863	0
ASSAM	0	12,81,736
MANIPUR	0	776
MEGHALAYA	0	7,87,441
MIZORAM	77,971	0
NAGALAND	0	1,274
TRIPURA	0	8,12,254

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	266
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


For the purpose of the statement
 the following details are provided
 for the period 25-01-2021 to 31-01-2021
 the reactive energy charge is calculated
 on the basis of the above details

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 25-01-2021 to 31-01-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	76997.7	25.5	77901	25.5	162.59	0.00	24,389	0	24,389
	132kV Khupi-Balipara	NP-9606-A	AS-55	59841.8	79.9	59617.6	79.9	-80.71	0.00	12,107	0	12,107
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	80471.5	1.5	80266.7	0.00	-147.46	0	-22,118	-22,118
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	1938.9	439	1944.1	0.00	1.87	0	281	281
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1861.7	498	1866.1	0.00	1.58	0	238	238
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	45417.6	166.2	45573.4	166.2	74.78	0.00	-11,218	0	-11,218
	132kV Chimpur-Pare	NP-9411-A	PA-05	572.4	7	611.5	7	18.77	0.00	-2,815	0	-2,815
TOTAL												863
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	40761.9	75.7	41013.1	75.7	401.92	0.00	-60,288	0	-60,288
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	59402	6862.5	61026	6862.5	2,598.40	0.00	-3,89,760	0	-3,89,760
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70039.9	98617.2	70157.5	98617.2	117.60	0.00	17,640	0	17,640
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	68863.1	99217.8	69252.8	99217.8	389.70	0.00	58,455	0	58,455
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27468.4	63.9	27719.9	63.9	402.40	0.00	-60,360	0	-60,360
	220kV MARIANI - MISA	NP-9700-A	AS-04	8672.4	99920.1	8678.3	99920.1	9.44	0.00	1,416	0	1,416
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	52124.7	82268.2	52097.3	82268.2	-19.73	0.00	-2,959	0	-2,959
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7310.4	1561.6	7358.9	0.00	34.92	0	5,238	5,238
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99502.1	95148.8	99502.1	95064.4	0.00	-30.38	0	4,558	4,558
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19908.7	3240.4	19908.7	3240.4	0.00	0.00	0	0	0
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87528	91178.2	87525.6	91178.2	-0.86	0.00	-130	0	-130
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91791.1	99935.3	91789.1	99935.3	-0.72	0.00	-108	0	-108
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93836.6	99981.3	93835.2	99981.3	-0.50	0.00	-76	0	-76
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89303.1	99986.8	89299.4	99986.8	-1.33	0.00	-200	0	-200
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28907	98978.1	28907.5	98978.9	0.18	0.29	-27	43	16
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99994.8	5.5	99987.3	0.00	-54.55	0	8,182	8,182
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	867.3	0.1	1236.1	0.00	2,682.18	0	-4,02,327	-4,02,327
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	607.8	82394.2	437.9	0.00	-61.16	0	9,175	9,175
	220kV Mariani-AGBPP	NP-6888-A	AS-03	39548.2	96335.5	37589	96335.5	-3,134.72	0.00	-4,70,208	0	-4,70,208
TOTAL												-12,81,736
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95761.4	99120.1	95762.6	99120.1	0.86	0.00	130	0	130
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	620.8	99951.6	618.4	99951.6	-1.15	0.00	-173	0	-173
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306	24533.3	12306.2	0.00	0.01	0	2	2
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99089.3	99898.5	99088.2	99898.5	-0.40	0.00	59	0	59
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19260.1	382.1	19274.4	382.1	5.15	0.00	-772	0	-772
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	16855.7	381.5	16869.8	381.5	5.08	0.00	-761	0	-761
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52887.1	99431.7	52880.2	99431.7	-2.48	0.00	373	0	373
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	4043.1	99964	4048.2	99964	2.45	0.00	367	0	367
TOTAL												-776


 Signature of the official
 Date: 31-01-2021
 Place: Dispur, Assam
 Name: Mr. [Name]
 Designation: [Designation]

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	0	0	0	0	0.00	0.00	0	0	0
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99979.2	19990.1	99979.2	19995.4	0.00	3.82	0	572	572
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	89382.1	90862.4	89120.3	0.00	-418.88	0	-62,832	-62,832
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87392.9	96037.8	87392.9	96037.8	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	79721.2	99954	77725	99954	-7,258.91	0.00	-10,88,836	0	-10,88,836
TOTAL				1706	99864	2372.7	99864	2,424.36	0.00	3,63,655	0	3,63,655
												-7,87,441
MIZORAM	132kV LAUNGUAL-AIZWAL PG	NP-8504-A	MZ-02	35430.7	75017.2	35443.7	76547.8	4.68	551.02	-702	82,652	81,950
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79463.9	49520.3	79442.7	49494.9	-7.63	-9.14	1,145	-1,372	-227
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69274.5	86580.6	69276.2	86525	0.61	-20.02	92	3,002	3,094
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96728.6	31558.3	96725	31618.1	-2.59	43.06	-389	-6,458	-6,847
TOTAL												77,971
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15214.1	6880.8	15218.1	6883.5	1.44	0.97	-216	146	-70
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70170.7	1561	70186.5	1561.1	11.38	0.07	-1,706	11	-1,696
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9636.4	99004.2	9623.4	99004.2	-4.68	0.00	702	0	702
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99873.4	44140.8	99875.1	0.00	0.61	0	-92	-92
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99865.2	43596.8	99867.4	0.00	0.79	0	-119	-119
TOTAL												-1,274
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97343.2	84695.4	97343.2	84645.6	0.00	-35.86	0	-5,378	-5,378
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	74620.9	99771.4	74620.9	99771.4	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	72902.8	99782.1	72902.8	99782.1	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	11858.7	99635.8	11840.9	99635.8	-17.09	0.00	-2,563	0	-2,563
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	50126.2	93757.3	50127.7	93757.3	1.44	0.00	216	0	216
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	66938.5	73453.5	67626.5	73453.5	825.60	0.00	1,23,840	0	1,23,840
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	1288.3	99999.7	3586.7	99999.7	2,206.46	0.00	-3,30,970	0	-3,30,970
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	2691.1	0.1	6839.7	0.1	3,982.66	0.00	-5,97,398	0	-5,97,398
TOTAL												-8,12,254

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the meter readings are taken as per the meter readings available at the time of the audit.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 25-01-2021 to 31-01-2021 REV-01

for the period 25-07-2021 to 31-07-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76480.5	96302.8	76475.2	96300.5	-2.544	-1.104	-382	166	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94728.6	99225	94728	99221.6	-0.288	-1.632	-43	245	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	0	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95523.3	99822.6	95521.3	99822.6	-0.96	0	-144	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	0	0	0	0	0	0	0
			NP-8491-A	ME-05	96439.8	99797.1	96437.7	99797.1	-1.008	0	-151	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91533.5	99993.6	91528	99993.6	-2.64	0	-396	0	0
			NP-8384-A	ME-01	95666.3	68631.8	95666.3	68613.9	0	-8.592	0	1,289	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2671.3	5482.9	2793.9	5482.9	58.848	0	8,827	0	266
			NP-9071-A	ME-16	76240.6	28702.1	76236.9	28640.3	-1.776	-29.664	-266	4,450	
TOTAL													266
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1374.1	0.1	1384.9	0.1	5.184	0	778	0	0
			NP-6892-B	TR-06	76917.6	3378.4	76917.6	3370.9	0	-0.72	0	108	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	95137.1	99471.9	95123.9	99471.9	-6.336	0	-950	0	0
			NP-9947-A	NG-02	272.9	99998.9	271.9	99998.9	-0.3	0	-45	0	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 (Signature)
 (Signature)
 (Signature)
 (Signature)

**Reactive Energy (VArH) Charge Statement
for the period 01-02-2021 to 07-02-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	32,793	0
ASSAM	0	12,87,570
MANIPUR	0	7,092
MEGHALAYA	0	9,09,263
MIZORAM	21,022	0
NAGALAND	0	599
TRIPURA	0	5,17,865

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	446
NAGALAND	MANIPUR	18
TRIPURA	ASSAM	0


 Director, Assam
 Energy Department
 Dispur, Assam
 781 005

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 01-02-2021 to 07-02-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	77901	25.5	79188.1	25.5	231.68	0.00	34,752	0	34,752
	132kV Khupi-Balipara	NP-9606-A	AS-55	59617.6	79.9	59193.9	79.9	-152.53	0.00	22,880	0	22,880
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	80266.7	1.5	80132.2	0.00	-96.84	0	-14,526	-14,526
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	1944.1	439	1949.7	0.00	2.02	0	302	302
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1866.1	498	1871.4	0.00	1.91	0	286	286
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	45573.4	166.2	45694.5	166.2	58.13	0.00	-8,719	0	-8,719
	132kV Chimpur-Pare	NP-9411-A	PA-05	611.5	7	641.8	7	14.54	0.00	-2,182	0	-2,182
TOTAL												32,793
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	41013.1	75.7	41530.9	75.7	828.48	0.00	-1,24,272	0	-1,24,272
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	61026	6862.5	62700.9	6862.5	2,679.84	0.00	-4,01,976	0	-4,01,976
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70157.5	98617.2	70228.9	98617.2	71.40	0.00	10,710	0	10,710
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	69252.8	99217.8	69433	99217.8	180.20	0.00	27,030	0	27,030
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27719.9	63.9	27937.7	63.9	348.48	0.00	-52,272	0	-52,272
	220kV MARIANI - MISA	NP-9700-A	AS-04	8678.3	99920.1	8672.6	99920.1	-9.12	0.00	-1,368	0	-1,368
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	52097.3	82268.2	51960.4	82268.1	-98.57	-0.07	-14,785	11	-14,774
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7358.9	1561.6	7374.9	0.00	11.52	0	1,728	1,728
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99502.1	95064.4	99500.8	95003.3	-0.47	-22.00	-70	3,299	3,229
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19908.7	3240.4	19908.7	3240.4	0.00	0.00	0	0	0
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87525.6	91178.2	87525	91178.2	-0.22	0.00	-32	0	-32
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91789.1	99935.3	91788.8	99935.3	-0.11	0.00	-16	0	-16
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93835.2	99981.3	93835.2	99981.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89299.4	99986.8	89297.2	99986.8	-0.79	0.00	-119	0	-119
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28907.5	98978.9	28907.5	98980.9	0.00	0.72	0	108	108
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99987.3	5.5	99987.3	0.00	0.00	0	0	0
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1236.1	0.1	1507.1	0.00	1,970.91	0	-2,95,636	-2,95,636
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	437.9	82394.2	429.7	0.00	-2.95	0	443	443
	220kV Mariani-AGBPP	NP-6888-A	AS-03	37589	96335.5	35754.2	96335.5	-2,935.68	0.00	-4,40,352	0	-4,40,352
TOTAL												-12,87,570
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95762.6	99120.1	95750	99120.1	-9.07	0.00	-1,361	0	-1,361
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	618.4	99951.6	599.4	99951.6	-9.12	0.00	-1,368	0	-1,368
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306.2	24533.3	12306.2	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99088.2	99898.5	99088.2	99898.5	0.00	0.00	0	0	0
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19274.4	382.1	19322.5	382.1	17.32	0.00	-2,597	0	-2,597
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	16869.8	381.5	16915.9	381.5	16.60	0.00	-2,489	0	-2,489
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52880.2	99431.7	52856	99431.7	-8.71	0.00	1,307	0	1,307
TOTAL												-7,092

[Signature]
 Director
 Energy Division
 Manipal Engineering College
 Manipal, Karnataka
 575001

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95887.1	81176.7	95887.1	81176.7	0.00	0.00	0	0	0
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99979.2	19995.4	99979.2	19996.4	0.00	0.72	0	108	108
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	89120.3	90862.4	88850.8	0.00	-431.20	0	-64,680	-64,680
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87392.9	96037.8	87392.9	96037.8	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	77725	99954	75417.1	99954	-8,392.36	0.00	-12,58,855	0	-12,58,855
TOTAL												-9,09,263
MIZORAM	132kV LAUNGUAL-AIZWAL PG	NP-8504-A	MZ-02	35443.7	76547.8	35443.7	76952.1	0.00	145.55	0	21,832	21,832
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79442.7	49494.9	79442.7	49510.3	0.00	5.54	0	832	832
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69276.2	86525	69276.2	86515.4	0.00	-3.46	0	518	518
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96725	31618.1	96725	31638.1	0.00	14.40	0	-2,160	-2,160
TOTAL												21,022
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15218.1	6883.5	15218.1	6891.9	0.00	3.02	0	454	454
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70186.5	1561.1	70186.5	1562.4	0.00	0.94	0	140	140
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9623.4	99004.2	9623.4	99004.4	0.00	0.07	0	11	11
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99875.1	44140.8	99885.8	0.00	3.85	0	-578	-578
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99867.4	43596.8	99879	0.00	4.18	0	-626	-626
TOTAL												-599
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97343.2	84645.6	97343.2	84644.6	0.00	-0.72	0	-108	-108
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	74620.9	99771.4	74433.4	99771.4	-67.50	0.00	-10,125	0	-10,125
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	72902.8	99782.1	72701.4	99782.1	-72.50	0.00	-10,876	0	-10,876
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	11840.9	99635.8	11704.7	99635.8	-130.75	0.00	-19,613	0	-19,613
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	50127.7	93757.3	50028.2	93757.3	-95.52	0.00	-14,328	0	-14,328
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	67626.5	73453.5	68002.1	73453.5	450.72	0.00	67,608	0	67,608
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	3586.7	99999.7	4526.1	99999.7	901.82	0.00	-1,35,274	0	-1,35,274
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	6839.7	0.1	8848.2	0.1	1,928.16	0.00	-2,89,224	0	-2,89,224
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	0.1	99999.9	459.2	99999.9	440.74	0.00	-66,110	0	-66,110
TOTAL												-5,17,865

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director, Energy
 Ministry, Government of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 01-02-2021 to 07-02-2021 REV-01

for the period 01-02-2021 to 01-02-2021 REV-01									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	50575	359.1	50592	359.1	8.16	0	1,224	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	50575	359.1	50592	359.1	8.16	0	1,224	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	0	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95521.3	99822.6	95520.5	99822.6	-0.384	0	-58	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	0	0	0	0	0	0	0
			NP-8491-A	ME-05	96437.7	99797.1	96436.9	99797.1	-0.384	0	-58	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91528	99993.6	91479.8	99993.6	-23.136	0	-3,470	0	0
			NP-8384-A	ME-01	95666.3	68613.9	95666.3	68588.7	0	-12.096	0	1,814	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2793.9	5482.9	2914.5	5482.9	57.888	0	8,683	0	446
			NP-9071-A	ME-16	76236.9	28640.3	76230.7	28602.1	-2.976	-18.336	-446	2,750	
TOTAL													446
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1384.9	0.1	1514.3	0.1	62.112	0	9,317	0	0
			NP-6892-B	TR-06	76917.6	3370.9	76917.6	3370.9	0	0	0	0	
TOTAL													0
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	95123.9	99471.9	95123.9	99439.4	0	-15.6	0	2,340	18
			NP-9947-A	NG-02	271.9	99998.9	271.9	99999.3	0	0.12	0	-18	
TOTAL													18

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

[Signature]
 Director, Energy
 Department, Government of India
 New Delhi

**Reactive Energy (VArH) Charge Statement
for the period 08-02-2021 to 14-02-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	7,371	0
ASSAM	0	11,48,045
MANIPUR	12,341	0
MEGHALAYA	0	7,74,395
MIZORAM	14,143	0
NAGALAND	0	4,504
TRIPURA	0	4,77,257

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	696


 (Signature)
 Name of the person
 Designation
 Date

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 08-02-2021 to 14-02-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	79188.1	25.5	80030.5	25.5	151.63	0.00	22,745	0	22,745
	132kV Khupi-Balipara	NP-9606-A	AS-55	59193.9	79.9	58883	79.9	-111.92	0.00	16,789	0	16,789
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	80132.2	1.5	79884.5	0.00	-178.34	0	-26,752	-26,752
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	1949.7	439	1965.3	0.00	5.62	0	842	842
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1871.4	498	1888.4	0.00	6.12	0	918	918
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	45694.5	166.2	45794.1	166.2	47.81	0.00	-7,171	0	-7,171
	132kV Chimpur-Pare	NP-9411-A	PA-05	641.8	7	641.8	7	0.00	0.00	0	0	0
TOTAL												7,371
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	41530.9	75.7	41912.5	75.7	610.56	0.00	-91,584	0	-91,584
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	62700.9	6862.5	64214.1	6862.5	2,421.12	0.00	-3,63,168	0	-3,63,168
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70228.9	98617.2	70496.7	98617.2	267.80	0.00	40,170	0	40,170
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	69433	99217.8	69840.3	99217.8	407.30	0.00	61,095	0	61,095
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	27937.7	63.9	28090.3	63.9	244.16	0.00	-36,624	0	-36,624
	220kV MARIANI - MISA	NP-9700-A	AS-04	8672.6	99920.1	8649.1	99920	-37.60	-0.16	-5,640	24	-5,616
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	51960.4	82268.1	51523.5	82268.1	-314.57	0.00	-47,185	0	-47,185
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7374.9	1561.6	7391.6	0.00	12.02	0	1,804	1,804
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99500.8	95003.3	99500.8	94949.9	0.00	-19.22	0	2,884	2,884
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19908.7	3240.4	19916.3	3240.5	1.37	0.02	-205	3	-203
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87525	91178.2	87530.2	91178.2	1.87	0.00	281	0	281
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91788.8	99935.3	91796.7	99935.3	2.84	0.00	427	0	427
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93835.2	99981.3	93826	99981.3	-3.31	0.00	-497	0	-497
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89297.2	99986.8	89252.7	99986.8	-16.02	0.00	-2,403	0	-2,403
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28907.5	98980.9	28907.7	98987.9	0.07	2.52	-11	378	367
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99987.3	5.5	99986.8	0.00	-3.64	0	545	545
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1507.1	0.1	1806.9	0.00	2,180.36	0	-3,27,055	-3,27,055
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	429.7	82394.2	190.5	0.00	-86.11	0	12,917	12,917
	220kV Mariani-AGBPP	NP-6888-A	AS-03	35754.2	96335.5	34111.7	96335.5	-2,628.00	0.00	-3,94,200	0	-3,94,200
TOTAL												-11,48,045
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95750	99120.1	95774.4	99120.1	17.57	0.00	2,635	0	2,635
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	599.4	99951.6	606.6	99951.6	3.46	0.00	518	0	518
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306.2	24533.3	12306.4	0.00	0.01	0	2	2
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99088.2	99898.5	99082.5	99898.5	-2.05	0.00	308	0	308
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19322.5	382.1	19405.6	382.1	29.92	0.00	-4,487	0	-4,487
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	16915.9	381.5	16998.4	381.5	29.70	0.00	-4,455	0	-4,455
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52856	99431.7	52580.4	99431.7	-99.22	0.00	14,882	0	14,882
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	4040.1	99964	4080.9	99964	19.58	0.00	2,938	0	2,938
TOTAL												12,341

(Signature)
 Director
 Energy Division
 Ministry of Power
 Government of India

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95887.1	81176.7	95893.5	81176.7	4.61	0.00	691	0	691
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99979.2	19996.4	99975	19998.2	-3.02	1.30	454	194	648
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88850.8	90862.4	88777.3	0.00	-117.60	0	-17,640	-17,640
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87392.9	96037.8	87391.4	96037.8	-2.40	0.00	360	0	360
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	75417.1	99954	73328.3	99954	-7,595.64	0.00	-11,39,345	0	-11,39,345
TOTAL												-7,74,395
MIZORAM	132kV LAUNGUAL-AIZWAL PG	NP-8504-A	MZ-02	35443.7	76952.1	35443.7	77125.5	0.00	62.42	0	9,364	9,364
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79442.7	49510.3	79441.9	49549.7	-0.29	14.18	43	2,128	2,171
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69276.2	86515.4	69269.7	86515.4	-2.34	0.00	-351	0	-351
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96725	31638.1	96752.4	31638.1	19.73	0.00	2,959	0	2,959
TOTAL												14,143
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15218.1	6891.9	15219.7	6917.7	0.58	9.29	-86	1,393	1,307
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70186.5	1562.4	70208	1572.8	15.48	7.49	-2,322	1,123	-1,199
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9623.4	99004.4	9618.9	99006.5	-1.62	0.76	243	113	356
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99885.8	44140.8	99932.6	0.00	16.85	0	-2,527	-2,527
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99879	43596.8	99924.2	0.00	16.27	0	-2,441	-2,441
TOTAL												-4,504
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97343.2	84644.6	97192.1	84644.6	-108.79	0.00	16,319	0	16,319
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	74433.4	99771.4	73869.4	99771.4	-203.04	0.00	-30,456	0	-30,456
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	72701.4	99782.1	72105.7	99782.1	-214.45	0.00	-32,168	0	-32,168
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	11704.7	99635.8	11604.6	99635.8	-96.10	0.00	-14,414	0	-14,414
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	50028.2	93757.3	49956.4	93757.3	-68.93	0.00	-10,339	0	-10,339
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68002.1	73453.5	68221.6	73453.5	263.40	0.00	39,510	0	39,510
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	4526.1	99999.7	5252.5	99999.7	697.34	0.00	-1,04,602	0	-1,04,602
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	8848.2	0.1	10169	0.1	1,267.97	0.00	-1,90,195	0	-1,90,195
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	459.2	99999.9	1097.1	99999.9	612.38	0.00	-91,858	0	-91,858
TOTAL												-4,77,257

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

Handwritten signature and stamp of the official.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 08-02-2021 to 14-02-2021 REV-01

for the period 01-01-2021 to 14-02-2021 REV-01									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76461.8	96300.5	76447.7	96300.5	-6.768	0	-1,015	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94727.5	99221.6	94721.1	99221.6	-3.072	0	-461	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	0	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95520.5	99822.6	95505.3	99822.6	-7.296	0	-1,094	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	0	0	0	0	0	0	0
			NP-8491-A	ME-05	96436.9	99797.1	96421.7	99797.1	-7.296	0	-1,094	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91479.8	99993.6	91219.8	99993.6	-124.8	0	-18,720	0	0
			NP-8384-A	ME-01	95666.3	68588.7	95666.3	68577.3	0	-5.472	0	821	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2914.5	5482.9	2952.4	5482.9	18.192	0	2,729	0	0
			NP-9071-A	ME-16	76230.7	28602.1	76252.6	28554.3	10.512	-22.944	1,577	3,442	
TOTAL													0
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1514.3	0.1	1739.2	0.1	107.952	0	16,193	0	696
			NP-6892-B	TR-06	76917.6	3370.9	76869.3	3370.9	-4.6368	0	-696	0	
TOTAL													696
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	95123.9	99439.4	95060.3	99384.4	-30.528	-26.4	-4,579	3,960	0
			NP-9947-A	NG-02	271.9	99999.3	106.1	99996.1	-49.74	-0.96	-7,461	144	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

Handwritten signature and stamp.

**Reactive Energy (VArH) Charge Statement
for the period 15-02-2021 to 21-02-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	7,942	0
ASSAM	0	12,21,463
MANIPUR	12,581	0
MEGHALAYA	0	6,69,576
MIZORAM	17,674	0
NAGALAND	0	1,350
TRIPURA	0	4,18,340

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	130


For the purpose of the statement
 this statement is prepared
 by the concerned
 person/department/office
 and is not to be used for any other purpose

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 15-02-2021 to 21-02-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	80030.5	25.5	80991.5	25.5	172.98	0.00	25,947	0	25,947
	132kV Khupi-Balipara	NP-9606-A	AS-55	58883	79.9	58447.2	79.9	-156.89	0.00	23,533	0	23,533
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	79884.5	1.5	79489.7	0.00	-284.26	0	-42,638	-42,638
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	1965.3	439	2003.9	0.00	13.90	0	2,084	2,084
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1888.4	498	1923.5	0.00	12.64	0	1,895	1,895
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	45794.1	166.2	45835.2	166.2	19.73	0.00	-2,959	0	-2,959
	132kV Chimpur-Pare	NP-9411-A	PA-05	641.8	7	640.7	7	-0.53	0.00	79	0	79
TOTAL												7,942

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	41912.5	75.7	42392.8	75.7	768.48	0.00	-1,15,272	0	-1,15,272
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	64214.1	6862.5	65579.5	6862.5	2,184.64	0.00	-3,27,696	0	-3,27,696
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70496.7	98617.2	70519.8	98617.2	23.10	0.00	3,465	0	3,465
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	69840.3	99217.8	70009.8	99217.8	169.50	0.00	25,425	0	25,425
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28090.3	63.9	28388.9	63.9	477.76	0.00	-71,664	0	-71,664
	220kV MARIANI - MISA	NP-9700-A	AS-04	8649.1	99920	8648.2	99919.7	-1.44	-0.48	-216	72	-144
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	51523.5	82268.1	51385.8	82268.1	-99.14	0.00	-14,872	0	-14,872
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7391.6	1561.6	7474.6	0.00	59.76	0	8,964	8,964
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99500.8	94949.9	99501.1	94890.4	0.11	-21.42	16	3,213	3,229
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19916.3	3240.5	19918.1	3240.5	0.32	0.00	-49	0	-49
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87530.2	91178.2	87526.4	91178.2	-1.37	0.00	-205	0	-205
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91796.7	99935.3	91793.4	99935.3	-1.19	0.00	-178	0	-178
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93826	99981.3	93825.1	99981.3	-0.32	0.00	-49	0	-49
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89252.7	99986.8	89245.4	99986.8	-2.63	0.00	-394	0	-394
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28907.7	98987.9	28907.8	98992.8	0.04	1.76	-5	265	259
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99986.8	5.5	99986.3	0.00	-3.64	0	545	545
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1806.9	0.1	2128.5	0.00	2,338.91	0	-3,50,836	-3,50,836
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	190.5	82394.2	99812.6	0.00	-136.04	0	20,407	20,407
	220kV Mariani-AGBPP	NP-6888-A	AS-03	34111.7	96335.5	32457.9	96335.5	-2,646.08	0.00	-3,96,912	0	-3,96,912
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	12.6	4.1	99961.8	4.1	-36.58	0.00	-5,486	0	-5,486
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	0.1	0.2	0.1	0.2	0.00	0.00	0	0	0
TOTAL												-12,21,463

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95774.4	99120.1	95809	99119.6	24.91	-0.36	3,737	54	3,791
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	606.6	99951.6	591	99950.7	-7.49	-0.43	-1,123	65	-1,058
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306.4	24533.3	12306.7	0.00	0.02	0	3	3
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99082.5	99898.5	99082.5	99898.5	0.00	0.00	0	0	0
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19405.6	382.1	19441.5	382.1	12.92	0.00	-1,939	0	-1,939
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	16998.4	381.5	17034.3	381.5	12.92	0.00	-1,939	0	-1,939
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52580.4	99431.7	52391.6	99431.7	-67.97	0.00	10,195	0	10,195
TOTAL												3,528
TOTAL												12,581

For the period 15-02-2021 to 21-02-2021
Rev-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95893.5	81176.7	95893.1	81175.8	-0.29	-0.65	-43	97	54
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99975	19998.2	99975	20005.3	0.00	5.11	0	767	767
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88777.3	90862.4	88684.7	0.00	-148.16	0	-22,224	-22,224
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391.4	96037.8	87391.1	96036.1	-0.48	-2.72	72	-408	-336
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	73328.3	99954	71449.8	99954	-6,830.91	0.00	-10,24,636	0	-10,24,636
TOTAL												-6,69,576
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35443.7	77125.5	35444.6	77416.3	0.32	104.69	-49	15,703	15,655
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79441.9	49549.7	79440	49590.6	-0.68	14.72	103	2,209	2,311
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69269.7	86515.4	69269.7	86510.4	0.00	-1.80	0	270	270
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96752.4	31638.1	96753.5	31644.4	0.79	4.54	119	-680	-562
TOTAL												17,674
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15219.7	6917.7	15222.3	6939.7	0.94	7.92	-140	1,188	1,048
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70208	1572.8	70217	1581.6	6.48	6.34	-972	950	-22
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9618.9	99006.5	9601.3	99005.6	-6.34	-0.32	950	-49	902
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99932.6	44140.8	99962.7	0.00	10.84	0	-1,625	-1,625
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99924.2	43596.8	99954.8	0.00	11.02	0	-1,652	-1,652
TOTAL												-1,350
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97192.1	84644.6	97192.1	84644.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	73869.4	99771.4	73702.2	99771.4	-60.19	0.00	-9,029	0	-9,029
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	72105.7	99782.1	71916.6	99782.1	-68.08	0.00	-10,211	0	-10,211
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	11604.6	99635.8	11365.2	99635.8	-229.82	0.00	-34,474	0	-34,474
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49956.4	93757.3	49813.1	93757.3	-137.57	0.00	-20,635	0	-20,635
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68221.6	73453.5	68323.9	73453.5	122.76	0.00	18,414	0	18,414
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	5252.5	99999.7	5759.4	99999.7	486.62	0.00	-72,994	0	-72,994
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	10169	0.1	11077	0.1	871.68	0.00	-1,30,752	0	-1,30,752
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	1097.1	99999.9	1708.3	0	586.75	0.10	-88,013	14	-87,998
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	686.6	99999.9	1048.9	99999.9	347.81	0.00	-52,171	0	-52,171
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	99999.9	99999.9	99934.1	99999.9	-63.17	0.00	-9,475	0	-9,475
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	0	99999.8	99937.4	99999.8	-60.10	0.00	-9,014	0	-9,014
TOTAL												-4,18,340

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 Director General
 Energy Department
 Government of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 15-02-2021 to 21-02-2021 REV-01

for the period 15-02-2021 to 21-02-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	99244	99984.8	99244	99984.8	0	0	0	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	97149.3	1692.7	97149.3	1692.7	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	0	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95505.3	99822.6	95494.9	99822.6	-4.992	0	-749	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	0	0	0	0	0	0	0
			NP-8491-A	ME-05	96421.7	99797.1	96411.2	99797.1	-5.04	0	-756	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91219.8	99993.6	91170.3	99993.6	-23.76	0	-3,564	0	0
			NP-8384-A	ME-01	95666.3	68577.3	95666.3	68566.5	0	-5.184	0	778	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2952.4	5482.9	2976.5	5482.9	11.568	0	1,735	0	0
			NP-9071-A	ME-16	76252.6	28554.3	76282.8	28510.7	14.496	-20.928	2,174	3,139	
TOTAL													0
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1739.2	0.1	1792.9	0.1	25.776	0	3,866	0	130
			NP-6892-B	TR-06	76869.3	3370.9	76860.3	3370.9	-0.864	0	-130	0	
TOTAL													130
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	95060.3	99384.4	94998.1	99382.6	-29.856	-0.864	-4,478	130	0
			NP-9947-A	NG-02	106.1	99996.1	99867.6	99982.9	-71.55	-3.96	-10,733	594	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


Sd/-
Regional Engineer
Electricity Department
Dispur, Assam

**Reactive Energy (VArH) Charge Statement
for the period 22-02-2021 to 28-02-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	11,044	0
ASSAM	0	9,56,136
MANIPUR	2,312	0
MEGHALAYA	0	6,14,751
MIZORAM	1,080	0
NAGALAND	8,802	0
TRIPURA	0	4,39,420

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	0
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	513


 Director, Energy
 Department
 Government of Assam
 Dispur, Assam 781 005

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 22-02-2021 to 28-02-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	80991.5	25.5	82164.6	25.5	211.16	0.00	31,674	0	31,674
	132kV Khupi-Balipara	NP-9606-A	AS-55	58447.2	79.9	57944	79.9	-181.15	0.00	27,173	0	27,173
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	79489.7	1.5	79192.5	0.00	-213.98	0	-32,098	-32,098
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	2003.9	439	2024.1	0.00	7.27	0	1,091	1,091
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1923.5	498	1942.6	0.00	6.88	0	1,031	1,031
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	45835.2	166.2	46087.8	166.2	121.25	0.00	-18,187	0	-18,187
	132kV Chimpur-Pare	NP-9411-A	PA-05	640.7	7	635.7	7	-2.40	0.00	360	0	360
TOTAL												11,044

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42392.8	75.7	42455.7	75.7	100.64	0.00	-15,096	0	-15,096
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	65579.5	6862.5	66668.5	6862.5	1,742.40	0.00	-2,61,360	0	-2,61,360
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70519.8	98617.2	70530.5	98617.2	10.70	0.00	1,605	0	1,605
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	70009.8	99217.8	70149.9	99217.8	140.10	0.00	21,015	0	21,015
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28388.9	63.9	28552.3	63.9	261.44	0.00	-39,216	0	-39,216
	220kV MARIANI - MISA	NP-9700-A	AS-04	8648.2	99919.7	8652.3	99919.7	6.56	0.00	984	0	984
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	51385.8	82268.1	51204	82268.1	-130.90	0.00	-19,634	0	-19,634
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7474.6	1561.6	7510	0.00	25.49	0	3,823	3,823
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99501.1	94890.4	99501.2	94795.7	0.04	-34.09	5	5,114	5,119
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19918.1	3240.5	19922.7	3240.5	0.83	0.00	-124	0	-124
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87526.4	91178.2	87510.2	91178.2	-5.83	0.00	-875	0	-875
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91793.4	99935.3	91780.5	99935.3	-4.64	0.00	-697	0	-697
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93825.1	99981.3	93817.4	99981.3	-2.77	0.00	-416	0	-416
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89245.4	99986.8	89219.4	99986.8	-9.36	0.00	-1,404	0	-1,404
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28907.8	98992.8	28908.2	99020.8	0.14	10.08	-22	1,512	1,490
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99986.3	5.5	99984.9	0.00	-10.18	0	1,527	1,527
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	2128.5	0.1	2369.5	0.00	1,752.73	0	-2,62,909	-2,62,909
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	99812.6	82394.2	99821.7	0.00	-356.72	0	53,509	53,509
	220kV Mariani-AGBPP	NP-6888-A	AS-03	32457.9	96335.5	30638.2	96335.5	-2,911.52	0.00	-4,36,728	0	-4,36,728
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	99961.8	4.1	99770.4	4.1	-137.81	0.00	-20,671	0	-20,671
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	0.1	0.2	129	0.2	92.81	0.00	13,921	0	13,921
TOTAL												-9,56,136

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95809	99119.6	95809.1	99120.2	0.07	0.43	11	-65	-54
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	591	99950.7	582.2	99944.6	-4.22	-2.93	-634	439	-194
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306.7	24533.3	12306.8	0.00	0.01	0	1	1
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99082.5	99898.5	99082.5	99898.5	0.00	0.00	0	0	0
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19441.5	382.1	19470.6	382.2	10.48	0.04	-1,571	5	-1,566
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17034.3	381.5	17063.4	381.5	10.48	0.00	-1,571	0	-1,571
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52391.6	99431.7	52284.5	99429.3	-38.56	-0.86	5,783	-130	5,654
TOTAL												2,312


 Signature of the official
 Date: 28/02/2021
 Place: Dispur, Assam
 Designation:

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95893.1	81175.8	95893.1	81176.2	0.00	0.29	0	-43	-43
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99975	20005.3	99975	20001.1	0.00	-3.02	0	-454	-454
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88684.7	90862.4	88610.9	0.00	-118.08	0	-17,712	-17,712
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391.1	96036.1	87391.1	96034.6	0.00	-2.40	0	-360	-360
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	71449.8	99954	69933.5	99954	-5,513.82	0.00	-8,27,073	0	-8,27,073
TOTAL								1,539.27	0.00	2,30,891	0	-6,14,751

MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35444.6	77416.3	35446.6	77438.2	0.72	7.88	-108	1,183	1,075
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79440	49590.6	79437.1	49593	-1.04	0.86	157	130	286
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69269.7	86510.4	69269.7	86510.4	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96753.5	31644.4	96750.9	31644.4	-1.87	0.00	-281	0	-281
TOTAL												1,080

NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15222.3	6939.7	15223.2	7084.8	0.32	52.24	-49	7,835	7,787
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70217	1581.6	70222.8	1674	4.18	66.53	-626	9,979	9,353
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9601.3	99005.6	9594.8	98907.1	-2.34	-35.46	351	-5,319	-4,968
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99962.7	44140.8	99994.5	0.00	11.45	0	-1,717	-1,717
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99954.8	43596.8	99985.4	0.00	11.02	0	-1,652	-1,652
TOTAL												8,802

TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97192.1	84644.6	97192.1	84644.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	76442.7	96300.5	76442.3	96300.5	-0.14	0.00	-22	0	-22
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	76442.7	96300.5	76442.3	96300.5	-0.14	0.00	-22	0	-22
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	11365.2	99635.8	10971.2	99635.8	-378.24	0.00	-56,736	0	-56,736
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49813.1	93757.3	49547.1	93757.3	-255.36	0.00	-38,304	0	-38,304
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68323.9	73453.5	68511	73453.5	224.52	0.00	33,678	0	33,678
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	5759.4	99999.7	6201.4	99999.7	424.32	0.00	-63,648	0	-63,648
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	11077	0.1	12099.5	0.1	981.60	0.00	-1,47,240	0	-1,47,240
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	1708.3	0	2592.1	0	848.45	0.00	-1,27,267	0	-1,27,267
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	1048.9	99999.9	1325.7	99999.9	265.73	0.00	-39,859	0	-39,859
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-4,39,420

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the meter reading is taken as per the meter reading provided by the beneficiary.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 22-02-2021 to 28-02-2021 REV-01

for the period 22-02-2021 to 28-02-2021 REV-01									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76442.7	96300.5	76442.3	96300.5	-0.192	0	-29	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94721	99221.4	94721	99220.5	0	-0.432	0	65	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	0	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95494.9	99822.6	95493.6	99822.6	-0.624	0	-94	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	0	0	0	0	0	0	0
			NP-8491-A	ME-05	96411.2	99797.1	96409.9	99797.1	-0.624	0	-94	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91170.3	99993.6	91062.1	99993.6	-51.936	0	-7,790	0	0
			NP-8384-A	ME-01	95666.3	68566.5	95666.3	68552	0	-6.96	0	1,044	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2976.5	5482.9	2995.3	5482.9	9.024	0	1,354	0	0
			NP-9071-A	ME-16	76282.8	28510.7	76282.8	28438.4	0	-34.704	0	5,206	
TOTAL													0
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1792.9	0.1	1989.3	0.1	94.272	0	14,141	0	513
			NP-6892-B	TR-06	76860.3	3370.9	76824.7	3370.7	-3.4176	-0.0192	-513	3	
TOTAL													513
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94998.1	99382.6	94996.3	99377.1	-0.864	-2.64	-130	396	0
			NP-9947-A	NG-02	99867.6	99982.9	99852.7	99839.2	-4.47	-43.11	-671	6,467	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

[Signature]
 Director, Energy
 Ministry, Government of India
 New Delhi

**Reactive Energy (VArH) Charge Statement
for the period 01-03-2021 to 07-03-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	2,615
ASSAM	0	7,28,830
MANIPUR	13,329	0
MEGHALAYA	0	5,71,051
MIZORAM	12,080	0
NAGALAND	0	7,868
TRIPURA	0	2,44,562

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	20,786
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	842


 (Name of the official)
 Designation
 Date: 01/03/2021

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 01-03-2021 to 07-03-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	82164.6	25.5	83334	25.5	210.49	0.00	31,574	0	31,574
	132kV Khupi-Balipara	NP-9606-A	AS-55	57944	79.9	57662.4	79.9	-101.38	0.00	15,206	0	15,206
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	79192.5	1.5	78913.5	0.00	-200.88	0	-30,132	-30,132
	Nirjuli-TRF 1	NP-9661-A	AR-01	439	2024.1	439.1	2027.1	0.04	1.08	-5	162	157
	Nirjuli-TRF 2	NP-9662-A	AR-02	498	1942.6	498.1	1945.6	0.04	1.08	-5	162	157
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	46087.8	166.2	46328.2	166.3	115.39	0.05	-17,309	7	-17,302
	132kV Chimpur-Pare	NP-9411-A	PA-05	635.7	7	667.3	7	15.17	0.00	-2,275	0	-2,275
TOTAL												-2,615

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42455.7	75.7	42479.1	75.7	37.44	0.00	-5,616	0	-5,616
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	66668.5	6862.5	67388	6862.5	1,151.20	0.00	-1,72,680	0	-1,72,680
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70530.5	98617.2	70573.6	98617.2	43.10	0.00	6,465	0	6,465
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	70149.9	99217.8	70280.4	99217.8	130.50	0.00	19,575	0	19,575
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28552.3	63.9	28549.7	63.9	-4.16	0.00	624	0	624
	220kV MARIANI - MISA	NP-9700-A	AS-04	8652.3	99919.7	8658.3	99918.5	9.60	-1.92	1,440	288	1,728
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	51204	82268.1	50823.6	82268.1	-273.89	0.00	-41,083	0	-41,083
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7510	1561.6	7581.7	0.00	51.62	0	7,744	7,744
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99501.2	94795.7	99481.3	94745.6	-7.16	-18.04	-1,075	2,705	1,631
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19922.7	3240.5	19951.9	3240.6	5.26	0.02	-788	3	-786
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87510.2	91178.2	87427.2	91178.2	-29.88	0.00	-4,482	0	-4,482
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91780.5	99935.3	91701.3	99935.3	-28.51	0.00	-4,277	0	-4,277
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93817.4	99981.3	93772	99981.3	-16.34	0.00	-2,452	0	-2,452
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89219.4	99986.8	89132	99986.8	-31.46	0.00	-4,720	0	-4,720
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28908.2	99020.8	28909.8	99042.6	0.58	7.85	-86	1,177	1,091
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99984.9	5.5	99984.7	0.00	-1.45	0	218	218
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	2369.5	0.1	2474.8	0.00	765.82	0	-1,14,873	-1,14,873
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82394.2	98821.7	82365.7	98305.3	-10.26	-185.90	-1,539	27,886	26,347
	220kV Mariani-AGBPP	NP-6888-A	AS-03	30638.2	96335.5	28837.8	96335.5	-2,880.64	0.00	-4,32,096	0	-4,32,096
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	99770.4	4.1	99529.5	4.1	-173.45	0.00	-26,017	0	-26,017
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	129	0.2	266.3	0.2	98.86	0.00	14,828	0	14,828
TOTAL												-7,28,830

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95809.1	99120.2	95829.5	99121.2	14.69	0.72	2,203	-108	2,095
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	582.2	99944.6	572.4	99940.8	-4.70	-1.82	-706	274	-432
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.3	12306.8	24533.6	12306.9	0.02	0.01	-3	1	-2
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99082.5	99898.5	99081.3	99898.5	-0.43	0.00	65	0	65
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19470.6	382.2	19513.1	382.2	15.30	0.00	-2,295	0	-2,295
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17063.4	381.5	17105.6	381.5	15.19	0.00	-2,279	0	-2,279
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52284.5	99429.3	52020.3	99429.2	-95.11	-0.04	14,267	-5	14,261
TOTAL												13,329

For the period 01-03-2021 to 07-03-2021
REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95893.1	81176.2	95903.7	81176.2	7.63	0.00	1,145	0	1,145
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99975	20001.1	99974	20001.2	-0.72	0.07	108	11	119
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88610.9	90862.4	88603.3	0.00	-12.16	0	-1,824	-1,824
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391.1	96034.6	87391.1	96034.6	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	69933.5	99954	68645.1	99954	-4,685.09	0.00	-7,02,764	0	-7,02,764
TOTAL												-5,71,051
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35446.6	77438.2	35469.8	77538.8	8.35	36.22	-1,253	5,432	4,180
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79437.1	49593	79420.1	49632.6	-6.12	14.26	918	2,138	3,056
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69269.7	86510.4	69253.3	86510.3	-5.90	-0.04	-886	5	-880
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96750.9	31644.4	96803.9	31644.4	38.16	0.00	5,724	0	5,724
TOTAL												12,080
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15223.2	7084.8	15234.1	7112.5	3.92	9.97	-589	1,496	907
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70222.8	1674	70281.4	1683	42.19	6.48	-6,329	972	-5,357
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9594.8	98907.1	9537.3	98906.6	-20.70	-0.18	3,105	-27	3,078
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	99994.5	44140.8	54.3	0.00	21.53	0	-3,229	-3,229
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	99985.4	43596.8	45.9	0.00	21.78	0	-3,267	-3,267
TOTAL												-7,868
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97192.1	84644.6	97127.4	84644.6	-46.58	0.00	6,988	0	6,988
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10971.2	99635.8	10731.4	99635.8	-230.21	0.00	-34,531	0	-34,531
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49547.1	93757.3	49386.5	93757.3	-154.18	0.00	-23,126	0	-23,126
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68511	73453.5	68544	73279.2	39.60	-209.16	5,940	31,374	37,314
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6201.4	99999.7	6461.8	99999.7	249.98	0.00	-37,498	0	-37,498
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	12099.5	0.1	12765.1	0.1	638.98	0.00	-95,846	0	-95,846
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	2592.1	0	3354.9	0	732.29	0.00	-1,09,843	0	-1,09,843
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	1325.7	99999.9	1526.2	99999.9	192.48	0.00	-28,872	0	-28,872
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	100.3	99999.9	249	99999.9	142.75	0.00	21,413	0	21,413
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	91.5	99999.8	226.5	99999.8	129.60	0.00	19,440	0	19,440
TOTAL												-2,44,562

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the meter reading is taken as per the meter reading provided by the beneficiary.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 01-03-2021 to 07-03-2021 REV-01

for the period 01-03-2021 to 01-03-2021 REV-01									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	0	0.3	99991.2	0.3	-4.224	0	-634	0	0
			NP-8473-A	ME-07	95493.6	99822.6	95467.6	99822.1	-12.48	-0.24	-1,872	36	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	0	0	99994.2	0	-2.784	0	-418	0	0
			NP-8491-A	ME-05	96409.9	99797.1	96383.9	99796.6	-12.48	-0.24	-1,872	36	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	91062.1	99993.6	90958.1	99993.6	-49.92	0	-7,488	0	-50
			NP-8384-A	ME-01	95666.3	68552	95667	68546.1	0.336	-2.832	50	425	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2995.3	5482.9	2593.7	5482.9	-192.768	0	-28,915	0	-20,736
			NP-9071-A	ME-16	76282.8	28438.4	76570.8	28363.3	138.24	-36.048	20,736	5,407	
TOTAL													-20,786
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	1989.3	0.1	2289.4	0.1	144.048	0	21,607	0	842
			NP-6892-B	TR-06	76824.7	3370.7	76766.2	3370.7	-5.616	0	-842	0	
TOTAL													842
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94996.3	99377.1	94938.4	99373.9	-27.792	-1.536	-4,169	230	0
			NP-9947-A	NG-02	99852.7	99839.2	99819	99838.7	-10.11	-0.15	-1,517	23	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director, Electricity, Assam
 100, Dibrugarh Road, Dibrugarh
 Assam - 786001

**Reactive Energy (VArH) Charge Statement
for the period 08-03-2021 to 14-03-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	2,226
ASSAM	0	6,26,189
MANIPUR	5,952	0
MEGHALAYA	0	5,48,113
MIZORAM	8,888	0
NAGALAND	0	4,471
TRIPURA	0	17,906

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	13,630
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	526
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	940



 Director
 Energy
 Department
 Government of Assam
 Dispur, Assam

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 08-03-2021 to 14-03-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	83334	25.5	84852.3	25.5	273.29	0.00	40,994	0	40,994
	132kV Khupi-Balipara	NP-9606-A	AS-55	57662.4	79.9	57150.6	79.9	-184.25	0.00	27,637	0	27,637
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	78913.5	1.5	78519.5	0.00	-283.68	0	-42,552	-42,552
	Nirjuli-TRF 1	NP-9661-A	AR-01	439.1	2027.1	439.1	2031.8	0.00	1.69	0	254	254
	Nirjuli-TRF 2	NP-9662-A	AR-02	498.1	1945.6	498.1	1949.8	0.00	1.51	0	227	227
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	46328.2	166.3	46679.3	166.3	168.53	0.00	-25,279	0	-25,279
	132kV Chimpur-Pare	NP-9411-A	PA-05	667.3	7	716	7	23.38	0.00	-3,506	0	-3,506
TOTAL												-2,226

ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42479.1	75.7	42499.6	75.7	32.80	0.00	-4,920	0	-4,920
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	67388	6862.5	68215.2	6862.5	1,323.52	0.00	-1,98,528	0	-1,98,528
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70573.6	98617.2	70581	98617.2	7.40	0.00	1,110	0	1,110
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	70280.4	99217.8	70334.1	99217.8	53.70	0.00	8,055	0	8,055
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28549.7	63.9	28595	63.9	72.48	0.00	-10,872	0	-10,872
	220kV MARIANI - MISA	NP-9700-A	AS-04	8658.3	99918.5	8656.9	99918.5	-2.24	0.00	-336	0	-336
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	50823.6	82268.1	50215	82268.1	-438.19	0.00	-65,729	0	-65,729
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7581.7	1561.6	7588.6	0.00	4.97	0	745	745
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99481.3	94745.6	99481.2	94647.8	-0.04	-35.21	-5	5,281	5,276
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19951.9	3240.6	19970.4	3240.6	3.33	0.00	-500	0	-500
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87427.2	91178.2	87299	91178.2	-46.15	0.00	-6,923	0	-6,923
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91701.3	99935.3	91577.5	99935.3	-44.57	0.00	-6,685	0	-6,685
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93772	99981.3	93640.6	99981.3	-47.30	0.00	-7,096	0	-7,096
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	89132	99986.8	88920.1	99986.8	-76.28	0.00	-11,443	0	-11,443
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28909.8	99042.6	28911	99043.1	0.43	0.18	-65	27	-38
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99984.7	5.5	99982.7	0.00	-14.55	0	2,182	2,182
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	2474.8	0.1	2401.1	0.00	-536.00	0	80,400	80,400
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82365.7	98305.3	82291.3	98104	-26.78	-72.47	-4,018	10,870	6,853
	220kV Mariani-AGBPP	NP-6888-A	AS-03	28837.8	96335.5	27160.3	96335.5	-2,684.00	0.00	-4,02,600	0	-4,02,600
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	99529.5	4.1	99241.3	4.1	-207.50	0.00	-31,126	0	-31,126
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	266.3	0.2	413.8	99999.7	106.20	-0.36	15,930	54	15,984
TOTAL												-6,26,189

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95829.5	99121.2	95830.6	99121.2	0.79	0.00	119	0	119
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	572.4	99940.8	559.1	99940.8	-6.38	0.00	-958	0	-958
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.6	12306.9	24533.7	12306.9	0.01	0.00	-1	0	-1
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99081.3	99898.5	99054.1	99898.5	-9.79	0.00	1,469	0	1,469
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19513.1	382.2	19548.8	382.2	12.85	0.00	-1,928	0	-1,928
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17105.6	381.5	17140.6	381.5	12.60	0.00	-1,890	0	-1,890
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	52020.3	99429.2	51858.1	99429.2	-58.39	0.00	8,759	0	8,759
TOTAL												5,952

For the period 08-03-2021 to 14-03-2021
REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95903.7	81176.2	95890.7	81174.6	-9.36	-1.15	-1,404	173	-1,231
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99974	20001.2	99975.9	20011.3	1.37	7.27	-205	1,091	886
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88603.3	90862.4	88579.8	0.00	-37.60	0	-5,640	-5,640
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391.1	96034.6	87391.1	96034.6	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	68645.1	99954	67621.6	99954	-3,721.82	0.00	-5,58,273	0	-5,58,273
TOTAL												-5,48,113
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35469.8	77538.8	35469.8	77558.5	0.00	7.09	0	1,064	1,064
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79420.1	49632.6	79420.1	49633	0.00	0.14	0	22	22
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69253.3	86510.3	69239.8	86510.3	-4.86	0.00	-729	0	-729
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96803.9	31644.4	96882.9	31644.4	56.88	0.00	8,532	0	8,532
TOTAL												8,888
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15234.1	7112.5	15240.5	7114	2.30	0.54	-346	81	-265
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70281.4	1683	70305.9	1683.1	17.64	0.07	-2,646	11	-2,635
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9537.3	98906.6	9516.6	98906.6	-7.45	0.00	1,118	0	1,118
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.8	54.3	44141.1	78.8	0.11	8.82	16	-1,323	-1,307
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	45.9	43597	71.7	0.07	9.29	11	-1,393	-1,382
TOTAL												-4,471
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97127.4	84644.6	97127.4	84644.6	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10731.4	99635.8	10588.4	99635.8	-137.28	0.00	-20,592	0	-20,592
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49386.5	93757.3	49290.7	93757.3	-91.97	0.00	-13,795	0	-13,795
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68544	73279.2	68585.9	72538.1	50.28	-889.32	7,542	1,33,398	1,40,940
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6461.8	99999.7	6630.6	99999.7	162.05	0.00	-24,307	0	-24,307
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	12765.1	0.1	13119.9	0.1	340.61	0.00	-51,091	0	-51,091
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	3354.9	0	3785.4	0	413.28	0.00	-61,992	0	-61,992
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	1526.2	99999.9	1644.5	99999.9	113.57	0.00	-17,035	0	-17,035
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	249	99999.9	358.6	99999.9	105.22	0.00	15,782	0	15,782
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	226.5	99999.8	325	99999.8	94.56	0.00	14,184	0	14,184
TOTAL												-17,906

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

[Handwritten Signature]
 Director, Energy
 Department
 Government of India
 New Delhi

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 08-03-2021 to 14-03-2021 REV-01

for the period 08-03-2021 to 14-03-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76433.9	96300.5	76430.9	96300.2	-1.44	-0.144	-216	22	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94720.2	99220.2	94719.9	99218.2	-0.144	-0.96	-22	144	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99991.2	0.3	99981.4	0.3	-4.704	0	-706	0	0
			NP-8473-A	ME-07	95467.6	99822.1	95461.4	99822.1	-2.976	0	-446	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99994.2	0	99987.7	0	-3.12	0	-468	0	0
			NP-8491-A	ME-05	96383.9	99796.6	96374.8	99796.6	-4.368	0	-655	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90958.1	99993.6	90831.3	99993.6	-60.864	0	-9,130	0	0
			NP-8384-A	ME-01	95667	68546.1	95667	68545.8	0	-0.144	0	22	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2593.7	5482.9	2298	5482.9	-141.936	0	-21,290	0	-13,630
			NP-9071-A	ME-16	76570.8	28363.3	76760.1	28285.9	90.864	-37.152	13,630	5,573	
TOTAL													-13,630
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	2289.4	0.1	2593.7	0.1	146.064	0	21,910	0	940
			NP-6892-B	TR-06	76766.2	3370.7	76700.9	3370.6	-6.2688	-0.0096	-940	1	
TOTAL													940
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94938.4	99373.9	94931.1	99373.9	-3.504	0	-526	0	-526
			NP-9947-A	NG-02	99819	99838.7	99836.8	99838.7	5.34	0	801	0	
TOTAL													-526

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director, Electricity
 Meghalaya
 Discom
 Shillong

**Reactive Energy (VArH) Charge Statement
for the period 15-03-2021 to 21-03-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	11,543
ASSAM	0	40,064
MANIPUR	12,779	0
MEGHALAYA	0	5,33,999
MIZORAM	13,700	0
NAGALAND	2,419	0
TRIPURA	0	1,09,163

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	11,700
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	158
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	43


 Director, Energy
 Department
 Government of Assam
 Dispur, Assam

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 15-03-2021 to 21-03-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	84852.3	25.5	85966.4	25.5	200.54	0.00	30,081	0	30,081
	132kV Khupi-Balipara	NP-9606-A	AS-55	57150.6	79.9	56869.9	79.9	-101.05	0.00	15,158	0	15,158
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	78519.5	1.5	78110.3	0.00	-294.62	0	-44,194	-44,194
	Nirjuli-TRF 1	NP-9661-A	AR-01	439.1	2031.8	439.1	2036.2	0.00	1.58	0	238	238
	Nirjuli-TRF 2	NP-9662-A	AR-02	498.1	1949.8	498.1	1953.5	0.00	1.33	0	200	200
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	46679.3	166.3	46838.7	166.3	76.51	0.00	-11,477	0	-11,477
	132kV Chimpur-Pare	NP-9411-A	PA-05	716	7	737.5	7	10.32	0.00	-1,548	0	-1,548
TOTAL												-11,543
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42499.6	75.7	42499.6	75.7	0.00	0.00	0	0	0
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	68215.2	6862.5	69092.7	6862.5	1,404.00	0.00	-2,10,600	0	-2,10,600
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70581	98617.2	70597.3	98617.2	16.30	0.00	2,445	0	2,445
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	70334.1	99217.8	70395.2	99217.8	61.10	0.00	9,165	0	9,165
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28595	63.9	28508.6	63.9	-138.24	0.00	20,736	0	20,736
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	50215	82268.1	49272.6	82268.1	-678.53	0.00	-1,01,779	0	-1,01,779
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7588.6	1561.6	7602.6	0.00	10.08	0	1,512	1,512
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99481.2	94647.8	99481.2	94570.3	0.00	-27.90	0	4,185	4,185
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	19970.4	3240.6	20007	3240.6	6.59	0.00	-988	0	-988
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87299	91178.2	87050.3	91178.2	-89.53	0.00	-13,430	0	-13,430
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91577.5	99935.3	91335.2	99935.3	-87.23	0.00	-13,084	0	-13,084
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93640.6	99981.3	93347.9	99981.2	-105.37	-0.04	-15,806	5	-15,800
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	88920.1	99986.8	88502.6	99986.8	-150.30	0.00	-22,545	0	-22,545
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28911	99043.1	28912.6	99053.3	0.58	3.67	-86	551	464
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99982.7	5.5	99981.9	0.00	-5.82	0	873	873
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	2401.1	0.1	2160.5	0.00	-1,749.82	0	2,62,473	2,62,473
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82291.3	98104	82289.4	97346.9	-0.68	-272.56	-103	40,883	40,781
TOTAL	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	99241.3	4.1	98953.5	3.2	-207.22	-0.65	-31,082	97	-30,985
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	413.8	99999.7	659.3	99999.7	176.76	0.00	26,514	0	26,514
	TOTAL											-40,064
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95830.6	99121.2	95828.3	99121.2	-1.66	0.00	-248	0	-248
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	559.1	99940.8	550.3	99940.8	-4.22	0.00	-634	0	-634
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.7	12306.9	24533.7	12306.9	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99054.1	99898.5	99020	99898.5	-12.28	0.00	1,841	0	1,841
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19548.8	382.2	19596.8	382.2	17.28	0.00	-2,592	0	-2,592
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17140.6	381.5	17188.1	381.5	17.10	0.00	-2,565	0	-2,565
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	51858.1	99429.2	51592.6	99429.2	-95.58	0.00	14,337	0	14,337
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	4164.6	99966.2	4164.9	99966.2	0.14	0.00	22	0	22
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	9.3	99999.9	8.4	99999.9	-6.55	0.00	982	0	982
TOTAL	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	99982.9	0	99981.4	0	-10.91	0.00	1,636	0	1,636
	TOTAL											12,779


 Director, Public Utility
 Department of Public Utility
 Government of Assam
 Dispur, Assam

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95890.7	81174.6	95859.1	81174.6	-22.75	0.00	-3,413	0	-3,413
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99975.9	20011.3	99977.2	20011.3	0.94	0.00	-140	0	-140
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88579.8	90862.4	88536.1	0.00	-69.92	0	-10,488	-10,488
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391.1	96034.6	87391	96034.6	-0.16	0.00	24	0	24
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	67621.6	99954	66833.3	99954	-2,866.55	0.00	-4,29,982	0	-4,29,982
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	5216.5	99864	5051.5	99864	-600.00	0.00	-90,000	0	-90,000
TOTAL												-5,33,999
MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-8504-A	MZ-02	35469.8	77558.5	35473.7	77567.6	1.40	3.28	-211	491	281
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79420.1	49633	79385.2	49636.4	-12.56	1.22	1,885	184	2,068
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69239.8	86510.3	69193.2	86510.3	-16.78	0.00	-2,516	0	-2,516
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	96882.9	31644.4	97011.3	31644.4	92.45	0.00	13,867	0	13,867
TOTAL												13,700
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15240.5	7114	15245.4	7160.4	1.76	16.70	-265	2,506	2,241
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70305.9	1683.1	70321	1712.7	10.87	21.31	-1,631	3,197	1,566
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9516.6	98906.6	9501.1	98896.7	-5.58	-3.56	837	-535	302
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44141.1	78.8	44141.1	93.6	0.00	5.33	0	-799	-799
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43597	71.7	43597	88.2	0.00	5.94	0	-891	-891
TOTAL												2,419
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97127.4	84644.6	97126.3	84646.2	-0.79	1.15	119	173	292
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10588.4	99635.8	10492.4	99635.8	-92.16	0.00	-13,824	0	-13,824
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49290.7	93757.3	49265.7	93757.3	-24.00	0.00	-3,600	0	-3,600
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68585.9	72538.1	68585.9	72464.5	0.00	-88.32	0	13,248	13,248
	132kV BUDHJUNG NAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6630.6	99999.7	6697.9	99998.5	64.61	-1.15	-9,691	-173	-9,864
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13119.9	0.1	13249.8	99998.7	124.70	-1.34	-18,706	-202	-18,907
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	3785.4	0	4309.1	99996.2	502.75	-3.65	-75,413	-547	-75,960
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	1644.5	99999.9	1865.2	99999.9	211.87	0.00	-31,781	0	-31,781
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	358.6	99999.9	477.5	99999.8	114.14	-0.10	17,122	14	17,136
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	325	99999.8	422.6	99999.5	93.70	-0.29	14,054	43	14,098
TOTAL												-1,09,163

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the following information is provided for the period from 01/01/2023 to 31/03/2023.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 15-03-2021 to 21-03-2021 REV-01

for the period 15-03-2021 to 21-03-2021 REV-01									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	0	0	0	0	0	0	0	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	0	0	0	0	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95461.4	99822.1	95411.2	99822.1	-24.096	0	-3,614	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	96374.8	99796.6	96324.8	99796.6	-24	0	-3,600	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90831.3	99993.6	90586.6	99993.6	-117.456	0	-17,618	0	0
			NP-8384-A	ME-01	95667	68545.8	95666.5	68545.6	-0.24	-0.096	-36	14	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2298	5482.9	2028.4	5482.9	-129.408	0	-19,411	0	-11,700
			NP-9071-A	ME-16	76760.1	28285.9	76922.6	28158.8	78	-61.008	11,700	9,151	
TOTAL													-11,700
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	2593.7	0.1	3078.5	0.1	232.704	0	34,906	0	43
			NP-6892-B	TR-06	76700.9	3370.6	76697.9	3370.6	-0.288	0	-43	0	
TOTAL													43
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94931.1	99373.9	94928.9	99374	-1.056	0.048	-158	-7	-158
			NP-9947-A	NG-02	99836.8	99838.7	99845.5	99868.2	2.61	8.85	392	-1,328	
TOTAL													-158

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director, Electricity
 Department
 Government of India
 New Delhi

**Reactive Energy (VArH) Charge Statement
for the period 22-03-2021 to 28-03-2021 REV-01**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	10,971	0
ASSAM	8,054	0
MANIPUR	24,789	0
MEGHALAYA	0	5,49,722
MIZORAM	12,247	0
NAGALAND	0	2,684
TRIPURA	0	1,13,612

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	12,276
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	720


 Director, Assam
 Meghalaya
 Tripura, etc. of these
 states/Union of India
 Discoms

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 22-03-2021 to 28-03-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	85966.4	25.5	87219.6	25.5	225.58	0.00	33,836	0	33,836
	132kV Khupi-Balipara	NP-9606-A	AS-55	56869.9	79.9	56422	79.9	-161.24	0.00	24,187	0	24,187
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	78110.3	1.5	77883.8	0.00	-163.08	0	-24,462	-24,462
	Nirjuli-TRF 1	NP-9661-A	AR-01	439.1	2036.2	439.2	2038.6	0.04	0.86	-5	130	124
	Nirjuli-TRF 2	NP-9662-A	AR-02	498.1	1953.5	498.3	1955.6	0.07	0.76	-11	113	103
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	46838.7	166.3	47109.2	166.3	129.84	0.00	-19,476	0	-19,476
	132kV Chimpu-Pare	NP-9411-A	PA-05	737.5	7	783.9	7	22.27	0.00	-3,341	0	-3,341
TOTAL												10,971
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42499.6	75.7	42566.6	75.7	107.20	0.00	-16,080	0	-16,080
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	69092.7	6862.5	69848.9	6862.5	1,209.92	0.00	-1,81,488	0	-1,81,488
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	70597.3	98617.2	70863.6	98617.2	266.30	0.00	39,945	0	39,945
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	70395.2	99217.8	70774.7	99217.8	379.50	0.00	56,925	0	56,925
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28508.6	63.9	28515.6	63.9	11.20	0.00	-1,680	0	-1,680
	220kV MARIANI - MISA	NP-9700-A	AS-04	8655	99922.7	8645.5	99922.7	-15.20	0.00	-2,280	0	-2,280
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	49272.6	82268.1	48601.1	82268	-483.48	-0.07	-72,522	11	-72,511
	132kV P'pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7602.6	1561.6	7634.1	0.00	22.68	0	3,402	3,402
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99481.2	94570.3	99479.9	94507.6	-0.47	-22.57	-70	3,386	3,316
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	20007	3240.6	20049.4	3240.6	7.63	0.00	-1,145	0	-1,145
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	87050.3	91178.2	86852.9	91178.2	-71.06	0.00	-10,660	0	-10,660
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91335.2	99935.3	91142.5	99935.2	-69.37	-0.04	-10,406	5	-10,400
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93347.9	99981.2	93118.6	99981.2	-82.55	0.00	-12,382	0	-12,382
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	88502.6	99986.8	88168.3	99986.8	-120.35	0.00	-18,052	0	-18,052
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28912.6	99053.3	28919.6	99053.3	2.52	0.00	-378	0	-378
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99981.9	5.5	99913.9	0.00	-494.55	0	74,182	74,182
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	2160.5	0.1	1684.3	0.00	-3,463.27	0	5,19,491	5,19,491
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82289.4	97346.9	82285.7	96894.8	-1.33	-162.76	-200	24,413	24,214
	220kV Mariani-AGBPP	NP-6888-A	AS-03	25476.1	96335.5	23825.3	96335.5	-2,641.28	0.00	-3,96,192	0	-3,96,192
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	98953.5	3.2	98868.5	3.2	-61.20	0.00	-9,180	0	-9,180
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	659.3	99999.7	835.3	99999.7	126.72	0.00	19,008	0	19,008
TOTAL												8,054
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95828.3	99121.2	95831.3	99121.2	2.16	0.00	324	0	324
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	550.3	99940.8	546.1	99940.7	-2.02	-0.05	-302	7	-295
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.7	12306.9	24533.7	12307	0.00	0.01	0	1	1
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	99020	99898.5	98975.1	99898.5	-16.16	0.00	2,425	0	2,425
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19596.8	382.2	19633.9	382.2	13.36	0.00	-2,003	0	-2,003
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17188.1	381.5	17224.9	381.5	13.25	0.00	-1,987	0	-1,987
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	51592.6	99429.2	51113	99428.3	-172.66	-0.32	25,898	-49	25,850
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	4164.9	99966.2	4171.6	99966.3	3.22	0.05	482	-7	475
TOTAL												24,789


 Director, Energy Department
 Government of Assam
 Dispur, Assam

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95859.1	81174.6	95827	81174.6	-23.11	0.00	-3,467	0	-3,467
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99977.2	20011.3	99985.4	20011.8	5.90	0.36	-886	54	-832
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88536.1	90862.4	88503.2	0.00	-52.64	0	-7,896	-7,896
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87391	96034.6	87373.2	96034.6	-28.48	0.00	4,272	0	4,272
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	66833.3	99954	65987.9	99954	-3,074.18	0.00	-4,61,127	0	-4,61,127
TOTAL												-5,49,722
MIZORAM	132kV LAUNGQUAL-AIZWAL PG	NP-8504-A	MZ-02	35473.7	77567.6	35531.6	77582.9	20.84	5.51	-3,127	826	-2,300
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79385.2	49636.4	79266.6	49642.5	-42.70	2.20	6,404	329	6,734
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69193.2	86510.3	69148.1	86510.3	-16.24	0.00	-2,435	0	-2,435
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97011.3	31644.4	97106.2	31644.4	68.33	0.00	10,249	0	10,249
TOTAL												12,247
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15245.4	7160.4	15259.3	7160.4	5.00	0.00	-751	0	-751
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70321	1712.7	70358.9	1712.7	27.29	0.00	-4,093	0	-4,093
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9501.1	98896.7	9459.5	98896.7	-14.98	0.00	2,246	0	2,246
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44141.1	93.6	44140.9	94	-0.07	0.14	-11	-22	-32
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43597	88.2	43596.8	89	-0.07	0.29	-11	-43	-54
TOTAL												-2,684
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97126.3	84646.2	97126.3	84646.2	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10492.4	99635.8	10425.5	99635.7	-64.22	-0.10	-9,634	14	-9,619
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49265.7	93757.3	49234.2	93757.3	-30.24	0.00	-4,536	0	-4,536
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68585.9	72464.5	68586.7	72440.4	0.96	-28.92	144	4,338	4,482
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6697.9	99998.5	6784.5	99998.5	83.14	0.00	-12,470	0	-12,470
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13249.8	99998.7	13434.9	99998.8	177.70	0.10	-26,654	14	-26,640
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	4309.1	99996.2	4739.9	99996.2	413.57	0.00	-62,035	0	-62,035
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	1865.2	99999.9	2048.8	99999.9	176.26	0.00	-26,438	0	-26,438
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	477.5	99999.8	566.4	99999.8	85.34	0.00	12,802	0	12,802
TOTAL												-1,13,612

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the meter reading is taken as per the meter reading available at the metering station.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 22-03-2021 to 28-03-2021 REV-01

for the period 22-03-2021 to 28-03-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	76430.9	96294.2	76404	96291.2	-12.912	-1.44	-1,937	216	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	94719.9	99204.8	94679.9	99200.3	-19.2	-2.16	-2,880	324	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95411.2	99822.1	95352.3	99821.6	-28.272	-0.24	-4,241	36	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	96324.8	99796.6	96266.3	99796.1	-28.08	-0.24	-4,212	36	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90586.6	99993.6	90381.5	99993.6	-98.448	0	-14,767	0	-504
			NP-8384-A	ME-01	95666.5	68545.6	95673.5	68543.2	3.36	-1.152	504	173	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	2028.4	5482.9	1737.2	5483.2	-139.776	0.144	-20,966	-22	-11,772
			NP-9071-A	ME-16	76922.6	28158.8	77085.8	28099.7	78.336	-28.368	11,750	4,255	
TOTAL													-12,276
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	3078.5	0.1	3449.1	0.1	177.888	0	26,683	0	720
			NP-6892-B	TR-06	76697.9	3370.6	76647.9	3370.6	-4.8	0	-720	0	
TOTAL													720
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94928.9	99374	94860.1	99374	-33.024	0	-4,954	0	0
			NP-9947-A	NG-02	99845.5	99868.2	99812.2	99868.2	-9.99	0	-1,499	0	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

(Signature)
 Director, Electricity
 Department, Government of India
 New Delhi

Reactive Energy (VArH) Charge Statement
for the period 29-03-2021 to 04-04-2021 REV-01

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	20,254	0
ASSAM	0	7,77,720
MANIPUR	16,390	0
MEGHALAYA	0	8,13,645
MIZORAM	24,268	0
NAGALAND	0	14,418
TRIPURA	0	58,586

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ASSAM	MEGHALAYA	2,966
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	1,848


 (For Circulation & Signature)
 Manager, Revenue
 Meghalaya
 Page 1 of 1, Date: 04/04/2021
 10:10:10 AM, 04/04/2021
 10:10:10 AM, 04/04/2021

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL

for the period 29-03-2021 to 04-04-2021 REV-01

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	87219.6	25.5	88500.8	25.5	230.62	0.00	34,592	0	34,592
	132kV Khupi-Balipara	NP-9606-A	AS-55	56422	79.9	56051.2	79.9	-133.49	0.00	20,023	0	20,023
	132kV Lekhi-Nirjuli	NP-9664-A	AR-03	1.5	77883.8	1.5	77728.5	0.00	-111.82	0	-16,772	-16,772
	Nirjuli-TRF 1	NP-9661-A	AR-01	439.2	2038.6	440.7	2041.7	0.54	1.12	-81	167	86
	Nirjuli-TRF 2	NP-9662-A	AR-02	498.3	1955.6	500.3	1958.8	0.72	1.15	-108	173	65
	132kV Tenga-Balipara	NP-9696-A	AR-17	0	0	0	0	0.00	0.00	0	0	0
	132kV Lekhi-Pare	NP-9607-A	PA-01	47109.2	166.3	47330.9	166.3	106.42	0.00	-15,962	0	-15,962
	132kV Chimpur-Pare	NP-9411-A	PA-05	783.9	7	839.4	7	26.64	0.00	-3,996	0	-3,996
	132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	0.1	99999.9	14.6	99999.9	13.92	0.00	2,088	0	2,088
	132kV ITANAGAR - BNC FDR 2	NP-9939-A	AR-20	0	0.2	0.9	0.2	0.86	0.00	130	0	130
TOTAL												20,254
ASSAM	220kV BTPS-II - SALAKATI	NP-9435-A	AS-31	42566.6	75.7	42864.4	75.7	476.48	0.00	-71,472	0	-71,472
	220kV BTPS-I - SALAKATI	NP-9434-A	AS-30	69848.9	6862.5	71560.4	6862.5	2,738.40	0.00	-4,10,760	0	-4,10,760
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	0	0	0	0	0.00	0.00	0	0	0
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	0	0	0	0	0.00	0.00	0	0	0
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	28515.6	63.9	28375.1	63.9	-224.80	0.00	33,720	0	33,720
	220kV MARIANI - MISA	NP-9700-A	AS-04	8645.5	99922.7	8616.1	99921.3	-47.04	-2.24	-7,056	336	-6,720
	132kV PANCHGRAM-B*PUR(PG)	NP-6872-A	AS-07	48601.1	82268	47754.2	82268	-609.77	0.00	-91,465	0	-91,465
	132kV P*pool-JIRIBAM	NP-8499-A	MN-06	1561.6	7634.1	1561.6	7634.4	0.00	0.22	0	32	32
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99479.9	94507.6	99440.6	94454.6	-14.15	-19.08	-2,122	2,862	740
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	20049.4	3240.6	20125.1	3240.6	13.63	0.00	-2,044	0	-2,044
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	86852.9	91178.2	86642.8	91178.2	-75.64	0.00	-11,345	0	-11,345
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	91142.5	99935.2	90936	99935.2	-74.34	0.00	-11,151	0	-11,151
	UMRANGSOO CONSUMPTION	NP-5781-A	AS-14	0	0	0	0	0.00	0.00	0	0	0
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	93118.6	99981.2	92992.7	99981.2	-45.32	0.00	-6,799	0	-6,799
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	88168.3	99986.8	87968.2	99986.8	-72.04	0.00	-10,805	0	-10,805
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	28919.6	99053.3	28938.9	99053.4	6.95	0.04	-1,042	5	-1,037
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	5.5	99913.9	5.5	99912.7	0.00	-8.73	0	1,309	1,309
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	0.1	1684.3	0.1	1580.8	0.00	-752.73	0	1,12,909	1,12,909
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	82285.7	96894.8	82288.6	96430.9	1.04	-167.00	157	25,051	25,207
	220kV Mariani-AGBPP	NP-6888-A	AS-03	23825.3	96335.5	22436.6	96335.5	-2,221.92	0.00	-3,33,288	0	-3,33,288
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	98868.5	3.2	98712.7	3.2	-112.18	0.00	-16,826	0	-16,826
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	835.3	99999.7	1039.7	99999.7	147.17	0.00	22,075	0	22,075
TOTAL												-7,77,720
MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	95831.3	99121.2	95849.9	99121.2	13.39	0.00	2,009	0	2,009
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	546.1	99940.7	548.5	99940.7	1.15	0.00	173	0	173
	JIRIBAM-TRF	NP-8501-A	MN-04	24533.7	12307	24534.6	12307	0.05	0.00	-8	0	-8
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98975.1	99898.5	98958	99898.5	-6.16	0.00	923	0	923
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	19633.9	382.2	19680.3	382.2	16.70	0.00	-2,506	0	-2,506
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	17224.9	381.5	17271.3	381.6	16.70	0.04	-2,506	5	-2,500
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	51113	99428.3	50805.5	99428.2	-110.70	-0.04	16,605	-5	16,600
TOTAL												16,390


 Signature of the official
 Date: 04/04/2021
 Place: Dispur, Assam
 Designation:

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95827	81174.6	95781.6	81174.6	-32.69	0.00	-4,903	0	-4,903
	132kV KHLRT S-PG II	NP-6880-A	ME-09	99985.4	20011.8	99992.3	20011.8	4.97	0.00	-745	0	-745
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	90862.4	88503.2	90862.4	88489.9	0.00	-21.28	0	-3,192	-3,192
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	87373.2	96034.6	87363.5	96034.5	-15.52	-0.16	2,328	-24	2,304
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	65987.9	99954	64277	99954	-6,221.45	0.00	-9,33,218	0	-9,33,218
TOTAL												-8,13,645
MIZORAM	132kV LAUNGQUAL-AIZWAL PG	NP-8504-A	MZ-02	35531.6	77582.9	35592.2	77608.6	21.82	9.25	-3,272	1,388	-1,885
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	79266.6	49642.5	78960.9	49646.1	-110.05	1.30	16,508	194	16,702
	132kV KOLASIB-BADARPUR PG	NP-8497-A	MZ-11	69148.1	86510.3	69086.9	86510.3	-22.03	0.00	-3,305	0	-3,305
	132kV KOLASIB-AIZAWL PG	NP-8496-A	MZ-12	97106.2	31644.4	97224.3	31644.4	85.03	0.00	12,755	0	12,755
TOTAL												24,268
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	15259.3	7160.4	15328.8	7160.6	25.02	0.07	-3,753	11	-3,742
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	70358.9	1712.7	70531.4	1712.8	124.20	0.07	-18,630	11	-18,619
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	9459.5	98896.7	9306.2	98896.7	-55.19	0.00	8,278	0	8,278
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44140.9	94	44140.8	97	-0.04	1.08	-5	-162	-167
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43596.8	89	43596.8	92.1	0.00	1.12	0	-167	-167
TOTAL												-14,418
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97126.3	84646.2	97125.9	84659.8	-0.29	9.79	43	1,469	1,512
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	10425.5	99635.7	10409.2	99635.7	-15.65	0.00	-2,347	0	-2,347
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	49234.2	93757.3	49225.8	93757.3	-8.06	0.00	-1,210	0	-1,210
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68586.7	72440.4	68609.7	72397.2	27.60	-51.84	4,140	7,776	11,916
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	6784.5	99998.5	6794.1	99998.5	9.22	0.00	-1,382	0	-1,382
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	13434.9	99998.8	13487.8	0.1	50.78	1.25	-7,618	187	-7,430
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	4739.9	99996.2	5099.5	99996.2	345.22	0.00	-51,782	0	-51,782
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	2048.8	99999.9	2232.1	99999.9	175.97	0.00	-26,395	0	-26,395
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	566.4	99999.8	637.9	99999.8	68.64	0.00	10,296	0	10,296
TOTAL												-58,586

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISGS.

4) 'NA' means meter reading not available.

For the purpose of this statement, the meter reading is taken as per the meter reading available at the time of the audit.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES

for the period 29-03-2021 to 04-04-2021 REV-01

for the period 29-03-2021 to 04-04-2021 REV-07									Actual*CT*PT		Amount in Rs.		
Beneficiary	Line Name	To Beneficiary	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Effective Net Reactive Charge
ASSAM	KAHELIPARA-UMTRU II	MEGHALAYA	NP-8488-A	AS-02	97149.3	1692.7	97149.3	1692.7	0	0	0	0	0
			NP-8475-A	ME-04	97149.3	1692.7	97149.3	1692.7	0	0	0	0	
	KAHELIPARA-UMTRU I	MEGHALAYA	NP-8490-A	AS-01	97149.3	1692.7	97149.3	1692.7	0	0	0	0	0
			NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0	0	0	0	
	S'SUJAI-UMTRU I	MEGHALAYA	NP-9921-A	AS-09	99981.4	0.3	99981.4	0.3	0	0	0	0	0
			NP-8473-A	ME-07	95352.3	99821.6	95292	99821.6	-28.944	0	-4,342	0	
	S'SUJAI-UMTRU II	MEGHALAYA	NP-9922-A	AS-50	99987.7	0	99987.7	0	0	0	0	0	0
			NP-8491-A	ME-05	96266.3	99796.1	96206.1	99796.1	-28.896	0	-4,334	0	
	PANCHGRAM-LUMSHONG	MEGHALAYA	NP-7595-A	AS-06	90381.5	99993.6	90505.1	99993.6	59.328	0	8,899	0	3,046
			NP-8384-A	ME-01	95673.5	68543.2	95631.2	68543.2	-20.304	0	-3,046	0	
	AGIA-Mendhipathar	MEGHALAYA	NP-9455-A	AS-86	1737.2	5483.2	1588.9	5483.2	-71.184	0	-10,678	0	-6,012
			NP-9071-A	ME-16	77085.8	28099.7	77169.3	28043.1	40.08	-27.168	6,012	4,075	
TOTAL													-2,966
ASSAM	D'CHERRA - D'NAGAR	TRIPURA	NP-9904-A	AS-08	3449.1	0.1	3889.5	0.1	211.392	0	31,709	0	1,848
			NP-6892-B	TR-06	76647.9	3370.6	76519.6	3370.5	-12.3168	-0.0096	-1,848	1	
TOTAL													1,848
MANIPUR	132KV KARONG-KOHIMA	NAGALAND	NP-9667-A	MN-03	94860.1	99374	94703.3	99373.9	-75.264	-0.048	-11,290	7	0
			NP-9947-A	NG-02	99812.2	99868.2	99693	99868.1	-35.76	-0.03	-5,364	5	
TOTAL													0

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

Signature
Name
Designation
Date