



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/ 6595-6617

Dt:24th Jan., 2024

सेवामें / To,
संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Provisional Reactive Energy Account under ABT regime-for the period 08.01.2024 to 14.01.2024 - Reg.

सर/मैडम,
Sir/Madam.

The Provisional statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 08.01.2024 to 14.01.2024 is sent herewith. The rate for charge/payment for reactive energy will be governed as per CERC IEGC Regulation-2023, which works out to be 5 Paise/KVARH w.e.f from 1st October 2023, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay under complimentary commercial mechanism of IEGC (October 2023) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Constituents may send their observation/ comments, if any on the same within 15 days from the date of issue of the account. In case no communication is received from constituents, the provisional Reactive Energy account statement as issued would be treated as final.

Enclosed - As above.

भवदीय / Yours faithfully,


(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33,Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer

Reactive Energy (VArH) Charge Statement
for the period 1/8/2024 to 1/14/2024

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	14,104	0
ASSAM	1,68,930	0
MANIPUR	237	0
MEGHALAYA	0	75,657
MIZORAM	23,166	0
NAGALAND	0	2,613
TRIPURA	12,539	0
PARE	74	0
DOYANG	1,040	0
KHANDONG	0	12,571
KOPILI-2	0	23,661
AGBPP	0	23,572
LOKTAK	0	338
AGTCCPP	0	1,274
RANGANADI	13,597	0
PALATANA	0	3,56,318
BGTPP	2,31,833	0
KAMENG	0	255
KOPILI	0	8,800
HVDC_BNC	0	3,15,404


(एस.एम.आइमल/J.M.Aimal)
निदेशक/Director
उ.पु.वि.स./NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 1/8/2024 to 1/14/2024

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Khupi-Balipara	NP-9606-A	AS-55	21776	79.8	22227.4	79.8	162.50	0.00	-8,125	0	-8,125
	132 KV NIRJULI - LEKHI	NP-9664-A	AR-03	99984	47584.9	99984	47544.9	0.00	-28.80	0	1,440	1,440
	132/33kV NIRJULI TRANSFORMER INCOMER-I	NE-0011-A	AR-21	99949.5	68308.1	99949.5	67474	0.00	-250.23	0	12,512	12,512
	132/33kV NIRJULI TRANSFORMER INCOMER-II	NP-0025-A	AR-22	0	0	0	0	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	38960.6	7.1	39035.6	7.1	54.00	0.00	2,700	0	2,700
	132 KV CHIMPU – BNC	NP-9935-A	AR-19	838.4	96545.4	838.4	96535.3	0.00	-9.70	0	485	485
	132 KV ZIRO - RANGANADI	NP-9704-A	AR-06	75218.3	43.1	76206.7	43.1	177.91	0.00	8,896	0	8,896
	132 KV RANGANADI - LEKHI	NP-9652-A	AR-05	96195.7	97304.8	96195.5	97286.6	-0.14	-13.10	-7	655	648
	220 KV KATHALGURI - DEOMALI	NP-9659-A	AR-07	80395.6	13.3	80254.1	13.3	-113.20	0.00	-5,660	0	-5,660
	132 KV PARE – CHIMPU CKT I	NP-9586-A	AR-08	91174.6	99752.1	91174.6	99752.1	0.00	0.00	0	0	0
	132 KV PARE – CHIMPU CKT II	NP-9587-A	AR-09	89564.9	98070.9	89564.9	98035.9	0.00	-16.80	0	840	840
	132 KV CHIMPU – GOHPUR	NP-9939-A	AR-20	325.4	98037.4	325.4	98029.7	0.00	-7.39	0	370	370
TOTAL												14,104
ASSAM	220kV BTPS-II - SALAKATI	NP-9070-A	AS-15	16201	99830.6	16132.7	99830.6	-109.28	0.00	-5,464	0	-5,464
	220 kV BTPS-SALAKATI –2	NP-8476-A	AS-16	29312.9	99550.3	29167.2	99550.3	-233.12	0.00	-11,656	0	-11,656
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	2977.5	98581	3704.8	98581	727.30	0.00	36,365	0	36,365
	220 kV SAMAGURI – MISA - 2	NP-9713-A	AS-18	26793.3	99202.7	27792.3	99202.7	999.00	0.00	49,950	0	49,950
	220 kV SONABIL- BALIPARA CKT I	NE-0035-A	AS-19	3.1	98326.3	3.1	98328.9	0.00	4.16	0	-208	-208
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	99462.3	79845.3	99151.6	79845.3	-111.85	0.00	-5,593	0	-5,593
	132 kV JIRIBAM - PAILAPOOL	NP-8498-A	AS-10	73689	65156.2	73270.4	65156.2	-200.93	0.00	-10,046	0	-10,046
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99357.4	82375.3	99356.8	82376.8	-0.22	0.54	-11	-27	-38
	132 kV HAFLONG (PG)-HAFLONG (AS)	NE-0026-A	AM-57	99221.2	99722.4	99203.5	99722.4	-12.74	0.00	-637	0	-637
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	73287.9	91177	73104.3	91177	-66.10	0.00	-3,305	0	-3,305
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	78260.4	99934.3	78082.5	99934.3	-64.04	0.00	-3,202	0	-3,202
	220 kV SONABIL- BALIPARA CKT 2	NE-0090-A	AM-66	2150.9	2.5	2330	2.5	286.56	0.00	14,328	0	14,328
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	76366.7	99979.8	76145.4	99979.8	-79.67	0.00	-3,983	0	-3,983
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	64188.3	99985.4	63913.2	99985.4	-99.04	0.00	-4,952	0	-4,952
	132 kV DIMAPUR - BOKAJAN	NP-7587-A	AS-63	58453.7	94881.3	58437	94881.3	-12.02	0.00	-601	0	-601
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	90716.1	99741.3	90482.9	99741.3	-1,696.00	0.00	-84,800	0	-84,800
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	615.3	97568.8	557.2	97568.8	-422.55	0.00	-21,127	0	-21,127
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	89433.5	99215.8	89433.2	99146.7	-0.11	-24.88	-5	1,244	1,238
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	89587.1	98722.2	89256.5	98722.2	-238.03	0.00	-11,902	0	-11,902
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	5576.2	5032.7	5729.3	5032.7	110.23	0.00	5,512	0	5,512
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	71404.9	99315.1	70846.1	99315.1	-268.22	0.00	-13,411	0	-13,411
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	16072.7	60981.9	16073.2	60982	0.18	0.04	9	-2	7
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50526.6	55511.7	50526.6	55512	0.00	0.11	0	-5	-5
	132kV Chapakhowa end of Roing-1	NP-0059-A	AM-67	0	0	0	0	0.00	0.00	0	0	0
	132kV Chapakhowa end of Roing-2	NP-0056-A	AM-68	0	0	0	0	0.00	0.00	0	0	0
	132 kV GOHPUR - BNC	NE-0094-A	AM-61	112.7	99368	113.6	99367.2	0.86	-0.77	43	38	82
	132 kV CHIMPU – GOHPUR	NE-0093-A	AM-62	99951.7	279.4	99951.4	279.8	-0.29	0.38	-14	-19	-34
	132 kV D'CHERA - DHARMANAGAR	NP-9904-A	AS-08	25844.5	99588.1	26200.2	99588.1	170.74	0.00	8,537	0	8,537
	132 kV KAHELIPARA – UMTRU -1	NE-0088-A	AS-01	0	0	0	0	0.00	0.00	0	0	0
	132 kV KAHELIPARA – UMTRU -2	NE-0089-A	AS-02	0	0	0	0	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -1	NP-9921-A	AS-09	99996.4	0.3	99996.4	0.3	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -2	NP-9922-A	AS-50	99996.9	0	99996.9	0	0.00	0.00	0	0	0
	132 KV PANCHGRAM - LUMSHNONG	NP-7595-A	AS-06	81463.9	1085.2	81066.6	1085.2	-190.70	0.00	-9,535	0	-9,535
	132 kV AGIA – MENDIPATHAR	NP-9455-A	AS-86	65599.2	6674.7	65049.4	6674.7	-263.90	0.00	-13,195	0	-13,195
	132 kV AGIA - NANGALBIBRA	NP-9920-A	AM-58	53976.8	53.5	53183.4	53.5	-285.62	0.00	-14,281	0	-14,281


(एस.एम.आइमल/S.M.Aimal)
निदेशक/Director
उ.पु.रे.वि.स/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong


	220 kV AGBPP – TINSUKIA - 1	NP-9654-A	AS-53	76236.3	17.2	76815.5	17.2	926.72	0.00	46,336	0	46,336
	220 kV AGBPP – TINSUKIA - 2	NP-9658-A	AS-74	74213.2	17.5	74826.3	17.5	980.96	0.00	49,048	0	49,048
	132 kV UMRANGSHOO - KHANDONG	NP-5290-A	AM-04	89779.7	98968.5	90270.2	98968.5	235.44	0.00	11,772	0	11,772
	132 kV PARE – NORTH LAKHIMPUR	NE-0117-A	AM-69	16.9	91917.7	16.9	91828.9	0.00	-42.62	0	2,131	2,131
	400 /220 kV BgTPP ICT-1	NP-9647-A	AM-42	9939.2	0	11183.5	0	2,986.32	0.00	1,49,316	0	1,49,316
	400 /220 kV BgTPP ICT-2	NP-5318-A	AM-28	54430.2	98789.2	55658.8	98789.2	1,965.76	0.00	98,288	0	98,288
	220 kV AGBPP – MARIANI	NP-6888-A	AS-03	46396.2	96335.1	45305.1	96335.1	-1,745.76	0.00	-87,288	0	-87,288
	132 kV NORTH LAKHIMPUR-NIRJULI	NE-0119-A	AM-70	18.7	96049.9	18.7	95996.4	0.00	-25.68	0	1,284	1,284
TOTAL												1,68,930

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96518.7	99120.3	96518.7	99120.3	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.3	99935.3	516.3	99935.3	0.00	0.00	0	0	0
	JIRIBAM-TRF	NE-0027-A	MN-04	99911.1	1.9	99911.1	1.9	0.00	0.00	0	0	0
	132 kV JIRIBAM (PG) – JIRIBAM (MN)	NP-9902-A	MN-19	3347.5	30	3361.9	30	3.46	0.00	173	0	173
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	22356.7	384.7	22356.8	384.7	0.04	0.00	-2	0	-2
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19849.5	384.1	19849.6	384.1	0.04	0.00	-2	0	-2
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9946-A	MN-17	27124.3	3	27134.7	3	7.49	0.00	374	0	374
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	5409.8	99967.9	5409.8	99967.9	0.00	0.00	0	0	0
	400 KV IMPHAL – THOUBAL-1	NP-9668-A	MN-28	0	0	0	0	0.00	0.00	0	0	0
	400 KV IMPHAL – THOUBAL-2	NP-9603-A	MN-29	97224.3	95484.5	97225.1	95484.5	5.82	0.00	291	0	291
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	94804.6	2.1	94707.9	2.1	-23.21	0.00	-1,160	0	-1,160
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	3242	99978.6	3322	99978.6	19.20	0.00	960	0	960
	132 kV KARONG-KOHIMA	NP-9667-A	MN-03	91938.8	97495.4	91937.9	97495.3	-0.43	-0.05	-22	2	-19
TOTAL												237


Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Net Reactive Charge
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	95943	80696.4	96232.7	80696.4	208.58	0.00	10,429	0	10,429
	132kV KHLRT S-PG II	NP-6880-A	ME-09	98627.9	21930.3	98474.9	21930.3	-110.16	0.00	5,508	0	5,508
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	88632.6	85965.6	88529	85965.6	-165.76	0.00	8,288	0	8,288
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	82178.1	96033.1	82049.5	96033.1	-205.76	0.00	10,288	0	10,288
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	72767.2	99953.7	71706	99953.7	-3,858.91	0.00	-1,92,945	0	-1,92,945
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	32168.8	99864	32599.1	99864	1,564.73	0.00	78,236	0	78,236
	132 kV KAHALIPARA – UMTRU -1	NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0.00	0.00	0	0	0
	132 kV KAHALIPARA – UMTRU -2	NE-0016-A	ME-04	0.6	0	0.6	0	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -1	NP-8473-A	ME-07	91400.6	99820.2	91306.8	99820.2	-45.02	0.00	-2,251	0	-2,251
	132 kV SARUSAJAI – UMTRU -2	NP-8491-A	ME-05	92299.1	99794.6	92205.3	99794.6	-45.02	0.00	-2,251	0	-2,251
	132 kV PANCHGRAM - LUMSHNONG	NP-8384-A	ME-01	96360.5	60772.7	96448.3	60772.7	42.14	0.00	2,107	0	2,107
TOTAL	132 kV AGIA – MENDIPATHAR	NP-9945-A	ME-17	99516.7	91264.7	99507.9	91264.7	-4.22	0.00	-211	0	-211
	132 kV AGIA – MENDIPATHAR	NP-9071-A	ME-16	95126.6	21557.7	95424.3	21557.7	142.90	0.00	7,145	0	7,145
TOTAL												-75,657

MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	695.8	8900.4	695.6	9157	-0.19	246.34	10	12,317	12,326
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	65356.5	53667.3	65152.6	53909.8	-73.40	87.30	3,670	4,365	8,035
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	1125.1	99732.4	1163.6	99732.4	13.86	0.00	693	0	693
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	14.2	45.6	58.8	45.6	32.11	0.00	1,606	0	1,606
	132kV Shimui-Melriat(PG)-I	NP-9493-A	MZ-17	99264.1	99057.1	99251.3	99026.9	-4.61	-10.87	-230	544	313
TOTAL												23,166

NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	17468.8	10138.2	17482.6	10138.3	13.25	0.10	-662	5	-658
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	75156.2	5649.5	75190.9	5649.5	24.98	0.00	-1,249	0	-1,249
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	6280	98155.5	6290.6	98155.4	3.82	-0.04	-191	-2	-193
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44494.8	5014.6	44494.8	5019.5	0.00	1.76	0	-88	-88
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43909.3	5101.5	43909.3	5106.5	0.00	1.80	0	-90	-90
	132 kV KARONG-KOHIMA	NP-9947-A	NG-02	1767.6	99890	1768.4	99890	0.24	0.00	12	0	12
	132 kV DHEP - SANIS	NP-6148-A	NG-22	0	0	0	0	0.00	0.00	0	0	0
TOTAL												-347
TOTAL												-347


 (एन.एस.आय.एम./S.M. Aimal)
 निदेशक/Director
 उद्योग विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

TOTAL												-2,613
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97407.7	84658.5	97408	84658.5	0.29	0.00	-14	0	-14
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7351.4	99970.6	7348.6	99970.6	-2.69	0.00	134	0	134
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14717.6	26.4	14715	26.4	-2.50	0.00	125	0	125
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10541.2	99995	10538.5	99995	-2.59	0.00	130	0	130
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	5061.3	99999.8	5074.2	99999.8	12.38	0.00	-619	0	-619
	132 kV D'CHERA - DHARMANAGAR	NP-6892-B	TR-06	76269	31028.8	76269	29811.3	0.00	-584.40	0	29,220	29,220
	132 kV AGARTALA - AGTPP - 1	NP-6850-A	TR-01	7408.9	6224.5	7150.8	6224.5	-247.78	0.00	-12,389	0	-12,389
	132 kV AGARTALA - AGTPP - 2	NP-6851-A	TR-02	47535.1	93754.3	47396	93754.3	-133.54	0.00	-6,677	0	-6,677
	132 kV PK BARI- RC NAGAR-1	NP-9933-A	TR-21	1523.2	99825.9	1523.2	99789.4	0.00	-35.04	0	1,752	1,752
	132 kV PK BARI- RC NAGAR-2	NP-9932-A	TR-22	1436.3	99997.1	1441.3	99997.1	4.80	0.00	240	0	240
	132 kV PALATANA - SM NAGAR	NP-8471-A	TR-13	68933.3	72313.1	68942.9	72313.1	11.52	0.00	576	0	576
	132 kV PALATANA - UDAIPUR	NP-8470-A	TR-14	53192.4	55102.9	53194.1	55102.9	1.22	0.00	61	0	61
TOTAL												12,539
PARE	132 kV PARE – NIRJULI	NP-9409-A	PA-03	58187.8	2525.5	58187.8	2536.7	0.00	10.75	0	-538	-538
	32 kV PARE – CHIMPU CKT I	NP-9411-A	PA-05	2900.9	99042.3	2900.9	99017	0.00	-12.14	0	607	607
	132 kV PARE – CHIMPU CKT II	NP-9538-A	PA-07	69188.9	98963	69188.9	98942.6	0.00	-9.79	0	490	490
	132 kV PARE – NORTH LAKHIMPUR	NP-9607-A	PA-01	58634.6	3306.9	58634.6	3317	0.00	9.70	0	-485	-485
TOTAL												74
DOYANG	132kV DHEP - DIMAPUR(PG) - 1	NP-9066-A	DY-01	81995	78653.4	81995	78615.2	0.00	-27.50	0	1,375	1,375
	132kV DHEP - DIMAPUR(PG) -2	NP-9050-A	DY-02	70799.4	88460.8	70799.4	88459.5	0.00	-0.94	0	47	47
	132 kV DHEP - SANIS	NP-8799-A	DY-03	19266.7	11713.6	19266.7	11721.6	0.00	5.76	0	-288	-288
	132 kV DHEP - MOKOKCHUNG	NP-9053-A	DY-04	57503.3	10460.7	57503.3	10463.3	0.00	1.87	0	-94	-94
TOTAL												1,040
KHANDONG	132kV KHANDONG - KHLRT - 1	NE-0114-A	KK-31	92879.1	6.5	93624.5	6.6	268.34	0.04	13,417	-2	13,415
	132kV KHANDONG - KHLRT - 2	NE-0066-A	KK-30	94661.3	230.9	93797.2	230.9	-311.08	0.00	-15,554	0	-15,554
	132 kV UMRANGSHOO - KHANDONG	NE-0138-A	KK-32	93463	99970	93173.2	99970	-208.66	0.00	-10,433	0	-10,433
TOTAL												-12,571
KOPILI-2	KOPILI GT OF STG-2	NE-0140-A	KK-42	53640.6	99914.5	51666.7	99914.5	-473.74	0.00	-23,687	0	-23,687
	KOPILI STG-2 33 kV STN TRF	NE-0137-A	KK-40	2343.6	9.2	2413.4	9.2	0.52	0.00	26	0	26
TOTAL												-23,661
AGBPP	220 kV AGBPP – MARIANI PG	NP-9582-A	KT-02	49256.5	1.1	51164.5	1.1	3,052.80	0.00	1,52,640	0	1,52,640
	KTG END OF 220kV DEOMALI FDR	NP-9566-A	KT-14	44572	99999.4	44178.7	99999.4	-314.64	0.00	-15,732	0	-15,732
	220 kV AGBPP – MARIANI	NP-9625-A	KT-01	11199.5	99930.9	11141.2	99930.9	-93.28	0.00	-4,664	0	-4,664
	220 kV AGBPP – TINSUKIA - 1	NP-9650-A	KT-15	9209.7	0.9	8250.9	0.9	-1,534.08	0.00	-76,704	0	-76,704
	220 kV AGBPP – TINSUKIA - 2	NP-9443-A	KT-16	3578.3	1.2	2589.4	1.2	-1,582.24	0.00	-79,112	0	-79,112
TOTAL												-23,572
LOKTAK	132 kV LOKTAK - JIRIBAM	NP-9064-A	LO-02	48804	97860.4	48789.6	97860.4	-6.91	0.00	-346	0	-346
	132 kV LOKTAK - IMPHAL (PG)	NP-9044-A	LO-03	33139.8	97678.3	33140.3	97678.3	0.24	0.00	12	0	12
	132 kV LOKTAK – RENGPAANG	NP-9065-A	LO-01	53650.5	98096.8	53648.5	98096.8	-0.96	0.00	-48	0	-48
	132 kV LOKTAK – NINGTHOUKONG	NP-9045-A	LO-04	6624.9	6598.2	6626.7	6598.2	0.86	0.00	43	0	43
TOTAL												-338
AGTCCPP	132 kV AGTPP - KUMARGHAT	NP-9080-A	AG-03	54636.7	97039.7	54620.9	97039.7	-11.38	0.00	-569	0	-569
	132 kV AGARTALA - AGTPP - 1	NP-9081-A	AG-01	23022	4817.8	23071.6	4817.8	47.62	0.00	2,381	0	2,381
	132 kV AGARTALA - AGTPP - 2	NP-9093-A	AG-02	23117.8	6503.2	23159.6	6503.2	40.13	0.00	2,006	0	2,006
	132 kV PK BARI- RC NAGAR-1	NP-9940-A	AG-16	96632.5	99998.4	96526.4	99998.4	-101.86	0.00	-5,093	0	-5,093
	132 kV PK BARI- RC NAGAR-12	NP-9941-A	AG-17	95865.3	99999.6	0	0	0.00	0.00	0	0	0
TOTAL												-1,274
RANGANADI	400 kV RANGANADI - BNC 1	NP-6033-A	RN-02	73666.1	99945	73658.5	99945	-27.64	0.00	-1,382	0	-1,382
	400 kV RANGANADI - BNC 2	NP-5817-A	RN-03	92833.1	99986.5	92785.2	99986.5	-174.18	0.00	-8,709	0	-8,709
	132 kV RANGANADI - LEKHI	NP-5792-A	RN-01	3762.1	99720.5	4560	99720.5	478.74	0.00	23,937	0	23,937
	132 kV ZIRO - RANGANADI	NP-5278-A	RN-11	42213.7	97977.1	42205.4	97977.1	-4.98	0.00	-249	0	-249
TOTAL												13,597


 (एसएम आमुल/S.M.Aumol)
 निदेशक/Director
 उच्च वोल्टेज/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
PALATANA	400 kV PALATANA - SILCHAR -1	NP-9558-A	PL-16	21787.2	99998.3	21093.4	99998.3	-2,522.91	0.00	-1,26,145	0	-1,26,145
	400 kV PALATANA - SILCHAR -2	NP-9560-A	PL-17	52105	99993.5	51375.7	99993.5	-2,652.00	0.00	-1,32,600	0	-1,32,600
	400 kV PALATANA – SM NGR_ST	NE-0013-A	PL-22	63526.6	2.3	63026.2	2.3	-1,819.64	0.00	-90,982	0	-90,982
	132 kV PALATANA - SM NAGAR	NP-9561-A	PL-19	21176.2	27.6	21129.5	27.6	-89.66	0.00	-4,483	0	-4,483
	132 kV PALATANA - UDAIPUR	NP-9559-A	PL-18	6673.5	99977.7	6629.6	99977.7	-42.14	0.00	-2,107	0	-2,107
TOTAL												-3,56,318
BGTPP	400 kV BgTPP - BONGAIGAON -1	NP-9683-A	NT-01	81265.3	2.2	81220.8	2.2	-323.64	0.00	-16,182	0	-16,182
	400 kV BgTPP - BONGAIGAON -2	NP-9682-A	NT-02	73113.8	6	73022.1	6	-666.91	0.00	-33,345	0	-33,345
	400 /220 kV BgTPP ICT-1	NP-9644-A	NT-22	31459	0.1	32271.2	0.1	2,599.04	0.00	1,29,952	0	1,29,952
	400 /220 kV BgTPP ICT-2	NP-9681-A	NT-14	30203.9	1.5	31150.2	1.5	3,028.16	0.00	1,51,408	0	1,51,408
TOTAL												2,31,833
KAMENG	400 kV KAMENG- BALIPARA (PG) - 1	NP-9588-A	KA-01	96848	99995	96848	99995	0.00	0.00	0	0	0
	400 kV KAMENG- BALIPARA (PG) -2	NP-9590-A	KA-03	93877.5	99972.5	93876.8	99972.5	-5.09	0.00	-255	0	-255
TOTAL												-255
KOPILI	220 kV KOPILI END OF MISA-1 FDR	NE-0076-A	KK-05	99626.3	99998.9	99609.9	99998.9	-26.24	0.00	-1,312	0	-1,312
	220 kV KOPILI END OF MISA-2 FDR	NE-0078-A	KK-06	99612.4	0.5	99559.3	0.5	-84.96	0.00	-4,248	0	-4,248
	220 kV KOPILI END OF MISA-3 FDR	NE-0080-A	KK-07	99674.3	0.7	99633.8	0.7	-64.80	0.00	-3,240	0	-3,240
TOTAL												-8,800
HVDC_BNC	132 kV CHIMPU – BNC	NP-9961-A	AM-55	99728.3	405.9	99728.3	405.6	0.00	-0.29	0	14	14
	132 kV PAVOI -BNC - 1	NP-9677-A	AM-10	93435.4	5381.7	93435.4	5380.8	0.00	-0.43	0	22	22
	132 kV PAVOI-BNC –2	NP-9678-A	AM-11	92314.4	3708.6	92314.3	3708.5	-0.05	-0.05	-2	2	0
	132 kV GOHPUR - BNC	NP-9962-A	AM-56	99749.1	240.6	99749.1	240.3	0.00	-0.29	0	14	14
	400 kV RANGANADI - BNC 1	NP-9086-A	AM-20	74125.9	99921.4	73821	99921.4	-2,217.45	0.00	-1,10,873	0	-1,10,873
TOTAL												-3,15,404

Note: 1) Rate of Reactive Energy Charge has been considered @ 5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.


 (S.M. Almol) /S.M. Almol
 निदेशक/Director
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong