



भारत सरकार/Government of India

विद्युत मंत्रालय/Ministry of Power

उत्तर पूर्वी क्षेत्रीय विद्युत समिति/North Eastern Regional Power Committee

लपालांग शिलांग-793006/Lapalang, Shillong 793006

क्रमांक एनईआरपीसी/देव/2023/157-179

दिनांक/Dt:03rd Apr., 2024

No. NERPC/Dev/2023

सेवा में / To,

संलग्न सूची के अनुसार / As per list enclosed.

विषय/Sub: एबीटी व्यवस्था के तहत अनंतिम प्रतिक्रियाशील ऊर्जा खाता - 18.03.2024 से 24.03.2024 की अवधि के लिए - तत्संबंधी। / Provisional Reactive Energy Account under ABT regime-for the period 18.03.2024 to 24.03.2024 - Reg.

सर/मैडम,

Sir/Madam.

18.03.2024 से 24.03.2024 की अवधि के लिए पूल के साथ और लाभार्थियों के बीच रुपये में देय / प्राप्य का विवरण देने वाला रिएक्टिव एनर्जी खाते का अनंतिम विवरण इसके साथ भेजा गया है। प्रतिक्रियाशील ऊर्जा के लिए शुल्क/भुगतान की दर सीईआरसी आईईजीसी विनियमन-2023 के अनुसार नियंत्रित की जाएगी, जो 1 अक्टूबर 2023 से 5 पैसे/केवीएआरएच होगी, उसके बाद प्रति वर्ष 0.5 पैसे की वृद्धि की दर से गणना की जाएगी, जब तक कि आयोग द्वारा अन्यथा संशोधित न किया जाए।

इसके अलावा, बिल की गई राशि के लिए घटकों द्वारा भुगतान बिलिंग तिथि के दस दिनों के भीतर किया जाएगा। इन बिलों के भुगतान में बारह दिनों से अधिक की देरी के मामले में, डिफॉल्ट घटकों को आईईजीसी (अक्टूबर 2023) मुद्दे के मानार्थ वाणिज्यिक तंत्र के तहत देरी के प्रत्येक दिन के लिए 0.04% की दर से साधारण ब्याज का भुगतान करना होगा।

उपयोगिताएँ कृपया ध्यान दें कि कुछ ट्रांसमिशन लाइनों के मामले में दोनों सिरों पर मीटर रीडिंग उपलब्ध नहीं है और उपलब्ध जानकारी के आधार पर रिएक्टिव एनर्जी खाता तैयार किया गया है।

घटक अपने अवलोकन/टिप्पणियाँ, यदि कोई हों, खाते के जारी होने की तारीख से 15 दिनों के भीतर भेज सकते हैं। यदि घटकों से कोई संचार प्राप्त नहीं होता है, तो जारी किए गए अनंतिम रिएक्टिव एनर्जी खाता विवरण को अंतिम माना जाएगा।

The Provisional statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 18.03.2024 to 24.03.2024 is sent herewith. The rate for charge/payment for reactive energy will be governed as per CERC IEGC Regulation-2023, which works out to be 5 Paise/KVARH w.e.f from 1st October 2023, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay under complimentary commercial mechanism of IEGC (October 2023) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Constituents may send their observation/ comments, if any on the same within 15 days from the date of issue of the account. In case no communication is received from constituents, the provisional Reactive Energy account statement as issued would be treated as final.

संलग्न -जैसा कि ऊपर बताया गया है।/Enclosed -As above.

भवदीय / Yours faithfully,

(अभिजीत अग्रवाल/Abhijeet Agarwal)

उप निदेशक/Deputy Director

वाणिज्य / Commercial

अभिभाषकों की सूची /List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtiah Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33,Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtiah, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(अभिजीत अग्रवाल/Abhijeet Agarwal)
उप निदेशक/Deputy Director
वाणिज्य / Commercial

Reactive Energy (VArH) Charge Statement
for the period 3/18/2024 to 3/24/2024

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	11,695	0
ASSAM	1,80,316	0
MANIPUR	0	680
MEGHALAYA	0	1,00,921
MIZORAM	7,195	0
NAGALAND	0	4,332
TRIPURA	25,765	0
PARE	0	487
DOYANG	428	0
KHANDONG	10,647	0
KOPII-2	38	0
AGBPP	0	1,37,916
LOKTAK	0	264
AGTCCPP	0	761
RANGANADI	14,035	0
PALATANA	0	77,748
BGTPP	0	1,27,089
KAMENG	0	1,127
KOPII	9,080	0
HVDC_BNC	0	46,939


कार्यवाहक अभियंता Executive Engineer
T. P. सिंह N.E.R.P.C.
विद्युत विभाग Min. of Power
नई दिल्ली Govt. of India
Date: 31/03/2024

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 3/18/2024 to 3/24/2024

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Khupi-Balipara	NP-9606-A	AS-55	26291.8	79.8	26616.6	79.8	116.93	0.00	-5,846	0	-5,846
	132 KV NIRJULI- LEKHI	NP-9664-A	AR-03	99975.5	47447.5	99975.5	47445.2	0.00	-1.66	0	83	83
	132/33kV NIRJULI TRANSFORMER INCOMER-I	NE-0011-A	AR-21	99946.2	60927.1	99946.2	60349	0.00	-173.43	0	8,672	8,672
	132/33kV NIRJULI TRANSFORMER INCOMER-II	NP-0025-A	AR-22	0	0	0	0	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	39821.4	7.5	39850.5	7.5	20.95	0.00	1,048	0	1,048
	132 KV CHIMPU – BNC	NP-9935-A	AR-19	866	96247.8	866.1	96229.4	0.10	-17.66	5	883	888
	132 KV ZIRO - RANGANADI	NP-9704-A	AR-06	85582.3	43.1	86761.7	43.1	212.29	0.00	10,615	0	10,615
	132 KV RANGANADI - LEKHI	NP-9652-A	AR-05	95927.1	97088.2	95922.9	97088.2	-3.02	0.00	-151	0	-151
	220 KV KATHALGURI - DEOMALI	NP-9659-A	AR-07	79173.1	13.3	79067.2	13.3	-84.72	0.00	-4,236	0	-4,236
	132 KV PARE – CHIMPU CKT I	NP-9586-A	AR-08	91092.5	99685.4	91092.1	99691.2	-0.19	2.78	-10	-139	-149
	132 KV PARE – CHIMPU CKT II	NP-9587-A	AR-09	89564.9	97508.5	89564.9	97502.7	0.00	-2.78	0	139	139
	132 KV CHIMPU – GOHPUR	NP-9939-A	AR-20	303.7	97787.6	303.5	97774.2	-0.19	-12.86	-10	643	634
TOTAL												11,695
ASSAM	220kV BTPS-II - SALAKATI	NP-9070-A	AS-15	15825	99830.6	15974.1	99830.6	477.12	0.00	23,856	0	23,856
	220 KV BTPS-SALAKATI –2	NP-8476-A	AS-16	28927.4	99550.3	29069.5	99550.3	454.72	0.00	22,736	0	22,736
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	9479	98581	9472.3	98581	-6.70	0.00	-335	0	-335
	220 KV SAMAGURI – MISA - 2	NP-9713-A	AS-18	35777.4	99202.7	36636.4	99202.7	859.00	0.00	42,950	0	42,950
	220 KV SONABIL- BALIPARA CKT I	NE-0035-A	AS-19	2.9	98344.3	2.9	98345.9	0.00	2.56	0	-128	-128
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	95713.3	79845.2	95472	79845.2	-86.87	0.00	-4,343	0	-4,343
	132 kV JIRIBAM - PAILAPOOL	NP-8498-A	AS-10	67900.6	65156.2	67429.3	65156.2	-226.22	0.00	-11,311	0	-11,311
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	99202	82433.7	99196.4	82454.7	-2.02	7.56	-101	-378	-479
	132 KV HAF LONG (PG)-HAF LONG (AS)	NE-0026-A	AM-57	99020.3	99722.4	98999.2	99722.4	-15.19	0.00	-760	0	-760
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	71447.3	91176.7	71378.2	91176.7	-24.88	0.00	-1,244	0	-1,244
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	76493.7	99933.9	76428.2	99933.9	-23.58	0.00	-1,179	0	-1,179
	220 KV SONABIL- BALIPARA CKT 2	NE-0090-A	AM-66	3896.2	2.5	4081	2.5	295.68	0.00	14,784	0	14,784
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	74755.8	99979.7	74713	99979.7	-15.41	0.00	-770	0	-770
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	62001.8	99985.3	61926.3	99985.3	-27.18	0.00	-1,359	0	-1,359
	132 kV DIMAPUR - BOKAJAN	NP-7587-A	AS-63	57989.9	94844.5	57919	94844.4	-51.05	-0.07	-2,552	4	-2,549
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	88849.7	99741.3	88824.5	99741.3	-183.27	0.00	-9,164	0	-9,164
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	49.2	97568.8	24.7	97568.8	-178.18	0.00	-8,909	0	-8,909
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	89734.1	98720.4	89727.8	98634.7	-2.27	-30.85	-113	1,543	1,429
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	86398.3	98722.2	86251	98722.2	-106.06	0.00	-5,303	0	-5,303
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	7248.6	5032.7	7349.5	5032.7	72.65	0.00	3,632	0	3,632
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	67727.9	99315.1	67459.9	99315.1	-128.64	0.00	-6,432	0	-6,432
	132KV Pavoi - BNC Ckt I	NP-9680-A	AM-12	16454.9	60978.9	16474.3	60969.7	6.98	-3.31	349	166	515
	132KV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50831.1	55510.7	50842.2	55500.2	4.00	-3.78	200	189	389
	132kV Chapakhowa end of Roing-1	NP-0059-A	AM-67	0	0	0	0	0.00	0.00	0	0	0
	132kV Chapakhowa end of Roing-2	NP-0056-A	AM-68	0	0	0	0	0.00	0.00	0	0	0
	132 kV GOHPUR - BNC	NE-0094-A	AM-61	252.8	99329.2	258.8	99314	5.76	-14.59	288	730	1,018
	132 KV CHIMPU – GOHPUR	NE-0093-A	AM-62	99910.5	298	99909	308.2	-1.44	9.79	-72	-490	-562
	132 kV D'CHERA - DHARMANAGAR	NP-9904-A	AS-08	29361.5	99589.1	29558.1	99589.1	94.37	0.00	4,718	0	4,718
	132 kV KAHALIPARA – UMTRU -1	NE-0088-A	AS-01	95111.3	99463.3	95111.3	99463.3	0.00	0.00	0	0	0
	132 kV KAHALIPARA – UMTRU -2	NE-0089-A	AS-02	96653.8	99647.6	96653.8	99647.6	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -1	NP-9921-A	AS-09	99996.4	0.3	99996.4	0.3	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -2	NP-9922-A	AS-50	99996.9	0	99996.9	0	0.00	0.00	0	0	0
	132 KV PANCHGRAM - LUMSHNONG	NP-7595-A	AS-06	76959.4	1085.2	76747.7	1085.1	-101.62	-0.05	-5,081	2	-5,078
	132 kV AGIA – MENDIPATHAR	NP-9455-A	AS-86	60117.1	6674.7	59494.9	6674.7	-298.66	0.00	-14,933	0	-14,933
	132 kV AGIA - NANGALBIBRA	NP-9920-A	AM-58	45783.2	53.5	44942.8	53.5	-302.54	0.00	-15,127	0	-15,127


 कार्यवाहक अभियंता Executive Engineer
 त.पु.वि.म. न.रे.प.स. N.R.P.S.
 विद्युत विभाग Ministry of Power
 गणराज्य भारत Govt of India
 डिप्टी कमिश्नर Discom

	220 kV AGBPP – TINSUKIA - 1	NP-9654-A	AS-53	85414.6	17.2	86332.8	17.2	1,469.12	0.00	73,456	0	73,456
	220 kV AGBPP – TINSUKIA - 2	NP-9658-A	AS-74	83700.4	17.5	84621.4	17.5	1,473.60	0.00	73,680	0	73,680
	132 kV UMRANGSHOO - KHANDONG	NP-5290-A	AM-04	92923.6	98968.5	93193.8	98968.5	129.70	0.00	6,485	0	6,485
	132 kV PARE – NORTH LAKHIMPUR	NE-0117-A	AM-69	33.4	90895.4	33.4	90864.6	0.00	-14.78	0	739	739
	400 /220 kV BgTPP ICT-1	NP-9647-A	AM-42	19742.1	0	20272.8	0	1,273.68	0.00	63,684	0	63,684
	400 /220 kV BgTPP ICT-2	NP-5318-A	AM-28	64984.5	98789.2	65521.9	98789.2	859.84	0.00	42,992	0	42,992
	220 kV AGBPP – MARIANI	NP-6888-A	AS-03	34740.9	96335.1	33401.5	96335.1	-2,143.04	0.00	-1,07,152	0	-1,07,152
	132 kV NORTH LAKHIMPUR-NIRJULI	NE-0119-A	AM-70	36.1	95743.9	36.2	95728.6	0.05	-7.34	2	367	370
TOTAL												1,80,316

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96521.3	99118.1	96523.2	99118.1	0.91	0.00	46	0	46
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	516.2	99931.2	515.9	99931.2	-0.14	0.00	-7	0	-7
	JIRIBAM-TRF	NE-0027-A	MN-04	99911.1	1.9	99911.1	1.9	0.00	0.00	0	0	0
	132 kV JIRIBAM (PG) – JIRIBAM (MN)	NP-9902-A	MN-19	3375.2	30	3387.7	30	3.00	0.00	150	0	150
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	22393.7	384.7	22409.5	384.7	5.69	0.00	-284	0	-284
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19883.8	384.1	19899.3	384.1	5.68	0.00	-279	0	-279
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9946-A	MN-17	27469.8	3	27521.6	3	37.30	0.00	1,865	0	1,865
	132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	5413.6	99966.9	5417.4	99966.9	1.82	0.00	91	0	91
	400 kV IMPHAL – THOUBAL-1	NP-9668-A	MN-28	0	0	0	0	0.00	0.00	0	0	0
	400 kV IMPHAL – THOUBAL-2	NP-9603-A	MN-29	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	93485.5	2.1	93364.7	2.1	-28.99	0.00	-1,450	0	-1,450
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	4229.5	99978.6	4316.8	99978.6	20.95	0.00	1,048	0	1,048
	132 kV KARONG-KOHIMA	NP-9667-A	MN-03	91835.1	97216.8	91823.2	97210.7	-5.71	-2.93	-286	146	-139
TOTAL												-680

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		Net Reactive Charge
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	98282.3	80696.4	98418.6	80696.4	98.14	0.00	4,907	0	4,907
	132kV KHLRT S-PG II	NP-6880-A	ME-09	97135.9	21930.3	97119.5	21930.3	-11.81	0.00	590	0	590
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	86242.3	85965.6	86230.6	85965.6	-18.72	0.00	936	0	936
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	79595.6	96033	79578.5	96033	-27.36	0.00	1,368	0	1,368
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	62943.6	99953.7	62051.1	99953.7	-3,245.45	0.00	-1,62,273	0	-1,62,273
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	36624.3	99864	36888.1	99864	959.27	0.00	47,964	0	47,964
	132 kV KAHALIPARA – UMTRU -1	NP-8474-A	ME-03	99244	99984.8	99244	99984.8	0.00	0.00	0	0	0
	132 kV KAHALIPARA – UMTRU -2	NE-0016-A	ME-04	0.6	0	0.6	0	0.00	0.00	0	0	0
	132 kV SARUSAJAI – UMTRU -1	NP-8473-A	ME-07	90376.5	99820.2	90297.3	99820.2	-38.02	0.00	-1,901	0	-1,901
	132 kV SARUSAJAI – UMTRU -2	NP-8491-A	ME-05	91275.4	99794.6	91196.2	99794.6	-38.02	0.00	-1,901	0	-1,901
	132 kV PANCHGRAM - LUMSHNONG	NP-8384-A	ME-01	97389	60769.8	97395.7	60769.5	3.22	-0.14	161	7	168
	132 kV AGIA – MENDIPATHAR	NP-9945-A	ME-17	99697.5	91264.7	99728.8	91264.7	15.02	0.00	751	0	751
TOTAL												-1,00,921

MIZORAM	132kV LAUNG MUAL-AIZWAL PG	NP-9495-A	MZ-02	779.1	10180.6	783.3	10232.4	4.03	49.73	-202	2,486	2,285
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	61720	54873	61512.8	54936.1	-74.59	22.72	3,730	1,136	4,865
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	0	0	0	0	0.00	0.00	0	0	0
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	0	0	0	0	0.00	0.00	0	0	0
	132kV Shimui-Melriat(PG)-I	NP-9493-A	MZ-17	99071.5	98904.2	99065.1	98894.9	-2.30	-3.35	-115	167	52
	132kV Shimui-Melriat(PG)-II	NP-9496-A	MZ-18	99051.5	99069.5	99042.8	99061.2	-3.13	-2.99	-157	149	-7
TOTAL												7,195

NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	18151.5	10244.6	18192.3	10245.8	39.17	1.15	-1,958	58	-1,901
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	76478.8	5815.6	76543.4	5817.7	46.51	1.51	-2,326	76	-2,250
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	6245.6	98146.1	6201.9	98146.2	-15.73	0.04	787	2	788
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44603.6	5173	44603.6	5178.6	0.00	2.02	0	-101	-101
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	44016	5262.8	44016	5268.9	0.00	2.20	0	-110	-110
	132 kV KARONG-KOHIMA	NP-9947-A	NG-02	1883.5	99913.9	1888.8	99913.9	1.59	0.00	80	0	80
	132 kV DHEP - SANIS	NP-6148-A	NG-22	0	0	0	0	0.00	0.00	0	0	0
	132 kV DHEP - MOKOKCHUNG	NP-9671-A	NG-05	51615.8	13802.9	51615.8	13849.5	0.00	16.78	0	-839	-839


 कार्यवाहक अभियंता Executive Engineer
 त. व. वि. म. न. ए. पी. C. E.
 विभाग, मंत्रालय, वि. मंत्रालय
 जिला कार्यालय, गुवाहाटी
 तारीख: 01/08/2023

TOTAL												-4,332
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97396.1	84658.6	97393.1	84658.6	-2.88	0.00	144	0	144
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7330.4	99970.6	7330.4	99970.6	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14694.9	26.4	14694.9	26.4	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10555.8	99995	10555.8	99995	0.00	0.00	0	0	0
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	5135.8	99999.8	5132.4	99999.8	-3.26	0.00	163	0	163
	132 kV D'CHERA - DHARMANAGAR	NP-6892-B	TR-06	76269	21856.2	76269	20814.4	0.00	-500.06	0	25,003	25,003
	132 kV AGARTALA - AGTPP - 1	NP-6850-A	TR-01	6819	6224.5	6806.9	6224.5	-11.62	0.00	-581	0	-581
	132 kV AGARTALA - AGTPP - 2	NP-6851-A	TR-02	47233.1	93754.2	47223.9	93754.2	-8.83	0.00	-442	0	-442
	132 kV PK BARI- RC NAGAR-1	NP-9933-A	TR-21	1528.1	99781.6	1528.1	99774.1	0.00	-7.20	0	360	360
TOTAL	132 kV PK BARI- RC NAGAR-2	NP-9932-A	TR-22	1459.9	99997.1	1462.4	99997.1	2.40	0.00	120	0	120
	132 kV PALATANA - SM NAGAR	NP-8471-A	TR-13	68973.7	72313.1	68973.7	72313.1	0.00	0.00	0	0	0
	132 kV PALATANA - UDAIPUR	NP-8470-A	TR-14	53228.2	55102.9	53255.9	55102.9	19.94	0.00	997	0	997
	25,765											
PARE	132 kV PARE – NIRJULI	NP-9409-A	PA-03	58249.3	2887.3	58250.2	2901.6	0.86	13.73	43	-686	-643
	32 kV PARE – CHIMPU CKT I	NP-9411-A	PA-05	2911	98773	2911	98757.1	0.00	-7.63	0	382	382
	132 kV PARE – CHIMPU CKT II	NP-9538-A	PA-07	69200.2	98735.5	69200.2	98722.3	0.00	-6.34	0	317	317
	132 kV PARE – NORTH LAKHIMPUR	NP-9607-A	PA-01	58513.3	3466.1	58511.4	3475.5	-1.82	9.02	-91	-451	-542
TOTAL												-487
DOYANG	132kV DHEP - DIMAPUR(PG) - 1	NP-9066-A	DY-01	81995	77772.6	81995	77712.2	0.00	-43.49	0	2,174	2,174
	132kV DHEP - DIMAPUR(PG) -2	NP-9050-A	DY-02	70750	88350.1	70750	88346.6	0.00	-2.52	0	126	126
	132 kV DHEP - SANIS	NP-8799-A	DY-03	19266.7	12217.3	19266.7	12259	0.00	30.02	0	-1,501	-1,501
	132 kV DHEP - MOKOKCHUNG	NP-9053-A	DY-04	57636.4	10734.6	57636.5	10745	0.07	7.49	4	-374	-371
TOTAL												428
KHANDONG	132kV KHANDONG - KHLRT - 1	NE-0114-A	KK-31	991.9	6.6	2113.2	6.6	403.67	0.00	20,183	0	20,183
	132kV KHANDONG - KHLRT - 2	NE-0066-A	KK-30	89095.4	230.8	88931.8	230.8	-58.90	0.00	-2,945	0	-2,945
	132 kV UMRANGSHOO - KHANDONG	NE-0138-A	KK-32	91417.7	99970	91234.6	99970	-131.83	0.00	-6,592	0	-6,592
TOTAL												10,647
KOPILI-2	KOPILI GT OF STG-2	NE-0140-A	KK-42	44426.9	99914.5	44426.9	99914.5	0.00	0.00	0	0	0
	KOPILI STG-2 33 kV STN TRF	NE-0137-A	KK-40	3420.9	9.2	3522.6	9.2	0.76	0.00	38	0	38
TOTAL												38
AGBPP	220 kV AGBPP – MARIANI PG	NP-9582-A	KT-02	64409.5	1.1	65768.2	1.1	2,173.92	0.00	1,08,696	0	1,08,696
	KTG END OF 220kV DEOMALI FDR	NP-9566-A	KT-14	40659	99999.4	40208.3	99999.4	-360.56	0.00	-18,028	0	-18,028
	220 kV AGBPP – MARIANI	NP-9625-A	KT-01	9377.2	99930.9	9137.5	99930.9	-383.52	0.00	-19,176	0	-19,176
	220 kV AGBPP – TINSUKIA - 1	NP-9650-A	KT-15	96126.4	0.9	94804.3	0.9	-2,115.36	0.00	-1,05,768	0	-1,05,768
	220 kV AGBPP – TINSUKIA - 2	NP-9443-A	KT-16	90817.9	1.2	89522.4	1.2	-2,072.80	0.00	-1,03,640	0	-1,03,640
TOTAL												-1,37,916
LOKTAK	132 kV LOKTAK - JIRIBAM	NP-9064-A	LO-02	48737.1	97858.1	48723.5	97858.1	-6.53	0.00	-326	0	-326
	132 kV LOKTAK - IMPHAL (PG)	NP-9044-A	LO-03	33164.4	97680.5	33170.7	97680.5	3.02	0.00	151	0	151
	132 kV LOKTAK – RENGPAANG	NP-9065-A	LO-01	53636.5	98096	53631.7	98096	-2.30	0.00	-115	0	-115
	132 kV LOKTAK – NINGTHOUKONG	NP-9045-A	LO-04	6637.3	6603.8	6638.5	6603.9	0.58	0.05	29	-2	26
TOTAL												-264
AGTCCPP	132 kV AGTPP - KUMARGHAT	NP-9080-A	AG-03	54584.6	97035.4	54584.6	97035.2	0.00	-0.14	0	7	7
	132 kV AGARTALA - AGTPP - 1	NP-9081-A	AG-01	23179.4	4817.8	23179.4	4817.9	0.00	0.10	0	-5	-5
	132 kV AGARTALA - AGTPP - 2	NP-9093-A	AG-02	23242.9	6503.3	23242.9	6503.4	0.00	0.10	0	-5	-5
	132 kV PK BARI- RC NAGAR-1	NP-9940-A	AG-16	96418.1	99998.3	96410.3	99998.3	-7.49	0.00	-374	0	-374
	132 kV PK BARI- RC NAGAR-12	NP-9941-A	AG-17	95623.5	99999.6	95615.5	99999.6	-7.68	0.00	-384	0	-384
TOTAL												-761
RANGANADI	400 kV RANGANADI - BNC 1	NP-6033-A	RN-02	73432.1	99945	73420.4	99945	-42.55	0.00	-2,127	0	-2,127
	400 kV RANGANADI - BNC 2	NP-5817-A	RN-03	92142.7	99986.5	92061	99986.5	-297.09	0.00	-14,855	0	-14,855
	132 kV RANGANADI - LEKHI	NP-5792-A	RN-01	13653.6	99720.3	14712	99720.3	635.04	0.00	31,752	0	31,752
	132 kV ZIRO - RANGANADI	NP-5278-A	RN-11	41589.3	97934.1	41564.8	97934.1	-14.70	0.00	-735	0	-735
TOTAL												14,035


 कार्यवाहक अभियंता Executive Engineer
 तृ तृ वि म N.E.R.P.C.
 भारत सरकार Min of Power
 नया दिल्ली Govt of India
 110068 New Delhi

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
PALATANA	400 kV PALATANA - SILCHAR -1	NP-9558-A	PL-16	15835.7	99998.3	15783.4	99998.3	-190.18	0.00	-9,509	0	-9,509
	400 kV PALATANA - SILCHAR -2	NP-9560-A	PL-17	45515.7	99993.5	45222.4	99993.5	-1,066.55	0.00	-53,327	0	-53,327
	400 kV PALATANA – SM NGR_ST	NE-0013-A	PL-22	61521	2.3	61441.1	2.3	-290.55	0.00	-14,527	0	-14,527
	132 kV PALATANA - SM NAGAR	NP-9561-A	PL-19	21086.6	27.6	21086.2	27.6	-0.77	0.00	-38	0	-38
	132 kV PALATANA - UDAIPUR	NP-9559-A	PL-18	6554.7	99977.8	6547.5	99977.8	-6.91	0.00	-346	0	-346
TOTAL												-77,748
BGTPP	400 kV BgTPP - BONGAIGAON -1	NP-9683-A	NT-01	80919	2.2	80918.7	2.2	-2.18	0.00	-109	0	-109
	400 kV BgTPP - BONGAIGAON -2	NP-9682-A	NT-02	72553.2	6	72513.5	6	-288.73	0.00	-14,436	0	-14,436
	400 /220 kV BgTPP ICT-1	NP-9644-A	NT-22	37994.4	0.1	38273.5	0.1	893.12	0.00	-44,656	0	-44,656
	400 /220 kV BgTPP ICT-2	NP-9681-A	NT-14	38292.3	1.5	38716.6	1.5	1,357.76	0.00	-67,888	0	-67,888
TOTAL												-1,27,089
KAMENG	400 kV KAMENG- BALIPARA (PG) - 1	NP-9588-A	KA-01	96644.4	99995	96644.3	99995	-0.73	0.00	-36	0	-36
	400 kV KAMENG- BALIPARA (PG) -2	NP-9590-A	KA-03	93598.6	99972.5	93595.6	99972.5	-21.82	0.00	-1,091	0	-1,091
TOTAL												-1,127
KOPILI	220 kV KOPILI END OF MISA-1 FDR	NE-0076-A	KK-05	99986.4	99998.9	25	99998.9	61.76	0.00	3,088	0	3,088
	220 kV KOPILI END OF MISA-2 FDR	NE-0078-A	KK-06	99923.4	0.5	99965.7	0.5	67.68	0.00	3,384	0	3,384
	220 kV KOPILI END OF MISA-3 FDR	NE-0080-A	KK-07	99889.2	0.7	99921.8	0.7	52.16	0.00	2,608	0	2,608
TOTAL												9,080
HVDC_BNC	132 kV CHIMPU – BNC	NP-9961-A	AM-55	99680.9	407.4	99680.9	415.7	0.00	7.97	0	-398	-398
	132 kV PAVOI -BNC - 1	NP-9677-A	AM-10	93306.6	5378	93306.6	5380.9	0.00	1.39	0	-70	-70
	132 kV PAVOI-BNC –2	NP-9678-A	AM-11	92046.6	3707.9	92035.7	3707.9	-5.23	0.00	-262	0	-262
	132 kV GOHPUR - BNC	NP-9962-A	AM-56	99700.3	241.4	99700.3	248.8	0.00	7.10	0	-355	-355
	400 kV RANGANADI - BNC 1	NP-9086-A	AM-20	72093.2	99921.4	71992.5	99921.4	-732.36	0.00	-36,618	0	-36,618
TOTAL												-46,939

Note: 1) Rate of Reactive Energy Charge has been considered @ 5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.


 कार्यवाहक अभियंता Executive Engineer
 तृतीय क्षेत्र NERPC
 विद्युत विभाग Min of Power
 भारत सरकार Govt of India
 शिलांग Shillong