Name of Element SHUTDOWNS PROPOSED BY PGCIL		2 3	4	5	6	7 8	,	10			Sep-:												Time	Reason	
SHUTDOWNS PROPOSED BY PGCIL									1 12	13 14	15	16 17	18	19	20 21	22	23 24	25 2	6 27	28	29	30	1 inte	Reason	Category
132kV RC NAGR(NEEPCO)-AGARTLA(TRIPURA)-2																							0800 Hrs to 1700 Hrs	AMP OF BAY EQUIPMENTS	Normal Maintenance rela shutdown.
132kV SM.NAGAR(TSECL)-COMILLA(BANGLAD)-1																							0800 Hrs to 1700 Hrs	AMP OF BAY EQUIPMENTS	Normal Maintenance rela shutdown.
132kV SM NAGAR(TSECL)-PALATANA(OTPC)-1																							0800 Hrs to 1700 Hrs	AMP OF BAY EQUIPMENTS	Normal Maintenance rela shutdown.
132kV BISWANATH CHARIALI-PAVOI(ASSAM)-1																							0830 Hrs to 1730 Hrs	Intsallation of TLA	Existing system improven related shutdown.
132kV BISWANATH CHARIALI-PAVOI(ASSAM)-2											П												0830 Hrs to 1730 Hrs	Intsallation of TLA	Existing system improven related shutdown.
132kV JIRIBAM-HAFLONG																							0800 Hrs to 1600 Hrs	Attending of Shutdtown natuer line defects works (Badarapur TLM)	Normal Maintenance rela shutdown.
132kV JIRIBAM-LOKTAK(NHPC)-2																							1000 Hrs to 1700 Hrs	For Relay firmware Upgradation works MICOM P442.	Existing system improven related shutdown.
132kV JIRIBAM-TIPAIMUKH(MANIPUR)																							0900 Hrs to 1630 Hrs	For Relay firmware Upgradation works MICOM P442.	Existing system improver
																									related shutdown.  Existing system improven
132kV Jiribam-Poilapool Line 132kV AIZWAL-MELRIAT																							0930 Hrs to 1630 Hrs 1000 Hrs to 1400 Hrs	For Relay firmware Upgradation works MICOM P442.  For Testing of 50-LBB & 67-OC&EF relay in Aizawl bay	related shutdown.  Normal Maintenance rela
32kV AIZWAL-MELRIAT											Н												1000 Hrs to 1400 Hrs	(#101) at Melriat SS	shutdown.
132kV AIZWAL-KOLASIB(MIZORAM)																							0800 Hrs to 1400 Hrs	REPLACEMENT OF PLCC CABLE AT KOLASIB SUBSTATION by Badrapur	Existing system improven related shutdown.
132kV TEZU-NAMSAI-1																							0800 Hrs to 1700 Hrs	For erection of Circuit Breaker under 132 kV Main Bus of Namsai Substation. Work will be carried out under TBCB NERSS-XV work of 220 kV GIS Upgradation work. S/D under Project/Construction head	Construction activities related shutdown.
132 KV ZIRO DAPORIJO TL																							0900 Hrs to 1700 Hrs	FOR AMP WORKS	Normal Maintenance rela shutdown.
132kV BADARPUR-JIRIBAM-1																							0800 Hrs to 1700 Hrs	Replacement of porcelain insulator strings with CLR insulators at major crossings in 132 KV Badarpur-Jiribam TL	Existing system improven related shutdown.
132kV BADARPUR-BADARPUR(ASSAM)-1																							0800 Hrs to 1700 Hrs	AMP OF BAY EQUIPMENTS AT AEGCL PANCHGRAM END.	Normal Maintenance rela shutdown.
132kV LOKTAK(NHPC)-IMPHAL																							0800 Hrs to 1700 Hrs	For Charging the Transmission Line through GIS Bus under NERSS-XIII.	Construction activities related shutdown.
132kV IMPHAL-DIMAPUR-1																				4		⇒	<b>CSD</b> 0700 Hrs to 1700 Hrs	For Shifting of TL Tower Loc. No. 162 (Diversion Work or account of criticality due to landslide on permanent towers).	Construction activities related shutdown.
132kV IMPHAL-IMPHAL(MANIPUR)-1																							0800 Hrs to 1700 Hrs	For Testing and Commissioning of Line Differential relay under NERSS-XIII.	related shutdown.
132kV Imphal(Manipur)-Imphal(PG)-2																							0800 Hrs to 1700 Hrs	For Testing and Commissioning of Line Differential relay under NERSS-XIII.	related shutdown.
132kV Imphal(Manipur)-Imphal(PG)-3																							0800 Hrs to 1700 Hrs	For Testing and Commissioning of Line Differential relay under NERSS-XIII.	Construction activities related shutdown.
132kV BADARPUR-KHLIEHRIAT-1	$\preceq$																						CSD 0700 Hrs to 1800 Hrs	Continious shutdown for HTLS reconductoring works under NERSS-XX project scheme & minutes of 11th	Construction activities related shutdown.
																								Continious shutdown for HTLS reconductoring works	Construction activities
132kV KHANDONG(NEEPCO)-KHLIEHRIAT-2																							CSD 0700 Hrs to 1800 Hrs	under NERSS-XX project scheme & minutes of 11th CMETS NER	related shutdown.
132kV Jiribam - Tipaimukh																							0700 Hrs to 1800 Hrs	For OPGW installation work under relaiable communication Scheme on long spans in the area of deep valleys/River crossing etc	Construction activities related shutdown.
A/R of 132kV IMPHAL-DIMAPUR-1																							0700 Hrs to 1700 Hrs	NON AUTO MODE OF D-I LINE FOR OPGW RESTRINGING WORK BY M/S APAR	Construction activities related shutdown.
A/R of 132kV KHANDONG(NEEPCO)-KHLIEHRIAT-2																							0700 Hrs to 1800 Hrs	NON-AUTO MODE required for OPGW installation works under Reliable Communication Scheme.	Construction activities related shutdown.
A/R of 132kV BADARPUR-KHLIEHRIAT-1																							0700 Hrs to 1800 Hrs	NON-AUTO MODE required for OPGW installation works under Reliable Communication Scheme.	Construction activities related shutdown.
A/R of 132 KV ZIRO DAPORIJO TL																							0800 Hrs to 1700 Hrs	NON-AUTO MODE REQUIRED FOR OPGW STRINING WORKS BY COMP T&D, ZIRO ARUNACHAL PRADESH	Construction activities related shutdown.
A/R of 132kV KHLIEHRIAT-KHLIEHRIAT(MePTCL)-1																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme.	Construction activities related shutdown.
A/R of 132kV Jiribam - Tipaimukh																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme.	Construction activities related shutdown.
A/R of 132kV Tipaimukh - Aizwal																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme.	Construction activities related shutdown.
A/R of 132kV Dimapur (PG) - Kohima (PG)																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme. /Data Shutdown also required for existing OPGW replacement work.	Construction activities related shutdown.
A/R of 132kV Kohima (PG) - Imphal (PG)																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme. /Data	Construction activities related shutdown.
-																								works under Reliable Communication Scheme.  NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme. /Data	related shutdow
A/R of 132kV Kohima (PG) - Imphal (PG)																							0700 Hrs to 1800 Hrs	NON - AUTO MODE required for OPGW installation works under Reliable Communication Scheme. /Data Shutdown also required for existing OPGW replacement work.	Construction activities related shutdown.
	1	2 3		5	6	7 8	9	10	1 12	13 14	Sep-	24	18	19	20 21	22	23 24	25 2	6 27	28	29	30		work.	Category
220kV Transmission lines																								For shifting of DT send CH-I & II to Spare output contact	Normal Maintenance re
220kV BONGAIGAON-SALAKATI-1								1		_		-		$\vdash$				_	+			_	0900 Hrs to 1200 Hrs	in PU -P743 relay	shutdown.  Normal Maintenance re
220kV BONGAIGAON-SALAKATI-2								Щ			San	24	Щ										0900 Hrs to 1700 Hrs	GD Tripping Logic Modification works	shutdown.
400kV Transmission lines	1	2 3	4	5	6	7 8	9	10	1 12	13 14	15 15	16 17	18	19	20 21	22	23 24	25 2	6 27	28	29	30			Category
400kV SILCHAR AZARA LINE ALONG WITH 63MVAR,SWLR OF AZARA AT SILCHAR																							0900 Hrs to 1700 Hrs	ABB Relay Firmware upgradation. M1 and M2 Relay testing.	Existing system improved related shutdown.
400kV BISWANATH CHARIALI-RANGANADI(NEEPCO)-I																			<			<b>+</b>	CSD 0800 Hrs to 1800 Hrs	Diversion work of section of 400kV D/C Ranganadi-BNC line on account of construction of 4lane highway by NHIDCL at loc no 167-168	Construction activities related shutdown.

	100kV BALIPARA-BISWANATH CHARIALI-2																			enhancing the overall reliability of the system.	related shutdown.
39 4																			0900 Hrs to 1700 Hrs	Modifications and confirmatory testing of Protection relays to comply latest Protection Scheme and observations for enhancing the overall reliability of the system.	Existing system improvement related shutdown.
	100kV BALIPARA-BISWANATH CHARIALI-4																		0900 Hrs to 1700 Hrs	Modifications and confirmatory testing of Protection relays to comply latest Protection Scheme and observations for enhancing the overall reliability of the system.	Existing system improvement related shutdown.
40 4	100kV MISA-NEW MARIANI-2																		0900 Hrs to 1700 Hrs	Replacement of porcelain insulator strings with CLR insulators at major crossings	Existing system improvement related shutdown.
41 4	100kV MISA-NEW MARIANI-I																		0900 Hrs to 1700 Hrs	Replacement of porcelain insulator strings with CLR insulators at major crossings	Existing system improvement related shutdown.
42 4	100 kV Kohima -Mariani line -II																		0900 Hrs to 1700 Hrs	For enabling the DEF setting in line protection.	Existing system improvement related shutdown.
	1201 V.N 1. 00	1	2 3	4 5	6	7 8	9 10	11 12	13 14	Sep-24 15 16	17 18	19	20 21	22 23	24 25	26 27	28 2	9 30			Category
43 5	132kV Nirjuli SS 60MVA,132/33kV ICT-1 AT NIRJULI GIS																		0800 Hrs to 1700 Hrs	AMP works and replacement of LV CB	Normal Maintenance related shutdown.
44 1	220kV Dimapur SS 60MVA 220/132KV ICT#1 (201 &107) BAY AT DIMAPUR SS																		0000 H t- 1000 H	ATTENDING OIL LEAKAGE IN OLTC PIPELINE ,	Normal Maintenance related
44 []	220kV Mokokchung SS																		0800 Hrs to 1600 Hrs	REPAIRING OF PNRV valave and AMP works	shutdown.
45 3	11.5MVAR,BUS REACTOR-1 AT MOKOKCHUNG																		0900 Hrs to 1700 Hrs	Differential, REF, B/U Impedence relay firmware upgradation works	Existing system improvement related shutdown.
46.4	400kV Balipara SS 100/220KV 315MVA ICT#2 (401T) AT BALIPARA																			AND OF THE 19T	Normal Maintenance related
																			0900 Hrs to 1700 Hrs	AMP OF THE ICT	shutdown.
47 4	100KV ICT-2 AND BUSREACTOR-2 TIE BAY (402) AT BALIPARA																		0900 Hrs to 1700 Hrs	AMP OF THE BAY	Normal Maintenance related shutdown.
48 4	100KV BONGAIGAON-1 MAIN BAY (415) AT BALIPARA																		0900 Hrs to 1700 Hrs	AMP OF THE BAY	Normal Maintenance related shutdown.
49 4	100KV BONGAIGAON-2 MAIN BAY (416) AT BALIPARA																		0900 Hrs to 1700 Hrs	AMP OF THE BAY	Normal Maintenance related shutdown.
50 4	100KV MISA-2 MAIN BAY (BAY-409) AT BALIPARA								_										0900 Hrs to 1700 Hrs	ABB AUXILLIARY SWITCH REPALCEMENT	Normal Maintenance related shutdown.
51 2	120/132KV 160MVA ICT-1 (219T) AT BALIPARA																		CSD 0900 Hrs to 1700 Hrs	Replacement of existing bushings with RIP bushings of 145KV Bushing CGL make in ICT-1.	Existing system improvement related shutdown.
	400kV Imphal SS																	, ·		145KV Bushing CGL make in IC1-1.	related shutdown.
52 3	15MVA,400/132/33kV ICT-1 AT IMPHAL						+	<b>-&gt;</b>											CSD 0800 Hrs to 1700 Hrs	For Transformer Wiring and 132kV panel Commissioning under NERSS-XIII.	Construction activities related shutdown.
53 3	115MVA,400/132/33kV ICT-2 AT IMPHAL																		CSD 0800 Hrs to 1700 Hrs	For Transformer Wiring and 132kV panel Commissioning under NERSS-XIII.	Construction activities related shutdown.
54 5	i0MVA,132/33kV ICT-1 AT IMPHAL									/_									CSD 0800 Hrs to 1700 Hrs	For Wiring and Charging of ICT-1 through GIS Bus under	Construction activities
	· ·											4								NERSS-XIII.  For Wiring and Charging of ICT-2 through GIS Bus under	related shutdown.  Construction activities
	i0MVA,132/33kV ICT-2 AT IMPHAL																		CSD 0800 Hrs to 1700 Hrs	NERSS-XIII	related shutdown.  Construction activities
56 2	0MVAR,BUS REACTOR-1 AT IMPHAL													<b></b>					CSD 0800 Hrs to 1700 Hrs	For Wiring and Charging of BR through GIS Bus under NERSS-XIII.	construction activities related shutdown.
57 (I	32kV MAN BUS AT IMPHAL Half portion of 132kV Main Bus shall be under Shut down condition Half portion of 132kV Main Bus shall be under Shut down condition town condition from 0500hrs to 1600hrs & 132kV Imphal-1, insighunkhong-1, Kotaki-2, 132kV LeT-1 & 2, 132kV Bus Reactor, 32kV Dimapur shall be in charged condition from 0600hrs to 1500hrs))																		0500 Hrs to 0600 Hrs 1500 Hrs to 1600 Hrs (All 132kV elements and ICTs shall be under shutdown)	For Opening and Closing of 132kV Bus Jumper for full fledge charging from AIS to GIS (For Jumper connection & testing)	Construction activities related shutdown.
	400kV Misa SS																				
58 4	100kV ICT-1 Main Bay at Misa S/S (Bay 401)																		0900 Hrs to 1700 Hrs	AMP of Bay Equipments in ICT-1 Main Bay at Misa. ICT shall remain charged through Tie Bay	Normal Maintenance related shutdown.
59 5	60MVAR,BUS REACTOR-1 AT MISA																		0800 Hrs to 1700 Hrs	AMP of Bus Reactor and associated Bay Equipments, replacement of Buchholz relay	Normal Maintenance related shutdown.
<b>60</b>   2 cl	t16 Bay of 220kV Misa-Dimpaur-2 line at Misa SS. Line will be charged through transfer bus coupler bay								$\Rightarrow$										CSD 0800 Hrs to 1700 Hrs	Circuit Breaker mechanism overhauling and testing of CB at Misa S/S. All other feeders will be connected to 220kV Bus B	Normal Maintenance related shutdown.
	400kV Silchar SS																				
61 1:	25MVAR,BUS REACTOR-3 AT SILCHAR																		0900 Hrs to 1700 Hrs	Modification of Gas Zone Tripping along with shutdown of future bay 424. Replacement of OTI. Cleaning and Tightening works.	Normal Maintenance related shutdown.
62 4	100KV Future Bay (425-BAY) AT SILCHAR																		0900 Hrs to 1200 Hrs	Gas zone trip modification.	Normal Maintenance related shutdown.
63 4	100KV Future Bay (430 Bay) AT SILCHAR																		1300 Hrs to 1700 Hrs	Gas zone trip modification.	Normal Maintenance related shutdown.
64 4	100kV Palatana 2 Tie Bay 408 AT SILCHAR																		0900 Hrs to 1700 Hrs	AMP of Bay Equipments. Tightening cleaning works.	Normal Maintenance related shutdown.
65 4	100KV Future Bay (424 Bay) AT SILCHAR																		0900 Hrs to 1700 Hrs	Gas zone trip modification.	Normal Maintenance related shutdown.
	400kV BNC SS																				

	ANNUTY LOUI LAB PROGRA																		2000 II	AMP of Bay equipment as per Preventive Maintenance	Normal Maintenance related
	400kV Filter-1 Subbank-2 Bay at BNC SS																		0900 Hrs to 1600 Hrs	Schedule  AMP of Bay equipment as per Preventive Maintenance	shutdown.  Normal Maintenance related
6	7 400kV Filter-1 Subbank-4 Bay at BNC SS																		0900 Hrs to 1600 Hrs	Schedule.	shutdown.
6	400kV BNC-Balipara Ckt-3 Main Bay at BNC SS																		0900 Hrs to 1600 Hrs	AMP of Bay equipment as per Preventive Maintenance Schedule	Normal Maintenance related shutdown.
6	80MVAR,BUS REACTOR-1 AT B'CHARIALI																		0800 Hrs to 1600 Hrs	AMP of Bus-reactor-1 and AMP of Bus Reactor-1 Main bay equipment as per preventive maintenance schedule.	Normal Maintenance related shutdown.
7	80MVAR, 400kV BUS REACTOR-2 AT BISWANATH CHARIALI																		0800 Hrs to 1600 Hrs	AMP of Bus-reactor-2 and AMP of Bus Reactor-2 Main bay equipment as per preventive maintenance schedule.	Normal Maintenance related shutdown.
7	63MVAR, LR OF 400kV LOWER SUBHANSERI-1 AT BNC																		0800 Hrs to 1600 Hrs	AMP of Line Reactor as per preventive maintenance schedule.	Normal Maintenance related shutdown.
7	2 132kV BNC-Pavoi ckt-2 Main Bay at BNC SS																		0900 Hrs to 1600 Hrs	Confirmatory DCRM Signature testing of Main Bay Breaker. The Line will be in service through TBC Bay	Normal Maintenance related shutdown.
7	400kV Bongaigaon SS 400kV BUR-REACTOR-2 & BALIPARA-2 TIE BAY (BAY NO 411) AT BONGAIGAON																		0900 Hrs to 1700 Hrs	For replacement of electromechanical LBB relay with Numerical relay (Micom P141) in bay no 411.	Existing system improvement related shutdown.
7	4 400kV BUS-REACTOR-2 MAIN BAY (BAY NO 410) AT BONGAIGAON																		0900 Hrs to 1130 Hrs	FOR TESTING OF LBB Numerical relay which is installed in Bay no 411.	Existing system improvement related shutdown.
7	400kV BALIPARA-2 MAIN BAY ( BAY NO 412) AT BONGAIGAON																		1130 Hrs to 1500 Hrs	FOR TESTING OF LBB RELAY INSTALLED IN BAY NO 411.	Existing system improvement related shutdown.
7	400kV BALIPARA-1 & ALIPURDUAR-1 TIE BAY (BAY NO 414) AT BONGAIGAON																		0900 Hrs to 1700 Hrs	For replacement of existing electromechanical LBB relay (English electric) with numerical relay (Micom P141) in bay no 414.	Existing system improvement related shutdown.
7	400kV ALIPURDUAR-I MAIN BAY (BAY NO 415) AT BONGAIGAON																		1130 Hrs to 1500 Hrs	FOR TESTING OF LBB RELAY INSTALLED IN BAY NO 414.	Existing system improvement related shutdown.
7	3 400kV Balipara-4 Main Bay at Bongaigaon s/s																		0900 Hrs to 1700 Hrs	AMP of Bay equipments.	Normal Maintenance related shutdown.
7	125MVAR,BUS REACTOR-5 AT BONGAIGAON																		0900 Hrs to 1700 Hrs	AMP of BUS REACTOR.	Normal Maintenance related shutdown.
8	400kV BUS-REACTOR-2 MAIN BAY AT 400KV BONGAIGAON S/S																		0900 Hrs to 1700 Hrs	AMP of Bay Equipments.	Normal Maintenance related shutdown.
8	400kV BALIPARA-3 MAIN BAY AT BONGAIGAON S/S																		0900 Hrs to 1700 Hrs	AMP of Bay Equipments.	Normal Maintenance related shutdown.
8	400kV AZARA MAIN BAY AT BONGAIGAON S/S																		0900 Hrs to 2000 Hrs	AMP of Bay Equipments.	Normal Maintenance related shutdown.
	Name of Flament		2 3	4 5	6 7	8 9	10 11	12 13	Se 14 15	p-24	17 18	19 20	21 :	2 23	24	25   26	27 28	29 30	Time	Remarks	Category
	Interregional/International																				
8	3 400KV Bongaigaon-Siliguri-1																		0900 Hrs to 1700 Hrs	Measurement of Line Impedance under Bay Upgradation works	Construction activities related shutdown.
8	4 400KV Bongaigaon-Siliguri-2																		0900 Hrs to 1700 Hrs	Measurement of Line Impedance under Bay Upgradation works	Construction activities related shutdown.
8	800kV HVDC AGRA-BISWANATHCHARIALI POLE-I													<b>(</b> =					CSD 1000 Hrs to 1800 Hrs	Diversion work of 800 kv hvdc BNC-Agra line infringing to Lucknow-Kanpur green Express way of NHAI(All 4 poles will be out of service)	Shutdown by NR-3
8	5 800kV HVDC AGRA-BISWANATHCHARIALI POLE-2													<b>—</b>					CSD 1000 Hrs to 1800 Hrs	Diversion work of 800 kv hvdc BNC-Agra line infringing to Lucknow-Kanpur green Express way of NHAI(All 4 poles will be out of service)	Shutdown by NR-3
8	800kV HVDC AGRA-BISWANATHCHARIALI POLE-3													<b>(</b>					CSD 1000 Hrs to 1800 Hrs	Diversion work of 800 kv hvdc BNC-Agra line infringing to Lucknow-Kanpur green Express way of NHAI(All 4 poles will be out of service)	Shutdown by NR-3
8	8 800kV HVDC AGRA-BISWANATHCHARIALI POLE-4													<b>(</b>					CSD 1000 Hrs to 1800 Hrs	Diversion work of 800 kv hvdc BNC-Agra line infringing to Lucknow-Kanpur green Express way of NHAI(All 4 poles will be out of service)	Shutdown by NR-3
Si	Name of Element		2 3	4 5	6 7	8 9	10 11	12 13		p-24	17 18	19 20	21 :	2 23	24	25 26	27 28	29 30	Time	Reason	Category
	SHUTDOWNS PROPOSED BY ASSAM																				Normal Maintenance related
	1 220KV SAMAGURI-JAWAHARNAGAR 2 220KV SAMAGURI-JAWAHARNAGAR																		8:00-16:00 8:00-16:00	CORRIDOR CLEARANCE CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	3 220KV SAMAGURI-JAWAHARNAGAR																		8:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	4 220KV SARUSAJAI-SONAPUR																		8:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	5 220KV SARUSAJAI-SONAPUR	$\vdash$	-						-	+					+				8:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	6 220KV SAMAGURI-SONAPUR																		8:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	7 220KV SAMAGURI-SONAPUR																		8:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Maintenance related
	8 132KV BOKAJAN-DIMAPUR																		9:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	9 132KV BOKAJAN-SARUPATHAR		-										+++	+					9:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	0 220KV AMGURI-MARIANI	$\vdash$	-							+	-			+	$\vdash$				9:00-16:00 8:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	1 220KV SAMAGURI-MARIANI	$\vdash$								++				+						CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	1 220KV SAMAGURI-MARIANI 2 220KV SAMAGURI-MARIANI		-							+				+	$\vdash$				8:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
		$\vdash$	-							+	-		+++	+					8:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	3 220KV AMGURI-NTPS	$\vdash$	-							+				+	H				8:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	4 220KV AMGURI-NTPS									1				-	$\Box$				8:00-16:00	CLEANING PREVENTIVE MAINTENANCE & CORRIDOR	shutdown. Normal Maintenance related
	5 132KV GOHPUR-NALKATA CKT 1										_		+	+					7:00-14:00	CLEANING	shutdown.
	6 132KV GOHPUR-NALKATA CKT 1												+	-					7:00-14:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.
	7 132KV GOHPUR-NALKATA CKT 2																		7:00-14:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.
	8 132KV GOHPUR-NALKATA CKT 2																		7:00-14:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.
	9 132KV GOLAGHAT-MARIANI																		8:00-16:00	CORRIDOR CLEARANCE	Normal Maintenance related shutdown.
:	0 132KV GOLAGHAT-SARUPATHAR																		8:00-16:00	CORRIDOR CLEARANCE	Normal Maintenance related shutdown.
:	1 220 KV Rangia-Salakati Ckt-1																		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.
:	2 220 KV Rangia-Salakati Ckt-2																		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.
:	3 400KV MIRZA-SILCHAR														Ш				8:00-16:00	PRE PUJA MAINTENANCE WORKS	Normal Maintenance related shutdown.
:	4 400KV MIRZA-BONGAIGAON																		8:00-16:00	PRE PUJA MAINTENANCE WORKS	Normal Maintenance related shutdown.
										-		-			-	-				•	

								_				_			_		_								
25	400/220KV, 315 AT-1 AT MIRZA																					8:00-16:00	PRE PUJA MAINTENANCE WORKS	Normal Mai shutdown.	intenance related
26	400/220KV , 315 AT-2 AT MIRZA	T	T																			8:00-16:00	PRE PUJA MAINTENANCE WORKS	Normal Mai	intenance related
		+	-																		_			shutdown. Normal Mai	intenance related
27	220kV AGIA-BTPS CKT I	4	_						$\perp \perp$													9:00-16:00	CORRIDOR CLEARANCE	shutdown.	
28	220kV AGIA-BTPS CKT 1																					9:00-16:00	CORRIDOR CLEARANCE	Normal Mai shutdown.	intenance related
29	220kV AGIA-BTPS CKT 2	Т	T																			9:00-16:00	CORRIDOR CLEARANCE	Normal Mai shutdown.	intenance related
30	220kV AGIA-BTPS CKT 2	_	$\pm$																			9:00-16:00	CORRIDOR CLEARANCE	Normal Mai	intenance related
		+	+	-	+		-	+				+-							-		+			shutdown.	intenance related
31	220KV AGIA-BOKO		4																			9:00-16:00	CORRIDOR CLEARANCE	shutdown.	
32	220KV AGIA-BOKO																					9:00-16:00	CORRIDOR CLEARANCE	Normal Mai shutdown.	intenance related
33	220KV AGIA-MIRZA																					9:00-16:00	CORRIDOR CLEARANCE	Normal Mai	intenance related
2.4	220KV AGIA-MIRZA	+	+																			9:00-16:00	CORRIDOR CLEARANCE	shutdown. Normal Mai	intenance related
		_	-																			9:00-16:00	CORRIDOR CLEARANCE	shutdown.	
35	220KV MIRZA-BOKO																					8:00-16:00	CORRIDOR CLEARANCE	shutdown.	intenance related
36	220KV MIRZA-BOKO																					8:00-16:01	CORRIDOR CLEARANCE	Normal Mai shutdown.	intenance related
37	220/132KV , 100 MVA TRAFO 1		$\top$																			10:00-16:00	PRE PUJA PREVENTIVE MAINTENANCE	Normal Mai	intenance related
		+	+		-		-	-	+-	-		-									-			shutdown.	intenance related
38	220/132KV , 160 MVA TRAFO 2		_																			10:00-16:00	PRE PUJA PREVENTIVE MAINTENANCE	shutdown.	
39	220/132KV , 100 MVA TRAFO 3																					10:00-16:00	PRE PUJA PREVENTIVE MAINTENANCE	Normal Mai shutdown.	intenance related
40	220kV TINSUKIA-KATHALGURI CKT 1																					9:00-16:00	CORRIDOR CLEANING		intenance related
		+	+	_	-		_	+-				+-		+		-	_		_		+			shutdown. Normal Mai	intenance related
	220kV TINSUKIA-KATHALGURI CKT 2	+	+	$\perp$	+	+	$\perp$	+-	$\perp$	$\perp$		_		$\vdash$		+	$\perp$	++	-	++	+	9:00-16:00	CORRIDOR CLEANING	shutdown.	
42	220KV TINSUKIA-NTPS																					9:00-16:00	CORRIDOR CLEANING	Normal Mai shutdown.	iintenance related
43	220KV TINSUKIA-NRPP	T	T																			9:00-16:00	CORRIDOR CLEANING	Normal Mai shutdown.	intenance related
44	32KV BUSES AT TINSUKIA	+	+					+	+					$\Box$		11						6-00-9-00	PRE PUJA PREVENTIVE MAINTENANCE	Normal Mai	intenance related
		+	+	+	-	++	+	+				+	-	+	-	+	-	+ +			+			shutdown. Normal Mai	intenance related
-	32KV PAILAPOOL-JIRIBUM		_					_								$\perp$		$\perp$	$\perp$			9:00-16:00	CORRIDOR CLEANING	shutdown.	
46	32KV HAFLONG-HAFLONG (PG)																					9:00-15:00	CORRIDOR CLEANING	Normal Mai shutdown.	intenance related
47	220KV SSJI-MIRZA CKT 1		$\top$																			8:00-16:00	CORRIDOR CLEANING	Normal Mai	intenance related
-		+	+	+	+	+++	+	_	+-	++		+		+			+	+++	+		-			shutdown. Normal Mai	intenance related
_	220KV SSJI-MIRZA CKT 2			_		$\perp$	$\perp$	+	$\perp$	$\perp$				$\square$				+	_		-	8:00-16:00	CORRIDOR CLEANING	shutdown.	
49	32 KV HAILAKANDI-DULLAVCHERRA TL															ш						09:00-16:00	Preventive maintenance and corridor cleaning work	shutdown.	intenance related
50	132 KV SRIKONA-PAILAPOOL TL	T																				09:00-16:00	Preventive maintenance and corridor cleaning work		intenance related
	132 KV PANCHGRAM-HAILAKANDI TL	+	+	+			+					+		+			-					09:00-16:00	Preventive maintenance and corridor cleaning work	Normal Mai	intenance related
		+	+	+	-	++	+		4	+		-	-	+	-	++	-	++	-	-	-		-	shutdown.	intenance related
52	32 KV PANCHGRAM-HAILAKANDI TL		_															$\perp$				09:00-16:00	Preventive maintenance and corridor cleaning work	shutdown.	
53	32 KV PANCHGRAM-LUMSHNONG TL																					09:00-16:00	Preventive maintenance and corridor cleaning work	Normal Mai shutdown.	intenance related
54	132 KV SRIKONA-PAILAPOOL TL		$\top$																			09:00-16:00	Preventive maintenance and corridor cleaning work	Normal Mai	intenance related
		+	+	-	+	++	+	+-	++	++			-	++	-		+	+	-		+		For Pre-Puia Bus and substation Maintenenace work No.	shutdown.	
55	132 kV Main Bus of 132 kV Hailakandi GSS																					06:00-14:00	power flow will be possible form Hailakandi GSS during the	Normal Mai shutdown.	intenance related
**	132 KV DULLAVCHERRA-DHARMANAGAR TL	+	+	+	+		+	+	+	+		+		+	-		-		+		+	09:00-16:00	shutdown period		intenance related
		+	+	_	-	++	+	+	++	+				$\vdash$	_	+	+		_		-		For Pre-Puja Line Maintenenace and corridor cleaning work		
57	32 KV DULLAVCHERRA-DHARMANAGAR TL																					09:00-16:00	For Pre-Puja Line Maintenenace and corridor cleaning work	shutdown.	intenance related
58	132 kV Main Bus of 132 kV Panchgram GSS																					06:00-14:00			intenance related
56	32 kv Main bus of 132 kv Fancigram GSS																					00:00-14:00	the shutdown period	shutdown.	
50	132 kV Main Bus of 132 kV Dullavcherra GSS																					05:00-12:00			intenance related
39	32 kv Main bus of 132 kv Duliaveliella GSS																					03.00-12.00	the shutdown period	Siluluowii.	
60	32KV MAIN BUS AT PAVOI ( As)																					4:30-9:00	PRE PUJA MAINTENANCE. FULL BLACKOUT.	Normal Mai shutdown.	intenance related
61	220KV SAMAGURI-SONABIL 1		$\top$																			8:00-16:00	Preventive maintenance and corridor cleaning work	Normal Mai	intenance related
		+	+	-	-		-	-				+-	-	+		-	-	+	-		+			shutdown.	intenance related
62	220KV SAMAGURI-SONABIL 2		_																			8:00-16:00	Preventive maintenance and corridor cleaning work	shutdown.	
63	220 KV Main Bus-I & II AT BOKO																					5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160 MVA TRAFO AT BOKO	Normal Mai shutdown.	intenance related
64	220 KV Main Bus-I & II AT BOKO																					5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160	Normal Mai	intenance related
			4				+	+	+	+		+		+		+	+	+	+		+		MVA TRAFO AT BOKO AUGMENTATION WORKS RELATED TO NEW 160	shutdown. Normal Mai	intenance related
	220 KV Main Bus-I & II AT BOKO	+	4			-	$\perp$	+-	$\perp$	++		_		$\vdash$	_	+	$\perp$	++	-	+	+	5:00-10:00	MVA TRAFO AT BOKO	shutdown.	
66	220 KV Main Bus-I AT BOKO																					5:00-10:00	MVA TRAFO AT BOKO	shutdown.	intenance related
67	220 KV Main Bus-II AT BOKO	T	T	T	T							T										5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160 MVA TRAFO AT BOKO	Normal Mai	intenance related
	220 KV Main Bus-L& II AT BOKO	+	+	+			+	+	+	+				+		++						5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160	shutdown. Normal Mai	intenance related
		+	+	+	-	++	+	+	+	+				+	-	++	-	++	-	-	-		MVA TRAFO AT BOKO	shutdown.	intenance related
69	220 KV Main Bus-I & II AT BOKO		_																			5:00-10:00	MVA TRAFO AT BOKO	shutdown.	
70	220 KV Main Bus-I & II AT BOKO																					5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160 MVA TRAFO AT BOKO	Normal Mai shutdown.	intenance related
71	220 KV Main Bus-I AT BOKO	$\top$	+	$\top$				+														5:00-10:00	AUGMENTATION WORKS RELATED TO NEW 160	Normal Mai	intenance related
		+	+	-		++	+	+-	++	++		-				++	-	+	+		+		MVA TRAFO AT BOKO AUGMENTATION WORKS RELATED TO NEW 160	shutdown. Normal Mai	intenance related
72	220 KV Main Bus-II AT BOKO	4	_					_	Щ.	Щ			Щ	Щ							1	5:00-10:00	MVA TRAFO AT BOKO	shutdown.	
SN	Name of Element										I3 14 15	ep-24			20		,,		26	10		Time	Reason	C	Category
		1		, ,	3			1	10 11	12	13 14 15	16	17 18	19	20 21	12	25 24	25	27	28 25	36				
	SHUTDOWNS PROPOSED BY TRIPURA		+	+		+++	-	4	++	++				+			+	+	+					Normal Mai	intenance related
- 1	132 KV Main Bus Udaipur S/Stn		4	_				4	$\perp \perp$									$\perp$			1	(9 am to 4 pm)		shutdown.	
2	132 KV Dhalabil S/S (132 KV Bus).																					(9 am to 4 pm)		Normal Mai shutdown.	intenance related
3	132 KV Ambassa - PK Bari (ISTS) Line							T														(9 am to 4 pm)	n n: 1 -1	Normal Mai	intenance related
-				+	+		+	+	+	+		+	_	+	-	++	-	+++	+		+		Dea Duis shutdown		intenance related
	132 KV Rokhia - Agartala Line II	-			-		+	+	++	+	-	-	-	+	_	+	-	+++	-		-	(9 am to 4 pm)	Pre-Puja shutdown	shutdown.	
					$\perp$		$\perp$										$\perp$		$\perp$		$\perp$	(9 am to 4 pm)	Pre-Puja shutdown	shutdown.	intenance related
	132 KV Kamalpur - PK Bari Line	_																				(9 am to 4 pm)	Pre-Puja shutdown	Normal Mai shutdown.	intenance related
5															1	_	_				_				intenance related
5	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II		4				+	+-											1	1 1		(9 sm to 4 mm)		Normal Mai	
5 6 7	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungnagar Line		#														-	-			-	(9 am to 4 pm)	Pre-Puja shutdown	shutdown.	
5 6 7	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II		#																			(9 am to 4 pm) (9 am to 4 pm)	Pre-Puja shutdown Pre-Puja shutdown	shutdown. Normal Mai shutdown.	intenance related
5 6 7 8	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungnagar Line		<u> </u>																				Pre-Puja shutdown Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai	intenance related
5 6 7 8	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungruspar Line 132 KV Agartala - Gamaitilla Line 132 KV Baramura - Gamaitilla Line																					(9 am to 4 pm)	Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai	intenance related
5 6 7 8 9	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungmagar Line 132 KV Baramura - Gamaitilla Line 132 KV Baramura - Jinnia Line 132 KV Baramura - Jinnia Line 132 KV Rokhia - Agartala Line I																					(9 am to 4 pm) (9 am to 4 pm) (9 am to 4 pm)	Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown.	intenance related
5 6 7 8 9	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungruspar Line 132 KV Agartala - Gamaitilla Line 132 KV Baramura - Gamaitilla Line																					(9 am to 4 pm)	Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown.	intenance related intenance related intenance related intenance related
5 6 7 8 9 10	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungmagar Line 132 KV Baramura - Gamaitilla Line 132 KV Baramura - Jinnia Line 132 KV Baramura - Jinnia Line 132 KV Rokhia - Agartala Line I																					(9 am to 4 pm) (9 am to 4 pm) (9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown.	intenance related
5 6 7 8 9 10 11	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agurtala - Bodhjungmagar Line 132 KV Baramura - Gamaitilla Line 132 KV Baramura - Jirania Line 132 KV Baramura - Jirania Line 132 KV Rokhia - Agartala Line I																					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown.	intenance related intenance related intenance related intenance related
5 6 7 8 9 10 11 12	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Rokhia - Agartala Line II 132 KV Baramura - Gamatitila Line 132 KV Baramura - Jirania Line 132 KV Baramura - Jirania Line 132 KV Rokhia - Agartala Line II 132 KV Rokhia - Agartala Line II 132 KV Surjamaninagar (ISTS) - Bodhjungnugar Line 132 KV Surjamaninagar (ISTS) - Bodhjungnugar Line																					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai shutdown. Normal Mai	intenance related intenance related intenance related intenance related intenance related
5 6 7 8 9 10 11 12	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Agartala - Bodhjungmagar Line 132 KV Baramura - Gamatitlla Line 132 KV Baramura - Jirania Line 132 KV Borkiia - Agartala Line I 132 KV Rokhia - Agartala Line I 132 KV Rokhia - Agartala Line II 132 KV Surjamaniragar (ISTS) - Bodhjungnagar Line																					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Mai shutdown.	intenance related iintenance related iintenance related iintenance related iintenance related iintenance related iintenance related
5 6 7 8 9 10 11 12 13	132 KV Kamalpur - PK Bari Line 132 KV Rokhia - Agartala Line II 132 KV Rokhia - Agartala Line II 132 KV Baramura - Gamatitila Line 132 KV Baramura - Jirania Line 132 KV Baramura - Jirania Line 132 KV Rokhia - Agartala Line II 132 KV Rokhia - Agartala Line II 132 KV Surjamaninagar (ISTS) - Bodhjungnugar Line 132 KV Surjamaninagar (ISTS) - Bodhjungnugar Line																					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Mai shutdown.	intenance related intenance related intenance related intenance related intenance related intenance related

16	32 KV Bus-1 of Agartala S/S with 132KV Agartala -Rokhia Line I & II																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
	32 KV Mission Tilla S/S (132 KV Bus)									_				+					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
	<u> </u>																			· · · · · · · · · · · · · · · · · · ·	shutdown. Normal Maintenance related
	32 KV Kamalpur - Dhalabill Line																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
_	32 KV Udaipur - Palatana Line																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
20	32 KV P.K. Bari (TSECL) - P.K. Bari (ISTS) Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
21	32 KV Surjamaninagar - Bodhjungnagar Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
22	32 KV Rokhia - Agartala Line II																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
23	32 KV Ambassa - P.K Bari (ISTS) Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
24	32 KV Kamalpur - Dhalabill Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
	32 KV Udaipur - Palatana Line			_															(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
_	32 KV Baramura - Gamaitilla Line			_																	shutdown. Normal Maintenance related
																			(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
27	32 KV Missiontilla - Durllavcherra Line																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
28	32 KV DC of Rokhia - Monarchak - Udaipur (LILO)																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
29	32 KV PK Bari - Missiontilla Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
30	32 KV Gamaitilla - Ambassa Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
31	32 KV Rokhia - Monarchak Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
32	32 KV Ambassa S/S (132 KV Bus)																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
-																				· ·	shutdown. Normal Maintenance related
-	32 KV Surjamaninagar - Bodhjungnagar Line			+										+				$\Box$	(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
	32 KV Mohanpur - Dhalabill Line				+								++						(9 am to 4 pm)	Pre-Puja shutdown	shutdown.  Normal Maintenance related
-	32 KV Rokhia - Agartala Line I																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
36	32 KV Surjamaninagar (TSECL) - Surjamaninagar (ISTS) Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
37	32 KV Agartala - Mohanpur Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
38	32 KV Baramura - Gamaitilla Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
_	32 KV P.K Bari - KGT PowerGrid line													+					(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
-	32 KV Rokhia - Agartala Line I								+					+					(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
				-																-	shutdown. Normal Maintenance related
_	32 KV Surjamaninagar (TSECL) - Surjamaninagar (ISTS) Line																	$\perp$	(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
42	32 KV Rokhia - Monarchak Line																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
43	32 KV P.K Bari (TSECL) - P.K Bari (ISTS) Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
44	32 KV Surjamaninagar - Bodhjungnagar Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
45	32 KV Bodhjungnagar - Jirania Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
46	32 KV PK Bari - Missiontilla Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
47	32 KV Monarchak - Udaipur Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
				-																	shutdown. Normal Maintenance related
48	32 KV Agartala - Bodhjungnagar line. 32 KV Bus-3 of Agartala S/S with Agartala -Bodhjungnagar, Agartala -																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
	iwiyagai Ellic i & ii, Aganala - KC iyagai Ellic ii																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
50	32 KV Main Bus Gamaitilla S/S																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
51	32 KV Udaipur - Palatana Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
52	32 KV Agartala - Bodhjungnagar Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
53	32 KV Ambassa - P.K Bari (ISTS) Line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
54	32 KV P K Bari - Missiontilla Line																		(9 am to 4 pm)	Pre-Puia shutdown	Normal Maintenance related
-																				Pre-Puja shutdown	shutdown. Normal Maintenance related
_	32 KV Surjamaninagar - Agartala Line I			-														$\vdash$	(9 am to 4 pm)		shutdown. Normal Maintenance related
-	32 KV Surjamaninagar (ISTS)- Bodhjungnagar								$\perp$					$\perp$					(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
57	32 KV Gamaitilla-Ambassa Line													$\perp$					(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
58	32 KV Mohanpur - Dhalabil line																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
59	32 KV Surjamaninagar (TSECL)- Surjamaninagar (ISTS) Line			Т														П	(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related shutdown.
60	32 KV bus of Surjamaninagar S/Stn. (Bus-1)																		(9 am to 4 pm)	Pre-Puja shutdown	Normal Maintenance related
	32 KV Kamalpur S/S (132 Kv Bus)																		(9 am to 4 pm)	Pre-Puja shutdown	shutdown. Normal Maintenance related
-									+					+							shutdown. Normal Maintenance related
62	32 KV Agartala - Mohanpur Line								Щ.	Sep-24									(9 am to 4 pm)	Pre-Puja shutdown	shutdown.
SN	Name of Element	1 2	3 .	4 5	6 1	8 9	10 11	12 13	14	15 16	17 18	19 20	21 :	2 23	24 25	26 27	28 29	30	Time	Reason	Category
	SHUTDOWNS PROPOSED BY MEGHALAYA																				
1	32KV Lumshong -Panchgram line																		10:00 - 14:00	Jungle clearing at T-Loc 312,313	Normal Maintenance related shutdown.
2	20kV Killing - Misa 1																		08:00 - 16:00	Prevetive Maintenanc of Terminal Equipments	Normal Maintenance related shutdown.
-	20kV Killing - Misa 2													+					08:00 - 16:00	Prevetive Maintenanc of Terminal Equipments	Normal Maintenance related
_	32KV Nongal-Agia II Line			+		+ +				-			+++	+					07:00 - 12:00	Replacement of broken disc and jumper repairing at Loc 7.	shutdown. Normal Maintenance related
-													+++	-							shutdown. Normal Maintenance related
-	32KV Nongal-Agia II Line			_					+										08:00 - 15:00	Jungle Clearance at Loc 70-89 & 235-247.	shutdown. Normal Maintenance related
6	60MVA 220kV/132kV ICT# 1 at Killing s/s																		08:00 - 16:00	Prevetive Maintenanc of ICT	shutdown.
7	60MVA 220kV/132kV ICT# 1 at Killing s/s																		08:00 - 16:00	Prevetive Maintenanc of Terminal Equipments LV side	Normal Maintenance related shutdown.
8	60MVA 220kV/132kV ICT# 1 at Killing s/s			Т														П	08:00 - 16:00	Prevetive Maintenanc of Terminal Equipments HV Side	Normal Maintenance related shutdown.
9	32KV Mendipathar-Agia Line																		09:00 - 14:00	Jungle Clearance at Loc 252-262	Normal Maintenance related shutdown.
_	60MVA 220kV/132kV ICT# 2 at Killing s/s																		08:00 - 14:00	Transformer oil filtration works and Aircell repairing works	Normal Maintenance related
-									+												Normal Maintenance related
11	32KV Mendipathar-Agia Line								Щ.	Sep-24									09:00 - 14:00	Jungle Clearance at Loc 297-299 & 310-214.	shutdown.
	Name of Element						10 11	12 13	14									30	Time	Reason	Category
SN	value of Element	1 2	3 4							100	17 18	19 20	21 :	2 23	24 25	26 27	28 29	30 1			
SN	SHUTDOWNS PROPOSED BY NAGALAND	1 2	3 .								17 18	19 20	21 .	2 23	24 25	26 27	28 29	30			Normal Maintenance related

											S	ep-24																	
Name of Element	2 3	3 4	5	6	7	8	,	10	 2 15	3 1	4 15	16	17	7 1	8 19	20	21	22	23	24	25	26	27	28	29 3	30	Time	Reason	Category
SHUTDOWNS PROPOSED BY ARUNACHAL PRADESH																													
1 132 kV Khuppi-Kimi Line																											08:00 hrs to 17:00hrs	Installation of numerical directional overcurrent E/F relay(Micom P14D) for Kimi line at Khuppi & routine vegetation clearance	Normal Maintenance related shutdown.
2 132 kV Tenga-Khupi Line																											08:00 hrs to 17:00hrs	Installation of numerical directional overcurrent E/F relay(Micom P14D) for Tenga line at Khuppi & routine vegetation clearance	Normal Maintenance related shutdown.
3 132 kV Balipara-Tenga Line																											08:00 hrs to 17:00hrs	Vegetation clearance	Normal Maintenance related shutdown.
4 220 KV Kathalguri-Deomali Line																											0800 Hrs to 1500 Hrs	Vegetation clearance	Normal Maintenance related shutdown.