



भारत सरकार/Government of India

विद्युत मंत्रालय/Ministry of Power

उत्तर पूर्वी क्षेत्रीय विद्युत समिति/North Eastern Regional Power Committee

लपालांग शिलांग-793006/Lapalang, Shillong 793006

क्रमांक एनईआरपीसी/देव/2024/5133-5155

दिनांक/Dt: 19th Nov., 2024

No. NERPC/Dev/2024/5133-5155

सेवा में / To,

संलग्न सूची के अनुसार / As per list enclosed.

विषय/Sub: एबीटी व्यवस्था के तहत अनंतिम प्रतिक्रियाशील ऊर्जा खाता 04.11.2024 से 10.11.2024 की अवधि के लिए - तत्संबंधी। / Provisional Reactive Energy Account under ABT regime-for the period 04.11.2024 to 10.11.2024 -Reg.

सर/मैडम,

Sir/Madam.

04.11.2024 से 10.11.2024 की अवधि के लिए पूल के साथ और लाभार्थियों के बीच रुपये में देय / प्राप्य का विवरण देने वाला रिएक्टिव एनर्जी खाते का अनंतिम विवरण इसके साथ भेजा गया है। प्रतिक्रियाशील ऊर्जा के लिए शुल्क/भुगतान की दर सीईआरसी आईईजीसी विनियमन-2023 के अनुसार नियंत्रित की जाएगी, जो 1 अक्टूबर 2024 से 5.5 पैसे/केवीएआरएच होगी, उसके बाद प्रति वर्ष 0.5 पैसे की वृद्धि की दर से गणना की जाएगी, जब तक कि आयोग द्वारा अन्यथा संशोधित न किया जाए।

इसके अलावा, बिल की गई राशि के लिए घटकों द्वारा भुगतान बिलिंग तिथि के दस दिनों के भीतर किया जाएगा। इन बिलों के भुगतान में बारह दिनों से अधिक की देरी के मामले में, डिफॉल्ट घटकों को आईईजीसी (अक्टूबर 2023) मुद्दे के मानार्थ वाणिज्यिक तंत्र के तहत देरी के प्रत्येक दिन के लिए 0.04% की दर से साधारण ब्याज का भुगतान करना होगा।

उपयोगिताएँ कृपया ध्यान दें कि कुछ ट्रांसमिशन लाइनों के मामले में दोनों सिरों पर मीटर रीडिंग उपलब्ध नहीं है और उपलब्ध जानकारी के आधार पर रिएक्टिव एनर्जी खाता तैयार किया गया है।

घटक अपने अवलोकन/टिप्पणियाँ, यदि कोई हों, खाते के जारी होने की तारीख से 15 दिनों के भीतर भेज सकते हैं। यदि घटकों से कोई संचार प्राप्त नहीं होता है, तो जारी किए गए अनंतिम रिएक्टिव एनर्जी खाता विवरण को अंतिम माना जाएगा।

The Provisional statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 04.11.2024 to 10.11.2024 is sent herewith. The rate for charge/payment for reactive energy will be governed as per CERC IEGC Regulation-2023, which works out to be 5.5 Paise/KVARH w.e.f from 1st October 2024, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay under complimentary commercial mechanism of IEGC (October 2023) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Constituents may send their observation/ comments, if any on the same within 15 days from the date of issue of the account. In case no communication is received from constituents, the provisional Reactive Energy account statement as issued would be treated as final.

संलग्न -जैसा कि ऊपर बताया गया है।/Enclosed -As above.

भवदीय / Yours faithfully,


(माया कुमारी/Maya Kumari)

उप निदेशक/Deputy Director

वाणिज्य / Commercial

अभिभाषकों की सूची /List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtiah Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33,Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtiah, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



माया कुमारी / Maya Kumari
उप-निदेशक / Deputy Director
उप-नि. वि. स. / N.E.R.P.C.
विद्युत विभाग / Ministry of Power
भारत सरकार / Govt. of India
शिलांग / Shillong

(माया कुमारी/Maya Kumari)
उप निदेशक/Deputy Director
वाणिज्य / Commercial

**Reactive Energy (VArH) Charge Statement
for the period 04/11/2024 to 10/11/2024**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	0	7,588
ASSAM	1,11,508	0
MANIPUR	13,734	0
MEGHALAYA	23,516	0
MIZORAM	1,863	0
NAGALAND	649	0
TRIPURA	35,825	0
PARE	0	0
DOYANG	8	0
KHANDONG	1,303	0
KOPILI-2	0	5,244
AGBPP	1,61,762	0
LOKTAK	0	37
AGTCCPP	0	0
RANGANADI	0	45,760
PALATANA	0	1,14,059
BGTPP	0	2,23,573
KAMENG	0	0
KOPILI	8,149	0
HVDC_BNC	0	0


माया कुमारी / Maya Kumari
उप-निरीक्षक / Deputy Director
उ.पु.बि.स. / N.E.R.P.C.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India
Dispur / Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 04/11/2024 to 10/11/2024

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Khupi-Balipara	NP-9606-A	AS-55	35727	80	35902.9	80	63.32	0.00	-3,483	0	-3,483
	132 KV NIRJULI - LEKHI	NP-9664-A	AR-03	25.3	47288.2	25.3	47288.2	0.00	0.00	0	0	0
	132/33kV NIRJULI TRANSFORMER INCOMER-I	NE-0011-A	AR-21	99909.1	54418.1	99909.1	54353.9	0.00	-19.26	0	1,059	1,059
	132/33kV NIRJULI TRANSFORMER INCOMER-II	NP-0025-A	AR-22	0	0	0	0	0.00	0.00	0	0	0
	132kV Tenga-Balipara	NP-9696-A	AR-17	42436.8	7.8	42441.4	7.8	3.31	0.00	182	0	182
	132 KV CHIMPU – BNC	NP-9935-A	AR-19	921.6	96097.7	921.6	96097.7	0.00	0.00	0	0	0
	132 KV ZIRO - RANGANADI	NP-9704-A	AR-06	95844.2	73	95844.2	72.6	0.00	-0.07	0	4	4
	132 KV RANGANADI - LEKHI	NP-9652-A	AR-05	95772.4	94843.3	95772.4	94843.3	0.00	0.00	0	0	0
	220 KV KATHALGURI - DEOMALI	NP-9659-A	AR-07	75640.7	13.2	75519.1	13.2	-97.28	0.00	-5,350	0	-5,350
	132 KV PARE – CHIMPU CKT I	NP-9586-A	AR-08	90942.8	99691.4	90942.8	99691.4	0.00	0.00	0	0	0
	132 KV PARE – CHIMPU CKT II	NP-9587-A	AR-09	89558.3	96652	89558.3	96652	0.00	0.00	0	0	0
	132 KV CHIMPU – GOHPUR	NP-9939-A	AR-20	289.3	97701.5	289.3	97701.5	0.00	0.00	0	0	0
TOTAL												-7,588
ASSAM	220kV BTPS-II - SALAKATI	NP-9070-A	AS-15	13083	99830.5	13377	99830.5	940.80	0.00	51,744	0	51,744
	220 KV BTPS-SALAKATI – 2	NP-8476-A	AS-16	26548.4	99550.2	26852.4	99550.2	972.80	0.00	53,504	0	53,504
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	13924.8	98575.8	14039.9	98575.8	115.10	0.00	6,331	0	6,331
	220 KV SAMAGURI – MISA - 2	NP-9713-A	AS-18	44083.3	99201.5	44546.2	99201.5	462.90	0.00	25,460	0	25,460
	220 KV SONABIL - BALIPARA CKT I	NE-0035-A	AS-19	2.9	97310.9	2.9	97310.9	0.00	0.00	0	0	0
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	92232	79844.8	92181.1	79844.8	-18.32	0.00	-1,008	0	-1,008
	132 KV JIRIBAM - PAILAPOOL	NP-8498-A	AS-10	63676.2	65155.7	63529.9	65155.7	-70.22	0.00	-3,862	0	-3,862
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	98974.5	82597.1	98974.5	82597.1	0.00	0.00	0	0	0
	132 KV HAFLONG (PG)-HAFLONG (AS)	NE-0026-A	AM-57	98558.1	99666.8	98528.1	99666.8	-21.60	0.00	-1,188	0	-1,188
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	70406.9	91176.3	70395.7	91176.3	-4.03	0.00	-222	0	-222
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	75498.7	99933.7	75490	99933.6	-3.13	-0.04	-172	2	-170
	220 KV SONABIL - BALIPARA CKT 2	NE-0090-A	AM-66	4774.5	2.3	4909.7	2.3	216.32	0.00	11,898	0	11,898
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	72896.2	99979.2	72856.8	99979.2	-14.18	0.00	-780	0	-780
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	59073.6	99984.9	58990.7	99984.9	-29.84	0.00	-1,641	0	-1,641
	132 KV DIMAPUR - BOKAJAN	NP-7587-A	AS-63	57594.9	94231.6	57591.6	94224	-2.38	-5.47	-131	301	170
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	87740.5	99691.6	87696.2	99691.6	-322.18	0.00	-17,720	0	-17,720
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	99255	97524	99132.7	97524	-889.45	0.00	-48,920	0	-48,920
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	95324	695.4	95327	666.9	1.08	-10.26	59	564	624
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	84875.3	98656.6	84873.2	98656.5	-1.51	-0.07	-83	4	-79
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	8055.7	4823.2	8055.7	4823.2	0.00	0.00	0	0	0
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	56748	99309.7	56537.8	99309.7	-100.90	0.00	-5,549	0	-5,549
	132KV PavoI - BNC Ckt I	NP-9680-A	AM-12	16761.2	60963.6	16761.2	60963.6	0.00	0.00	0	0	0
	132KV PavoI - BNC Ckt II	NP-8801-A	AM-13	51075	55493.5	51075	55493.5	0.00	0.00	0	0	0
	132kV Chapakhowa end of Roing-1	NP-0059-A	AM-67	0	0	0	0	0.00	0.00	0	0	0
	132kV Chapakhowa end of Roing-2	NP-0056-A	AM-68	0	0	0	0	0.00	0.00	0	0	0
	132 KV GOHPUR - BNC	NE-0094-A	AM-61	445.8	99241.6	445.8	99241.6	0.00	0.00	0	0	0
	132 KV CHIMPU – GOHPUR	NE-0093-A	AM-62	99843.9	335.2	99843.9	335.2	0.00	0.00	0	0	0
	132 KV D'CHERA - DHARMANAGAR	NP-9904-A	AS-08	31007.9	99395.3	31012.5	99395.3	2.21	0.00	121	0	121
	132 KV KAHELIPARA – UMTRU -1	NE-0088-A	AS-01	92711.9	99423.3	92618.4	99423.3	-44.88	0.00	-2,468	0	-2,468
	132 KV KAHELIPARA – UMTRU -2	NE-0089-A	AS-02	95837.9	99624	95837.9	99624	0.00	0.00	0	0	0
	132 KV SARUSAJAI – UMTRU -1	NP-9921-A	AS-09	99997.9	0.3	99997.9	0.3	0.00	0.00	0	0	0
	132 KV SARUSAJAI – UMTRU -2	NP-9922-A	AS-50	99996.9	0	99996.9	0	0.00	0.00	0	0	0
	132 KV PANCHGRAM - LUMSHNONG	NP-7595-A	AS-06	75367.3	1085.1	75335.6	1085.1	-15.22	0.00	-837	0	-837
	132 KV AGIA – MENDIPATHAR	NP-9455-A	AS-86	52129.7	6627.4	51216.9	6627.4	-438.14	0.00	-24,098	0	-24,098
	132 KV AGIA - NANGALBIBRA	NP-9920-A	AM-58	33338	99904.8	32032.3	99904.8	-470.05	0.00	-25,853	0	-25,853

माया कुमारी / Maya Kumari
उप-निरीक्षक / Deputy Director
उ.पु.क्ष.वि.स. / U.P. & S. / N.E.R.P.C.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India
दिसपुर / Shillong

220 kV AGBPP – TINSUKIA - 1	NP-9654-A	AS-53	81254.5	16.7	81015.2	16.7	-382.88	0.00	-21,058	0	-21,058
220 kV AGBPP – TINSUKIA - 2	NP-9658-A	AS-74	79349	17	79056.1	17	-468.64	0.00	-25,775	0	-25,775
132 kV UMRANGSHOO - KHANDONG	NP-5290-A	AM-04	0	0	0	0	0.00	0.00	0	0	0
132 kV PARE – NORTH LAKHIMPUR	NE-0117-A	AM-69	41.8	84004.4	41.8	84004.4	0.00	0.00	0	0	0
400 /220 kV BgTPP ICT-1	NP-9647-A	AM-42	39248.4	0	41214.8	0	4,719.36	0.00	2,59,565	0	2,59,565
400 /220 kV BgTPP ICT-2	NP-5318-A	AM-28	82816.3	98789.3	82985.7	98789.3	271.04	0.00	14,907	0	14,907
220 kV AGBPP – MARIANI	NP-6888-A	AS-03	4733.5	96333.6	3385	96333.6	-2,157.60	0.00	-1,18,668	0	-1,18,668
132 kV NORTH LAKHIMPUR-NIRJULI	NE-0119-A	AM-70	100	91883.9	100	91883.9	0.00	0.00	0	0	0
132 kV HATSINGIMARI END OF AMPATI-1	NE-0100-A	AM-73	99447	99944.6	99282.4	99944.6	-118.51	0.00	-6,518	0	-6,518
132 kV HATSINGIMARI END OF AMPATI-2	NE-0096-A	AM-74	99461.9	99943	99300.3	99943	-116.35	0.00	-6,399	0	-6,399
TOTAL											1,11,508

132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96543.1	99118	96543.1	99118	0.00	0.00	0	0	0
132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	519.8	99930.3	519.8	99930.3	0.00	0.00	0	0	0
JIRIBAM-TRF	NE-0027-A	MN-04	99911.2	1.9	99911.2	1.9	0.00	0.00	0	0	0
132 kV JIRIBAM (PG) – JIRIBAM (MN)	NP-9902-A	MN-19	3627.1	30.1	3628.3	30.1	0.29	0.00	16	0	16
IMPHAL (PG) ICT I	NP-9520-A	MN-13	22484.3	384.9	22484.3	384.9	0.00	0.00	0	0	0
IMPHAL (PG) ICT II	NP-9522-A	MN-14	19970	384.3	19970	384.3	0.00	0.00	0	0	0
132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9946-A	MN-17	27852.6	3.1	27848.1	3.1	-3.24	0.00	-178	0	-178
132kV Imp(S)-Imp(PG) Ckt III	NP-9706-A	MN-01	5449.2	99966.9	5449.2	99966.9	0.00	0.00	0	0	0
400 KV IMPHAL – THOUBAL-1	NP-9668-A	MN-28	0	0	0	0	0.00	0.00	0	0	0
400 KV IMPHAL – THOUBAL-2	NP-9603-A	MN-29	97258.8	95659.2	97258.8	95627.3	0.00	-232.00	0	12,760	12,760
132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	89681.3	2.3	89543	2.3	-33.19	0.00	-1,826	0	-1,826
132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	6968.4	99977.8	7076	99977.8	25.82	0.00	1,420	0	1,420
132 kV KARONG-KOHIMA	NP-9667-A	MN-03	91770	96249.2	91770	96249.2	0.00	0.00	0	0	0
132 kV LOKTAK – RENGPAANG	NP-9512-A	MN-11	3566.2	116.8	3579.6	116.8	6.43	0.00	354	0	354
132 kV LOKTAK – NINGTHOUKONG	NP-9651-A	MN-02	55913.5	12.6	55943.5	12.6	21.60	0.00	1,188	0	1,188
TOTAL											13,734

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	98431.6	80696.4	98451	80696.4	13.97	0.00	768	0	768
	132kV KHLRT S-PG II	NP-6880-A	ME-09	96369.5	21930.3	96368.1	21930.3	-1.01	0.00	55	0	55
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	84194.3	85965.2	84175.1	85965.2	-30.72	0.00	1,690	0	1,690
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	77155.9	96032.5	77133	96032.5	-36.64	0.00	2,015	0	2,015
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	38561.7	99953.5	38338.4	99953.5	-812.00	0.00	-44,660	0	-44,660
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	49006.4	99864	49236.6	99864	837.09	0.00	46,040	0	46,040
	132 kV KAHALIPARA – UMTRU -1	NP-8474-A	ME-03	99219.9	99984.8	99219.9	99984.8	0.00	0.00	0	0	0
	132 kV KAHALIPARA – UMTRU -2	NE-0016-A	ME-04	98679	99999.4	98554.2	99999.4	-59.90	0.00	-3,295	0	-3,295
	132 kV SARUSAJAI – UMTRU -1	NP-8473-A	ME-07	87825	99819.2	87705.9	99819.2	-57.17	0.00	-3,144	0	-3,144
	132 kV SARUSAJAI – UMTRU -2	NP-8491-A	ME-05	88707.4	99793.6	88588.7	99793.6	-56.98	0.00	-3,134	0	-3,134
	132 KV PANCHGRAM - LUMSHNONG	NP-8384-A	ME-01	97662.9	60751.8	97662.3	60751.6	-0.29	-0.10	-16	5	-11
	132 kV AGIA – MENDIPATHAR	NP-9945-A	ME-17	96460.1	91283.6	96719.2	91283.6	124.37	0.00	6,840	0	6,840
	132 kV AGIA – MENDIPATHAR	NP-9071-A	ME-16	1185.2	21597.6	1775	21597.6	283.10	0.00	15,571	0	15,571
	132 kV AMPATI to HATSINGIMARI 1	NE-0074-A	ME-18	99963.4	9.8	23.7	9.8	43.42	0.00	2,388	0	2,388
	132 kV AMPATI to HATSINGIMARI 2	NE-0157-A	ME-18	99957.1	3.2	17.5	3.2	43.49	0.00	2,392	0	2,392
TOTAL												23,516

132kV LAUNGMAUL-AIZWAL PG	NP-9495-A	MZ-02	1190.7	11260	1190.7	11287.9	0.00	26.78	0	1,473	1,473
132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	57898	55146.3	57870.7	55153.7	-9.83	2.66	541	147	687
132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	1326	99594.3	1326	99594.3	0.00	0.00	0	0	0
132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	99161.8	88.6	99153.3	88.6	-6.12	0.00	-337	0	-337
132kV Shimui-Melriat(PG)-I	NP-9493-A	MZ-17	98798.7	98729.9	98797	98727.1	-0.61	-1.01	-34	55	22
132kV Shimui-Melriat(PG)-II	NP-9496-A	MZ-18	98830.7	98959.4	98829.9	98957.7	-0.29	-0.61	-16	34	18
TOTAL											1,863

132kV DIMAPUR S-PG I	NP-9602-A	NG-01	18444.1	10613.7	18445.6	10613.8	1.44	0.10	-79	5	-74
132kV DIMAPUR S-PG II	NP-9649-A	NG-17	77013.2	6457.8	77018	6457.8	3.46	0.00	-190	0	-190
132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	6005.2	98124.6	6007.1	98124.6	0.68	0.00	-38	0	-38


 माया कुमारी / Maya Kumari
 उप-निरीक्षक / Deputy Director
 उ.पु.के.वि.स. / N.E.R.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Govt. of India
 शिलांग / Shillong

NAGALAND	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44606.3	4975.2	44606.3	4952.1	0.00	-8.32	0	457	457
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	44017.3	5060.1	44017.3	5035.3	0.00	-8.93	0	491	491
	132 kV KARONG-KOHIMA	NP-9947-A	NG-02	1888	99976.2	1888.4	99976.2	0.12	0.00	7	0	7
	132 kV DHEP - SANIS	NE-0103-A	NG-22	99869.9	3.1	99869.7	3	-0.10	-0.05	-5	3	-3
TOTAL												649
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97384	84692.4	97384	84692.4	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7408.8	99967.8	7408.8	99967.8	0.00	0.00	0	0	0
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14903.5	23.7	14903.5	23.7	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10968.3	99987	10970.9	99987	2.50	0.00	-137	0	-137
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	5343.4	99998.7	5344	99998.7	0.58	0.00	-32	0	-32
	132 kV D'CHERA - DHARMANAGAR	NP-6892-B	TR-06	76269	89349.2	76269	87985.8	0.00	-654.43	0	35,994	35,994
	132 kV AGARTALA - AGTPP - 1	NP-6850-A	TR-01	6603.1	6221.6	6603.1	6221.6	0.00	0.00	0	0	0
	132 kV AGARTALA - AGTPP - 2	NP-6851-A	TR-02	47102.7	93751.2	47102.7	93751.2	0.00	0.00	0	0	0
	132 kV PK BARI- RC NAGAR-1	NP-9933-A	TR-21	1575.9	99726.6	1575.9	99726.6	0.00	0.00	0	0	0
	132 kV PK BARI- RC NAGAR-2	NP-9932-A	TR-22	1521.3	99995.8	1521.3	99995.8	0.00	0.00	0	0	0
	132 kV PALATANA - SM NAGAR	NP-8471-A	TR-13	69039.7	72305.1	69039.7	72305.1	0.00	0.00	0	0	0
TOTAL												35,825
PARE	132 kV PARE – NIRJULI	NP-9409-A	PA-03	58523.9	2966.8	58523.9	2966.8	0.00	0.00	0	0	0
	32 kV PARE – CHIMPU CKT I	NP-9411-A	PA-05	2979.8	98665.5	2979.8	98665.5	0.00	0.00	0	0	0
	132 kV PARE – CHIMPU CKT II	NP-9538-A	PA-07	68970.1	98579.9	68970.1	98579.9	0.00	0.00	0	0	0
	132 kV PARE – NORTH LAKHIMPUR	NP-9607-A	PA-01	58395.5	3599.3	58395.5	3599.3	0.00	0.00	0	0	0
TOTAL												0
DOYANG	132kV DHEP - DIMAPUR(PG) - 1	NP-9066-A	DY-01	81952.7	77263.6	81952.8	77263.6	0.07	0.00	4	0	4
	132kV DHEP - DIMAPUR(PG) - 2	NP-9050-A	DY-02	70665.4	88286.1	70665.5	88273.9	0.07	-8.78	4	483	487
	132 kV DHEP - SANIS	NP-8799-A	DY-03	19311.2	12426.8	19311.3	12426.8	0.07	0.00	4	0	4
	132 kV DHEP - MOKOKCHUNG	NP-9053-A	DY-04	57782.7	10888.2	57782.7	10900.5	0.00	8.86	0	-487	-487
TOTAL												8
KHANDONG	132kV KHANDONG - KHLRT - 1	NE-0114-A	KK-31	379	6.6	829.6	6.6	162.22	0.00	8,922	0	8,922
	132kV KHANDONG - KHLRT - 2	NE-0066-A	KK-30	85761.9	230.6	85661.1	230.6	-36.29	0.00	-1,996	0	-1,996
	132 kV UMRANGSHOO - KHANDONG	NE-0138-A	KK-32	86039	99969.8	85897	99969.8	-102.24	0.00	-5,623	0	-5,623
TOTAL												1,303
KOPILI-2	KOPILI GT OF STG-2	NE-0140-A	KK-42	9195	99914	8791.1	99914	-96.94	0.00	-5,331	0	-5,331
	KOPILI STG-2 33 kV STN TRF	NE-0137-A	KK-40	5933.9	9.2	6147.1	9.2	1.60	0.00	88	0	88
TOTAL												-5,244
AGBPP	220 kV AGBPP – MARIANI PG	NP-9582-A	KT-02	21021.2	0.7	23162.8	0.7	3,426.56	0.00	1,88,461	0	1,88,461
	KTG END OF 220kV DEOMALI FDR	NP-9566-A	KT-14	25971.1	99999	25475.5	99999	-396.48	0.00	-21,806	0	-21,806
	220 kV AGBPP – MARIANI	NP-9625-A	KT-01	11966.2	99930.9	12171.1	99930.9	327.84	0.00	18,031	0	18,031
	220 kV AGBPP – TINSUKIA - 1	NP-9650-A	KT-15	91110.9	1.1	90962.6	1.1	-237.28	0.00	-13,050	0	-13,050
	220 kV AGBPP – TINSUKIA - 2	NP-9443-A	KT-16	84261	1.4	84148.8	1.4	-179.52	0.00	-9,874	0	-9,874
TOTAL												1,61,762
LOKTAK	132 kV LOKTAK - JIRIBAM	NP-9064-A	LO-02	48210.8	97857.6	48209.5	97857.6	-0.62	0.00	-34	0	-34
	132 kV LOKTAK - IMPHAL (PG)	NP-9044-A	LO-03	33133.2	97680.7	33133.2	97680.7	0.00	0.00	0	0	0
	132 kV LOKTAK – RENGPAANG	NP-9065-A	LO-01	53293.6	98095.8	53293.5	98095.8	-0.05	0.00	-3	0	-3
	132 kV LOKTAK – NINGTHOUKONG	NP-9045-A	LO-04	6507.7	6604	6507.7	6604	0.00	0.00	0	0	0
TOTAL												-37
AGTCCPP	132 kV AGTPP - KUMARGHAT	NP-9080-A	AG-03	54500.5	96849.6	54500.5	96849.6	0.00	0.00	0	0	0
	132 kV AGARTALA - AGTPP - 1	NP-9081-A	AG-01	23186	4849.5	23186	4849.5	0.00	0.00	0	0	0
	132 kV AGARTALA - AGTPP - 2	NP-9093-A	AG-02	23331.6	6779.2	23331.6	6779.2	0.00	0.00	0	0	0
	132 kV PK BARI- RC NAGAR-1	NP-9940-A	AG-16	96242.1	99998.3	96242.1	99998.3	0.00	0.00	0	0	0
	132 kV PK BARI- RC NAGAR-12	NP-9941-A	AG-17	95430.1	99999.5	95430.1	99999.5	0.00	0.00	0	0	0
TOTAL												0
TOTAL												0
	400 kV RANGANADI - BNC 1	NP-6033-A	RN-02	71276.2	99944.9	71276.2	99944.9	0.00	0.00	0	0	0


 भाया कुमारी / Maya Kumari
 उप-निरीक्षक / Deputy Director
 उ.पु.वे.वि.स. / N.E.R.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Govt. of India
 Dispur / Shillong

RANGANADI	400 kV RANGANADI - BNC 2	NP-5817-A	RN-03	75354	99986.4	75125.2	99986.4	-832.00	0.00	-45,760	0	-45,760
	132 kV RANGANADI - LEKHI	NP-5792-A	RN-01	16278.9	99802.9	16278.9	99802.9	0.00	0.00	0	0	0
	132 kV ZIRO - RANGANADI	NP-5278-A	RN-11	41432.6	97839.5	41432.6	97839.5	0.00	0.00	0	0	0
	132 kV RANGANADI END OF 132 kV PARE-2	NP-9439-A	RN-18	17191	29.9	17191	29.9	0.00	0.00	0	0	0
	132 kV RANGANADI END OF 132 kV CHIMPU	NP-9441-A	RN-20	4658.8	99998.7	4658.8	99998.7	0.00	0.00	0	0	0
TOTAL												-45,760

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
PALATANA	400 kV PALATANA - SILCHAR -1	NP-9558-A	PL-16	5884.2	99998.2	5691.6	99998.2	-700.36	0.00	-38,520	0	-38,520
	400 kV PALATANA - SILCHAR -2	NP-9560-A	PL-17	34466.6	99977.5	34229.8	99977.4	-861.09	-0.36	-47,360	20	-47,340
	400 kV PALATANA – SM NGR ST	NE-0013-A	PL-22	53857.7	2.3	53716.6	2.3	-513.09	0.00	-28,220	0	-28,220
	132 kV PALATANA - SM NAGAR	NP-9561-A	PL-19	21016.8	27.6	21017	27.6	0.38	0.00	21	0	21
	132 kV PALATANA - UDAIPUR	NP-9559-A	PL-18	6467	99977.7	6467	99977.7	0.00	0.00	0	0	0
TOTAL												-1,14,059
BGTPP	400 kV BgTPP - BONGAIGAON -1	NP-9683-A	NT-01	80696.1	2.2	80696.1	2.2	0.00	0.00	0	0	0
	400 kV BgTPP - BONGAIGAON -2	NP-9682-A	NT-02	71765	6	71765	6	0.00	0.00	0	0	0
	400 /220 kV BgTPP ICT-1	NP-9644-A	NT-22	48824.5	0.1	49962.5	0.1	3,641.60	0.00	-2,00,288	0	-2,00,288
	400 /220 kV BgTPP ICT-2	NP-9681-A	NT-14	52429.2	1.5	52561.5	1.5	423.36	0.00	-23,285	0	-23,285
TOTAL												-2,23,573
KAMENG	400 kV KAMENG- BALIPARA (PG) - 1	NP-9588-A	KA-01	96605.9	99994.8	96605.9	99994.8	0.00	0.00	0	0	0
	400 kV KAMENG- BALIPARA (PG) -2	NP-9590-A	KA-03	93529.8	99972.3	93529.8	99972.3	0.00	0.00	0	0	0
TOTAL												0
KOPILI	220 kV KOPILI END OF MISA-1 FDR	NE-0076-A	KK-05	99764.1	99997.6	99795.9	99997.6	50.88	0.00	2,798	0	2,798
	220 kV KOPILI END OF MISA-2 FDR	NE-0078-A	KK-06	99653.5	0.5	99686.5	0.5	52.80	0.00	2,904	0	2,904
	220 kV KOPILI END OF MISA-3 FDR	NE-0080-A	KK-07	99665.2	0.6	99693	0.6	44.48	0.00	2,446	0	2,446
TOTAL												8,149
HVDC_BNC	132 kV CHIMPU – BNC	NP-9961-A	AM-55	99642.2	416.8	99642.2	416.8	0.00	0.00	0	0	0
	132 kV PAVOI -BNC - 1	NP-9677-A	AM-10	93215.5	5383.4	93215.5	5383.4	0.00	0.00	0	0	0
	132 kV PAVOI-BNC -2	NP-9678-A	AM-11	91846.2	3709.4	91846.2	3709.4	0.00	0.00	0	0	0
	132 kV GOHPUR - BNC	NP-9962-A	AM-56	99662.1	251	99662.1	251	0.00	0.00	0	0	0
	400 kV RANGANADI - BNC 1	NP-9086-A	AM-20	71856.3	99921.3	71856.3	99921.3	0.00	0.00	0	0	0
TOTAL												0

Note: 1) Rate of Reactive Energy Charge has been considered @ 5 paise/KVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.


 भाया कुमारी / Maya Kumari
 उप-निरीक्षक / Deputy Director
 उ.पु.के.वि.स. / N.E.R.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Govt. of India
 पुराना / Shillong