

SN		Name of Element	Shutdown Proposed for the month of February 2025																												Time	Reason	Category	Study Comments
			Feb-25																															
SHUTDOWNS PROPOSED BY PGCIL			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28				
1	132kV LOKTAK(NHPC)-IMPHAL																																	
2	132kV KHANDONG(NEEPCO)-KHLIEHRIAT-2																																	
3	132kV BADARPUR-KHLIEHRIAT-1																																	
4	132kV MELRIAT-ZEMABAWK(MIZORAM)																																	
5	132kV SILCHAR-HAILAKANDI(ASSAM)-2																																	
6	132kV AIZWAL-KUMARGHAT																																	
7	132 KV S/C R C NAGAR-KUMARGHAT LINE																																	
8	132kV ROING-TEZU LINE																																	
9	132kV DOYANG(NEEPCO)-DIMAPUR-1																																	
10	132kV DOYANG(NEEPCO)-DIMAPUR-2																																	
11	132kV RC NAGR(NEEPCO)-AGARTLA(TRIPURA)-1																																	
12	132kV RC NAGR(NEEPCO)-AGARTLA(TRIPURA)-2																																	
13	A/R of 132kV JIRIBAM-TIPAIMUKH(MANIPUR)																																	
14	A/R of 132kV AGARTALA GAS (PG) - KUMARGHAT (PG)																																	
15	A/R of 132 KV IMPHAL - DIMAPUR-1																																	
			Jun-25																															
220kV Transmission lines			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28				
19	220kV BALIPARA-SONABIL(ASSAM)-1																																	
20	220kV BALIPARA-SONABIL(ASSAM)-2																																	
21	220kV MARIANI-MARIANI(AEGCL)																																	
22	220kV MISA-DIMAPUR-1																																	
23	220kV MARIANI-MOKOKCHUNG-1																																	
			Jun-25																															
400kV Transmission lines			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28				
			Category																															

[illegible]

[illegible]

Sl. No.	Activity	Activity Location	Activity Duration	Activity Description	Activity Status	Activity Remarks
19	220KV SAMAGURI-MARIANI		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed. At present, the Upper Assam power system is connected with 220 kV Samaguri-Mariani(AS) line, 220 kV Mian(AS) - Mian (PG) line, 220 kV AGBPP-Mariani(PG) line and 132 kV Mian - Golaghat - Sarupathar - Bokajan - Dimapur link. Under N-1 condition, Gate flow should be monitored and shall be maintained below 260 MW(during solar period) and 245 MW (during non-solar period) for safe and reliable grid operation. RELIABILITY OF THE SYSTEM IS REDUCED.
20	220KV SAMAGURI-JAWAHARNAGAR		9:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Samaguri-Sarusajai link, 220kV Jawaharnagar-Samaguri line & 220kV Azara-Sarusajai-J Nagur link. <b>SD to be availed after return of Mirza 220kV Bus-I &amp; II.</b>
21	220KV SAMAGURI-JAWAHARNAGAR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Samaguri-Sarusajai link, 220kV Jawaharnagar-Samaguri line & 220kV Azara-Sarusajai-J Nagur link.
22	220KV SAMAGURI-JAWAHARNAGAR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Samaguri-Sarusajai link, 220kV Jawaharnagar-Samaguri line & 220kV Azara-Sarusajai-J Nagur link.
23	220KV SAMAGURI-JAWAHARNAGAR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Samaguri-Sarusajai link, 220kV Jawaharnagar-Samaguri line & 220kV Azara-Sarusajai-J Nagur link.
24	220KV SAMAGURI-SONAPUR		10:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Sarusajai-Sonapur line, 220kV Samaguri-Jawaharnagar-Sarusajai-Azara link. <b>SD to be availed after return of Mirza 220kV Bus-I &amp; II.</b>
25	220KV SAMAGURI-SONAPUR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Sarusajai-Sonapur line, 220kV Samaguri-Jawaharnagar-Sarusajai-Azara link.
26	220KV SAMAGURI-SONAPUR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Sarusajai-Sonapur line, 220kV Samaguri-Jawaharnagar-Sarusajai-Azara link.
27	220KV SAMAGURI-SONAPUR		8:00-16:00	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Sarusajai-Sonapur line, 220kV Samaguri-Jawaharnagar-Sarusajai-Azara link.
28	220KV SARUSAJAI-SONAPUR		8:30-16:30	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220kV Samaguri-Sonapur line, 220kV Samaguri-Jawaharnagar-Sarusajai-Azara link.
29	220KV MIRZA-AGIA		8:30-16:30	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	S/D may be availed. 220 kV Agia - Boko - Mirza link to be kept in service. Also, 400kV Bongpangong - Azara, 400/220kV ICTs at Azara S/s, 220kV Balpara - Sonabil D/C.
30	220KV MIRZA-AGIA		8:30-16:30	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	S/D may be availed. 220 kV Agia - Boko - Mirza link to be kept in service. Also, 400kV Bongpangong - Azara, 400/220kV ICTs at Azara S/s, 220kV Balpara - Sonabil D/C.
31	220KV MIRZA-BOKO		8:30-16:30	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	S/D may be availed. 220 kV Agia - Boko line and 220 kV Agia - Mirza line to be kept in service.
32	220KV MIRZA-BOKO		8:30-16:30	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	Normal Maintenance related shutdown.	S/D may be availed. 220 kV Agia - Boko line and 220 kV Agia - Mirza line to be kept in service.
33	220KV MAIN BUS 1 AND 2 AT MIRZA		5:00-9:00	ALIGNMENT OF BUS ISOLATORS	Normal Maintenance related shutdown.	The SD may be availed. The combined loading of 220 kV Samaguri-Sonapur & 220 kV Samaguri-J Nagur line shall be maintained below 190 MW during the SD period. Availability of Langi generation will improve the reliability of capital area of Assam system.
34	220KV MAIN BUS 1 AND 2 AT MIRZA		5:00-9:00	ALIGNMENT OF BUS ISOLATORS	Normal Maintenance related shutdown.	The SD may be availed. The combined loading of 220 kV Samaguri-Sonapur & 220 kV Samaguri-J Nagur line shall be maintained below 190 MW during the SD period. Availability of Langi generation will improve the reliability of capital area of Assam system.
35	220KV MAIN BUS 1 AND 2 AT MIRZA		5:00-9:00	ALIGNMENT OF BUS ISOLATORS	Normal Maintenance related shutdown.	The SD may be availed. The combined loading of 220 kV Samaguri-Sonapur & 220 kV Samaguri-J Nagur line shall be maintained below 190 MW during the SD period. Availability of Langi generation will improve the reliability of capital area of Assam system.
36	220KV MAIN BUS 1 AND 2 AT MIRZA		5:00-9:00	ALIGNMENT OF BUS ISOLATORS	Normal Maintenance related shutdown.	The SD may be availed. The combined loading of 220 kV Samaguri-Sonapur & 220 kV Samaguri-J Nagur line shall be maintained below 190 MW during the SD period. Availability of Langi generation will improve the reliability of capital area of Assam system.
37	220KV MAIN BUS 1 AND 2 AT MIRZA		5:00-9:00	ALIGNMENT OF BUS ISOLATORS	Normal Maintenance related shutdown.	The SD may be availed. The combined loading of 220 kV Samaguri-Sonapur & 220 kV Samaguri-J Nagur line shall be maintained below 190 MW during the SD period. Availability of Langi generation will improve the reliability of capital area of Assam system.
38	315MVA, AT-1 AT MIRZA		8:00-16:00	ROUTINE TESTING OF EQUIPMENT	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400/220 kV ICT-1, 220 kV Samaguri-Sonapur/J Nagur-Sarusajai-Azara link, 220 kV Balpara-Sonabil D/C, 220 kV Msa-Samaguri D/C.
39	400KV MIRZA-SILCHAR		8:00-16:00	ROUTINE TESTING OF EQUIPMENT	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400kV Bongpangong-Azara line & 220 kV Salakati-BTPS-Agia-Azara link. NER TTC/ATC will be revised.
40	400KV MIRZA-BONGAIGAON		8:00-16:00	ROUTINE TESTING OF EQUIPMENT	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400kV Bongpangong-Azara line & 220 kV Salakati-BTPS-Agia-Azara link. NER TTC/ATC will be revised.
41	220KV MIRZA-SARUSAJAI CKT 1		8:00-16:00	ROUTINE TESTING OF EQUIPMENT	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Mirza-Sarusajai II & Azara-Sarusajai-Sonapur/J Nagur-Samaguri link.
42	132KV PAILOPOOL-JRIBUM		9:00-16:00	CORRIDOR CLEANING & LINE MAINTENANCE WORKS	Normal Maintenance related shutdown.	SD may be availed subject to availability of 132 kV Srikonapailapool line.
43	132KV BUS AT HAFLONG		8:00-16:00	ERRECTION OF TOWER BEAM FOR TRACTION BAY	Normal Maintenance related shutdown.	The SD may be availed. No power supply in Haflong area of Assam during SD period.
44	220 kV Main bus-II at SAMAGURI		9:00-15:00	REPLACEMENT OF DAMAGED MAIN CONDUCTOR	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Main Bus I. All elements must be shifted to 220 kV Main Bus II.
45	220 kV Main bus-II at SAMAGURI		9:00-15:00	REPLACEMENT OF DAMAGED MAIN CONDUCTOR	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Main Bus I. All elements must be shifted to 220 kV Main Bus II.
46	220 kV Main bus-II at SAMAGURI		9:00-15:00	REPLACEMENT OF DAMAGED MAIN CONDUCTOR	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Main Bus I. All elements must be shifted to 220 kV Main Bus II.
47	220 kV Main bus-II at SAMAGURI		9:00-15:00	REPLACEMENT OF DAMAGED MAIN CONDUCTOR	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Main Bus I. All elements must be shifted to 220 kV Main Bus II.
48	220 kV Main bus-II at SAMAGURI		9:00-15:00	REPLACEMENT OF DAMAGED MAIN CONDUCTOR	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220 kV Main Bus I. All elements must be shifted to 220

[illegible]

SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category	
SHUTDOWNS PROPOSED BY NEEPCO PHPS(Pare)																																	
1	unit#1																													09:00 to 23:59 hrs,continuous	Annual Planned Maintenance ,	Normal Maintenance related shutdown.	The SD may be availed.
2	Plant shutdown																													00:00 hrs of 20/02/25 to 23:59 hrs of 01/03/25,continuous	To carry out the trunnion seal replacement on Unit#2.	Normal Maintenance related shutdown.	The SD may be availed.
AgGBPS(R.C.Nagar)																																	
1	GTG#2																													00:00 to 23:00 hrs, continuous	Installation of New GCP	Normal Maintenance related shutdown.	The SD may be availed.
2	GTG#4																													00:00 hrs of 24/02/25 to 23:00 hrs of 08/03/25, continuous	Installation of New GCP	Normal Maintenance related shutdown.	The SD may be availed.
PLHPS(Panvor Lower)																																	
1	Complete plant shutdown																													00:00 hrs of 07.01.25 to 23:00 hrs of 12/03/25, continuous	Replacement of MIV seals and all other associated works of all 3 generating units, PLHPS	Normal Maintenance related shutdown.	The SD may be availed.
Kopili 4x50 MW PS																																	
1	Unit#4																													09:00 to 23:59 hrs,continuous	Annual Planned Maintenance for 15 days.	Normal Maintenance related shutdown.	The SD may be availed.
DoyangHPS																																	
1	Unit#1																													09:00 to 23:59 hrs,continuous	Annual Planned Maintenance	Normal Maintenance related shutdown.	The SD may be availed.
KaHPS																																	
1	Unit#1																													09:00 to 23:59 hrs,continuous	Annual Planned Maintenance	Normal Maintenance related shutdown.	The SD may be availed.
Khandong																																	
1	Khandong Switchyard																													08:00 hrs to 17:00 hrs, continuous	Re-conductoring of Buses and erection of bay equipments	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Badarpur-Khilehriat line & 132 kV Badarpur-Panchgram-Lunahong-Khilehriat line 132 KV Agia -Nangalbhra and 132 kV Agia Mendpathar line & 220 kV Mawngap-Killing D/C.
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category	
SHUTDOWNS PROPOSED BY INDIGRID																																	
1	400/132kV,315MVA ICT-1 at SM Nagar Substation (ISTS)																													09:00-17:00 hrs	AMP of transformer and bay equipment	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 0400/132kV,315MVA ICT-2 at SM Nagar Substation (ISTS)
2	400/132kV,315MVA ICT-2 at SM Nagar Substation (ISTS)																													09:00-17:00 hrs	AMP of transformer and bay equipment	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 0400/132kV,315MVA ICT-1 at SM Nagar Substation (ISTS)
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category	
SHUTDOWNS PROPOSED BY KMTL																																	
1	400 KV Imphal to New Kohima Ckt-I																													07:00-14:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400 KV Imphal - New Kohima Ckt-II
2	400 KV Imphal to New Kohima Ckt-II																													07:00-14:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400 KV Imphal - New Kohima Ckt-I
3	402 KV New Kohima-Mariani Ckt-I																													07:00-14:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400 KV Mariani-New Kohima Ckt-II.
4	403 KV New Kohima-Mariani Ckt-II																													07:00-14:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 400 KV Mariani-New Kohima Ckt-I.
5	3X167 MVA Auto Transformer Bank-I																													07:00-19:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed.
6	125 MVAR Reactor-I																													07:00-18:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of Bus Reactor II. 9 kV Voltage change is expected omm switching of 125 MVAR reactors.
7	125 MVAR Reactor-II																													07:00-18:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of Bus Reactor I. 9 kV Voltage change is expected omm switching of 125 MVAR reactors.
8	3X167 MVA Auto Transformer Bank-II																													07:00-19:00 hrs	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed.
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category	
SHUTDOWNS PROPOSED BY TRIPURA																																	
1	132 KV Monarchuk - Udaipur Line																													(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amny be availed subject to availability of 132 kV Monarchuk-Rokhia-Udaipur line. Generation of Monarchuk to be kept 70 MW during the SD period. SPS at Monarchuk to be kept in OFF condition.
2	132 KV Rokhia - Monarchuk Line																													(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amny be availed subject to availability of 132 kV Monarchuk-Udaipur line. Generation of Monarchuk to be kept 70 MW during the SD period. SPS at Monarchuk to be kept in OFF condition.
3	132 KV Rokhia - Monarchuk Line																													(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amny be availed subject to availability of 132 kV Monarchuk-Udaipur line. Generation of Monarchuk to be kept 70 MW during the SD period. SPS at Monarchuk to be kept in OFF condition.
4	132 KV Rokhia - Monarchuk - Udaipur Line																</																

17	132 KV Monarchuk - Udaipur Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Monarchuk-Rokhia-Udaipur line. Generation of Monarchuk to be kept 70 MW during the SD period. SPS at Monarchuk to be kept in OFF condition.			
18	132 KV Agartala SS, 79 Tilla ( Section- 2) with 132 KV Agartala - Mohampur Line and 132 KV Agartala - R.C.Nagar Line I																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV SM Nagar - SM Nagar , 132 kV SM Budjung Nagar, 400/220 kV ICT's at Palatana, 132 kV RC Nagar-Agtala line II.			
19	132 KV Gamaitilla S/S (132 KV Bus)																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	SD may be availed.			
20	132 KV Dharmanagar - Durflavcherra Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	SD may be availed subject to availability of 132kV PK Bari - Dharmnagar and 132kV Dulavcherra - Halakandi.			
21	132 KV Surjamaninagar - Bodhjungnagar Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 KV Surjamaninagar - SM Nagar(ISTS)Line.			
22	132 KV Jirania S/S (132 KV Bus)																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	SD may be availed.			
23	132 KV Bus of Surjamaninagar S/Stn. (Bus-1)																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	SD may be availed subject to no outage of elements.			
24	132 KV P.K. Bari (TSECL) - P.K. Bari (ISTS) Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	SD may be availed.			
25	132 KV Surjamaninagar - Agartala Line I																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 KV Surjamaninagar - Agartala Line II.			
26	132 KV Surjamaninagar - Agartala Line II																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 KV Surjamaninagar - Agartala Line I.			
27	132 KV Gamaitilla - Ambassa Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of Gamailla - Barrura Line.			
28	132 KV Rokhia - Monarchuk Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 kV Monarchuk-Udaipur line. Generation of Monarchuk to be kept 70 MW during the SD period. SPS at Monarchuk to be kept in OFF condition.			
29	132 KV Surjamaninagar - Agartala Line II																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 KV Surjamaninagar - Agartala Line I.			
30	132 KV Bodhjungnagar - Jirania Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 KV Jirania-Barrura Line.			
31	132 KV Udaipur - Palatana Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed subject to availability of 132 kV Udaipur-Monarchuk line.			
32	132 KV P.K Bari - Mission Tilla Line																											(9 am to 4 pm)	Maintenance Work	Normal Maintenance related shutdown.	The SD amy be availed.			
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category		
	SHUTDOWNS PROPOSED BY NETC																																	
1	400 kV Silchar-Azara TL (Ckt- I)																													11.00 hrs to 15.00 hrs	For rectification of Transmission Line Surge Arrestor (TL&A).		The SD may be availed subject to availabity of 400kV Bongaigaon-Azara line &220 kV Salakati-BTPS-Agin-Azara link.	
2	400 kV Silchar-Byrnihat TL (Ckt- II)																													11.00 hrs to 15.00 hrs	For rectification of Transmission Line Surge Arrestor (TL&A).		The SD may be availed subject to availability of 400kV Bongaigaon-Killing line.	
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category		
	SHUTDOWNS PROPOSED BY NTPC																																	
1	NTPC Unit #3																													00.00 hrs to 23.59 hrs	Overhauling works		SD may be availed, TTC/ATC needs to be revised.	
SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	Time	Reason	Category		
	SHUTDOWNS PROPOSED BY NHPC																																	
1	Loktak Unit #1																													00.00 hrs to 23.59 hrs	Annual Maintenance		SD may be availed	
1	Loktak Unit #2																													00.00 hrs to 23.59 hrs	Annual Maintenance		SD may be availed	