



सत्यमेव जयते



भारत सरकार Government of India
विद्युत मंत्रालय Ministry of Power
उत्तर पूर्वी क्षेत्रीय विद्युत समिति
North Eastern Regional Power Committee
लपलांग शिलांग 793006
Lapalang, Shillong 793006

क्रमांक: एनईआरपीसी/कॉम/आरईए/2024-25/
No. NERPC/COM/ REA/2024-25/7768-7813

दिनांक/Dt: 28 February 2025

सेवा में / To,

संलग्न सूची के अनुसार

As per list enclosed.

विषय /Sub: वित्त वर्ष 2024-25 के लिए जनवरी 2025 तक एनईआर के कोयला/लिग्नाइट आईएसजीएस के लिए रैंपिंग प्रदर्शन का प्रमाणन/Certification of Ramping Performance for Coal/Lignite ISGS of NER upto January 2025 for FY 2024-25- reg.

सर/मैडम,

Sir/Madam,

जनवरी 2025 तक एनईआर के कोयला/लिग्नाइट आईएसजीएस के रैंपिंग प्रदर्शन का सारांश विवरण एनईआरएलडीसी द्वारा पत्र संख्या के माध्यम से प्रस्तुत किया गया है। एनईआरएलडीसी/आरए/2024-25/रैंप सर्टिफिकेट/7390 दिनांक 07-02-2025 संलग्न के रूप में प्रमाणित है। यह सीईआरसी (टैरिफ के नियम और शर्तें) विनियम, 2019 के विनियम 30 और एनएलडीसी द्वारा दिनांक 30.12.2020 के पत्र के माध्यम से जारी थर्मल आईएसजीएस की रैंपिंग क्षमता के आकलन के लिए संशोधित विस्तृत दिशानिर्देशों के अनुसार तैयार किया गया है।

घटक इस कथन के जारी होने की तारीख से 15 दिनों के भीतर अपने अवलोकन/टिप्पणियाँ, यदि कोई हों, भेज सकते हैं।

The statement of summary of ramping performance of coal/lignite ISGS of NER upto January 2025 as furnished by NERLDC vide letter no. NERLDC/RA/2024-25/Ramp Cert/7390 dated 07-02-2025 is certified as enclosed. This is prepared in accordance with the Regulation 30 of CERC (Terms and Conditions of Tariff) Regulations, 2019 and the Revised detailed guidelines for assessment of ramping capability of thermal ISGS issued by NLDC vide letter dated 30.12.2020.

Constituents may send their observation/ comments, if any on the same within 15days from the date of issue of this statement.

Enclosed - As above

संलग्न - उपरोक्तानुसार

भवदीय / Yours faithfully,

(माया कुमारी / Maya Kumari)

उपनिदेशक/Deputy Director

पत्तों की सूची /List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala – 799 001
2. Director (Distribution), MePDCL, Lumjingshai, S.R. Road, Shillong – 793 001
3. Engineer-in-Chief (P&E), P&E Dept., Govt. of Mizoram, Aizawl – 796 001
4. Chief General Manager (Comml), APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati – 781 001
5. Chief Engineer (Comm), Dept. of Power, Govt. of Arunachal Pradesh, Itanagar – 791 111
6. Managing Director, MSPDCL, Keishampat, Imphal – 795001
7. E-in-C, Dept. of Power, Govt. of Nagaland, Kohima – 797 001
8. Chief Engineer, Loktak HE Project, Vidyut Vihar, Komkeirap, Manipur – 795 124
9. Executive Director (Comml.), NEEPCO Ltd., Lower New Colony, Shillong – 793 003
10. Executive Director, NERTS, POWERGRID, Lapalang, Shillong – 793 006
11. Managing Director, OTPC, Core 4 & Central, 10th Floor, SCOPE Minar, Laxmi Nagar, Delhi – 110092
12. GM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneshwar-12
13. CE (G. M.), CEA, SewaBhawan, R.K.Puram, New Delhi – 110 066.
14. E. D., NERLDC, Lower Nongrah, Dongtieh, Lapalang, Shillong - 6.
15. C.G.M (SLDC) AEGCL, Kahelipara, Guwahati.
16. Gen. Manager (Comml.), NHPC Ltd., NHPC Office complex, Sector –33, Faridabad-121003.
17. C.G.M (Commercial) APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati - 781 001.
18. General Manager, Ranganadi HEP, NEEPCO, Yazlee, Ar. Pradesh
19. Project Manager, Doyang HEP, NEEPCO, Nagaland
20. Project Manager, AGBPP, NEEPCO Ltd., No. –III, Vill. Bokuloni, Dibrugarh, Assam.
21. Project Manager, AGTPP, NEEPCO Ltd., Ramchandranagar, Agartala, Tripura West- 799008.
22. Dy. G. M (Elect.), Kopili HEP, NEEPCO Ltd., Umrangso, N.C. Hills, Assam.
23. Supdt. Engr. (System Management) MeECL, Lumjingshai, Short Round Road, Shillong.
24. ED (Comml), MSPDCL, Secure Office Building Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
25. Executive Engineer, MSLDC, P & E Dept., Chaltlang, Aizawl- 796012.
26. Supdt. Engr. Dimapur Sub-station Deptt. of Power, Govt. of Nagaland, Dimapur.
27. Dy. G. M. (Commercial) NERTS, Lower Nongrah, Dongtieh, Lapalang, Shillong - 6.
28. Dy. General Manager (ER), POWERGRID, Boring Road, Alankar Place, Patna - 800 001
29. DGM (Comml), OTPC, 6th Floor, IFCI Tower, 61 Nehru Place, New Delhi – 110 019
30. AGM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneshwar-12
31. AGM (Comml.), NTPC, Bongaigaon Thermal Power Project, P.O Salakati, Kokrajhar-783369
32. Addl. General Manager, Comml & Sys.Opn., TSECL, Banamalipur, Agartala.-799001.
33. Ex. Engr., SLDC, Deptt. of Power, Itanagar, Ar. Pradesh – 791 111
34. CEO, NVVN Ltd., 7th Floor, Scope Complex, Lodhi Road, N.Delhi- 110 003
35. Power Trading Corpn. of India Ltd., 2nd Floor, NBCC Tower, 15-Bhikaji Cama Place, New Delhi – 66.
36. DGM (Power Trading), Adani Exports Ltd, 13 Palam Marg, Vasant Vihar, New Delhi- 110057.
37. ED, TPTCL, Block 'A', 34, Sant Tukaram Road, Carnac Bunder, Mumbai-400 009.
38. Member Secretary, NRPC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016.
39. Member Secretary, ERPC, 14, Golf Club Road, Kolkata- 700 033.
40. Member Secretary, WRPC, Plot No F-3, MIDC Area, Opp Seepz, Marol, Andheri (E), Mumbai-400 093.
41. Member Secretary, SRPC, 29, Race Course Road, Bangalore- 560009.
42. Lanco Electric Utility Limited, LANCO House, 141, Avenue, 8, Banjara Hills, Hyderabad-500 034
43. Reliance Energy Trading Ltd., Reliance Energy Centre, Santa Cruz (E), Mumbai-400 055
44. Vice President, Indian Energy Exchange Limited, 10th Floor, B Wing, Statesman House, Barakhamba Road, Connaught Place, New Delhi - 110 001.
45. LANCO Electric Utility Ltd, Plot No 229, Udyog Vihar, Phase-1, Gurgaon, Haryana – 122 016.
46. RPTCL, Agrawal House, 2, St. George's Gate Road, 6th Floor, Kolkata – 700 022.



(माया कुमारी / Maya Kumari)
उपनिदेशक/Deputy Director

NORTH EASTERN REGIONAL POWER COMMITTEE

Ramp Performance of Thermal Power Stations upto Month										January 2025
Number of months in computation (M):										10
Station	Total no. of Time Blocks (Tm)	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(Td)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E)	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in RoE(%)
BGTPP	24686	24591	1	1106	979	1031	1.04	0.89	0.93	0


 Maya Kumari
 Deputy Director
 N.E.R.P.C.
 Ministry of Power
 Govt. of India
 Shillong