

फॉर्मेट एस3: आरपीसी द्वारा आरआरएस प्रदाता के पैरामीटर/ Format AS3:
RRAS Provider Parameters by RPC

From: NERPC

To: Nodal Agency (NLDC, Delhi)

(Name of RRAS Provider Generating Station) **Agartala Gas Based Power Station**

(Name of Owner Organization) **North Eastern Electric Power Corporation Limited (NEEPCO)**

Validity of the Information

From: 16/07/2026

To: 15/08/2026

Date: 15/07/2026

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	4x21MW+2x23MW
b)	Total Installed Capacity (MW)	135
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	126
d)	Technical Minimum (MW)	69.28
e)	Type of Fuel	Natural Gas
f)	Region	N.E.R
g)	Bid area	A1
h)	Fixed Cost (Paise/kWh up to one decimal place)	219.9 (for June-2026)
i)	Variable Cost (Paise/kWh up to one decimal place)	564.9 (for May-2026) 760.9 (for June-2026) For Open cycle
j)	Ramp-Up Rate (MW/Min) for each unit	GTG 1-4: 2 MW/min STG1-2: 0.5 MW/min
k)	Ramp- Down Rate (MW/Min) for each unit	GTG 1-4: 2 MW/min STG1-2: 0.5 MW/min
l)	Start-up Time from Cold Start (in Min) & Warm Start of each unit	Cold Start GTG 1-4: 25 min STG1-2: 480-600 min
		Warm Start GTG 1-4: 25 min STG1-2: 240 min
m)	Any other information	Minimum Loading of Gas Turbines must be at least 18 MW each for taking individual HRSG into service

Signature of Authorized Signatory (With Stamp)

(लेनिन बी. आई.एस.सी.आई.एस.सी.)
 (Lenin B. IES/OPES)
 उपायुक्त निदेशक / Deputy Director
 उत्तर पूर्वी विद्युत निदेशक / N.E.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Government of India
 शिलांग / Shillong

लेनिन बी. आई.एस.सी.आई.एस.सी.)
 (Lenin B. IES/OPES)
 उपायुक्त निदेशक / Deputy Director
 उत्तर पूर्वी विद्युत निदेशक / N.E.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Government of India
 शिलांग / Shillong

फॉर्मेट एस3: आरपीसी द्वारा आरआरएस प्रदाता के पैरामीटर/ Format AS3:

RRAS Provider Parameters by RPC

From: NERPC

To: Nodal Agency (NLDC, Delhi)

(Name of RRAS Provider Generating Station) Assam Gas Based Power Station (Kathalguri)

(Name of Owner Organization) **North Eastern Electric Power Corporation Limited (NEEPCO)**

Validity of the Information

From: 16/07/2026

To: 15/08/2026

Date: 15/07/2026

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	6x33.5MW+3x30 MW
b)	Total Installed Capacity (MW)	291
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	110%
d)	Technical Minimum (MW)	152
e)	Type of Fuel	Natural Gas
f)	Region	N.E.R
g)	Bid area	A2
h)	Fixed Cost (Paise/kWh up to one decimal place)	196.0 (for June-2026)
i)	Variable Cost (Paise/kWh up to one decimal place)	554.7 (for June-2026)
j)	Ramp-Up Rate (MW/Min) for each unit	GTG 1-4: 2.27 MW/min GTG 5&6: 4.28 MW/min STG 1-3: 3.00 MW/min
k)	Ramp- Down Rate (MW/Min) for each unit	GTG 1-4: 2.27 MW/min GTG 5&6: 4.28 MW/min STG 1-3: 3.00 MW/min
l)	Start-up Time (in Min) from Cold Start & Warm Start of each unit	Cold Start GTG 1-4: 28 min GTG 5&6: 22 min STG 1-3: 180 min Warm Start GTG 1-4: 13 min GTG 5&6: 7 min STG 1-3: 30 min
m)	Any other information	NIL

Signature of Authorized Signatory (With Stamp)

Name: लेनिन बोडिंग्गद्ला / Lenin B. Bodingdla

Name: लीमन बाईराम / L. B. Bairam
Designation: उप निदेशक / Deputy Director

उ.पू.म.वि.सं. / N.E.R.F. S.O.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Government of India
शिलांग / Shillong

[illegible]

फॉर्मेट एस3: आरपीसी द्वारा आरआरएस प्रदाता के पैरामीटर/ Format AS3:
RRAS Provider Parameters by RPC

From: NERPC

To: Nodal Agency (NLDC, Delhi)

(Name of RRAS Provider Generating Station) **LOKTAK HEP**

(Name of Owner Organization) **NHPC Limited**

Validity of the Information

From: 16/07/2026

To: 15/08/2026

Date: 15/07/2026

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	3x35
b)	Total Installed Capacity (MW)	105
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	105 MW*
d)	Technical Minimum (MW)	N.A
e)	Type of Fuel	WATER
f)	Region	N.E.R
g)	Bid area	A1
h)	Fixed Cost (Paise/kWh up to one decimal place)	194.5
i)	Variable Cost (Paise/kWh up to one decimal place)	194.5
j)	Ramp-Up Rate (MW/Min) for each unit	25 MW per min
k)	Ramp- Down Rate (MW/Min) for each unit	25 MW per min
l)	Start-up Time from Cold Start (in Min) / Warm Start/Hot Start of each unit	15 min
m)	Any other information	

* As per water availability

Signature of Authorized Signatory (With Stamp)

Name: लेनिन बोडिगडला / Lenin Bodigadla

Designation: उप निदेशक / Deputy Director

उप निदेशक / Deputy Director-

उ.पू.वे.वि.स. / N.E.R.P.C.

विद्युत मंत्रालय / Ministry of Power

भारत सरकार / Government of India

शिलोंग / Shillong

(उप निदेशक) / Deputy Director
 उ.पू.वे.वि.स. / N.E.R.P.C.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Government of India
 शिलोंग / Shillong

फॉर्मेट एस3: आरपीसी द्वारा आरआरएस प्रदाता के पैरामीटर/ Format AS3:

RRAS Provider Parameters by RPC

From: NERPC

To: Nodal Agency (NLDC, Delhi)

(Name of RRAS Provider Generating Station) **Bongaigaon Thermal Power**

Plant (Name of Owner Organization) **NTPC Limited**

Validity of the Information

From: 16/07/2026

To: 15/08/2026

Date: 15/07/2026

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	3x250 MW
b)	Total Installed Capacity (MW)	750
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	238.90 MW per unit
d)	Technical Minimum (MW)	375.39
e)	Type of Fuel	Coal
f)	Region	N.E.R
g)	Bid area	A2
h)	Fixed Cost (Paise/kWh up to one decimal place)	240.6
i)	Variable Cost (Paise/kWh up to one decimal place)	390.6
j)	Ramp-Up Rate (MW/Min) for each unit	2.28 MW per min (ex Bus)
k)	Ramp- Down Rate (MW/Min) for each unit	2.28 MW per min (ex Bus)
l)	Start-up Time from Cold Start (in Min) / Warm Start/Hot Start of each unit	Cold Start: 600 min Warm Start: 360 min Hot Start: 360 Min
m)	Any other information	Warm start up time: 10 hr. (i.e. 600 min.) if RSD>12 hr. Cold start up time: 23 hr. (i.e. 1380 min.) if RSD>4 days as boiler will be kept under preservation

Signature of Authorized Signatory (With Stamp)

Name: लेनिन बोदिगद्ला / Lenin B. Bodigadla
Designation: उ.प्र.क्षेत्रीय निदेशक / Deputy Director
उ.प्र.क्षेत्रीय निदेशक / Deputy Director
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Government of India
शिलांग / Shillong

फॉर्मेट एस3: आरपीसी द्वारा आरआरएस प्रदाता के पैरामीटर/ Format AS3:

RRAS Provider Parameters by RPC

From: NERPC

To: Nodal Agency (NLDC, Delhi)

(Name of RRAS Provider Generating Station) **KOPILI HEP**

(Name of Owner Organization) **NEEPCO Limited**

Validity of the Information

From: 16/07/2026

To: 15/08/2026

Date: 15/07/2026

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	4x50
b)	Total Installed Capacity (MW)	200
c)	Maximum possible Ex-bus injection (MW) (including overload if any)	200 MW*
d)	Technical Minimum (MW)	N.A
e)	Type of Fuel	WATER
f)	Region	N.E.R
g)	Bid area	A1
h)	Fixed Cost (Paise/kWh up to one decimal place)	117.50#
i)	Variable Cost (Paise/kWh up to one decimal place)	117.50#
j)	Ramp-Up Rate (MW/Min) for each unit	34.28 MW per min
k)	Ramp- Down Rate (MW/Min) for each unit	40 MW per min
l)	Start-up Time from Cold Start (in Min) / Warm Start/Hot Start of each unit	NA
m)	Any other information	NA

* As per water availability

As per Provisional tariff (final Tariff order awaited from CERC)

Signature of Authorized Signatory (With Stamp)

Name: लेनिन बोडिगडला / Lenin Bodigadla
Lenin B. (NERPC)

Designation: उप निदेशक / Deputy Director
उ.प. नि.वि.स. / N.E.R.P.C.

विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Government of India
शिलांग / Shillong