



भारत सरकार Government of India

विद्युत मंत्रालय Ministry of Power

उत्तर पूर्वी क्षेत्रीय विद्युत समिति

North Eastern Regional Power Committee

एन ई आर पी सी कॉम्प्लेक्स, डोंग पारमाओ, लापालाङ, शिल्लोंग-७९३००६, मेघालय
NERPC Complex, Dong Parmaw, Lapalang, Shillong - 793006, Meghalaya



क्रमांक: एनईआरपीसी/कॉम/आरईए/2026-27/5288-5326

No. NERPC/COM/ REA/2026-27/5288-5326

दिनांक: 22 सितंबर 2026

Dt: September 22, 2026

सेवा में / To,

संलग्न सूची के अनुसार/As per list enclosed.

विषय /Sub: वित्त वर्ष 2026-27 के लिए अगस्त-2026 तक पूर्वोत्तर क्षेत्र के कोयला/लिग्नाइट आईएसजीएस के लिए रैंपिंग प्रदर्शन का प्रमाणन के संबंध में/ Certification of Ramping Performance for Coal/Lignite ISGS of NER upto August-2026 for FY 2026-27- reg.

सर/मैडम, /Sir/Madam.

NER द्वारा पत्र संख्या NERLDC/RA/2026-27 /RampCert/9793 दिनांक 18-09-2026 के माध्यम से प्रदान की गई NER के कोयला/लिग्नाइट ISGS की अगस्त-2026 तक की रैंपिंग प्रदर्शन सारांश की रिपोर्ट संलग्न प्रमाणित की जाती है। रैंपिंग प्रदर्शन प्रमाणीकरण CERC के टैरिफ विनियमन, 2024-2029, IEGC-2023 और उनके बाद के संशोधनों तथा NLDC द्वारा दिनांक 30.12.2020 के पत्र के माध्यम से जारी थर्मल ISGS की रैंपिंग क्षमता के आकलन के लिए संशोधित विस्तृत दिशानिर्देशों के अनुसार तैयार किया गया है। यह वही सामग्री NERPC वेबसाइट <https://www.nerpc.gov.in> पर भी उपलब्ध है।

घटक अपनी टिप्पणियाँ/प्रतिक्रियाएँ, यदि कोई हों, इस बयान के जारी होने की तारीख से 15 दिनों के भीतर भेज सकते हैं। यदि घटक की ओर से कोई संचार नहीं प्राप्त होता है, तो जारी किया गया रैंपिंग प्रदर्शन प्रमाणपत्र अंतिम माना जाएगा।

The statement of summary of ramping performance of coal/lignite ISGS of NER upto August-2026 as furnished by NERLDC vide letter No.: NERLDC/RA/2026-27 /RampCert/9793 dated 18-09-2026 is certified as enclosed. The Ramping Performance Certification has been prepared in accordance with the CERC's Tariff Regulation, 2024-2029, IEGC-2023 and their subsequent amendments and the Revised detailed guidelines for assessment of ramping capability of thermal ISGS issued by NLDC vide letter dated 30.12.2020. The same is also available on NERPC website <https://www.nerpc.gov.in>.

Constituents may send their observation/ comments, if any on the same within 15 days from the date of issue of this statement. In case no communication is received from constituents, the Ramping Performance Certification as issued would be treated as final.

Enclosed - As above


संलग्न - उपरोक्तानुसार

भवदीय / Yours faithfully,

(वी. एन. मुंछा/V. N. Muncha)
निदेशक/ Director

पत्तों की सूची /List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala – 799 001
2. Director (Distribution), MePDCL, Lumjingshai, S.R. Road, Shillong – 793 001
3. Engineer-in-Chief (P&E), P&E Dept., Govt. of Mizoram, Aizawl – 796 001
4. Chief General Manager (Comml), APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati – 781 001
5. Chief Engineer (Comm), Dept. of Power, Govt. of Arunachal Pradesh, Itanagar – 791 111
6. Managing Director, MSPDCL, Keishampat, Imphal-795 001.
7. E-in-C, Dept. of Power, Govt. of Nagaland, Kohima – 797 001
8. Chief Engineer, Loktak HE Project, Vidyut Vihar, Komkeirap, Manipur – 795 124
9. Executive Director (Comml.), NEEPCO Ltd., Lower New Colony, Shillong – 793 003
10. Executive Director, NERTS, POWERGRID, Lapalang, Shillong – 793 006
11. Managing Director, OTPC, Core 4 & Central, 10th Floor, SCOPE Minar, Laxmi Nagar, Delhi –110092
12. GM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneswar-12
13. CE (G. M.), CEA, SewaBhawan, R.K.Puram, New Delhi – 110 066.
14. G. M., NERLDC, Lower Nongrah, Dongtieh, Lapalang, Shillong - 6.
15. C.G.M (SLDC) AEGCL, Kahelipara, Guwahati.
16. Gen. Manager (Comml.), NHPC Ltd., NHPC Office complex, Sector –33, Faridabad-121003.
17. G.M (Commercial) APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati - 781 001.
18. General Manager, Ranganadi HEP, NEEPCO, Yazlee, Ar. Pradesh
19. Project Manager, Doyang HEP, NEEPCO, Nagaland
20. Project Manager, AGBPP, NEEPCO Ltd., No. –III, Vill. Bokuloni, Dibrugarh, Assam.
21. Project Manager, AGTPP, NEEPCO Ltd., Ramchandranagar, Agartala, Tripura West- 799008.
22. Dy. G. M (Elect.), Kopili HEP, NEEPCO Ltd., Umrangso, N.C. Hills, Assam.
23. Supdt. Engr. (System Management) MeECL, Lumjingshai, Short Round Road, Shillong.
24. Supdt. Engr. (Commercial) Deptt. of Electricity, Govt.of Manipur, Keisampet, Imphal. 795001
25. Executive Engineer, MSLDC, P & E Dept., Chaltlang, Aizawl- 796012.
26. Supdt. Engr. Dimapur Sub-station Deptt. of Power, Govt.of Nagaland, Dimapur.
27. Dy. G. M. (Commercial) NERTS, Lower Nongrah, Dongtieh, Lapalang, Shillong - 6.
28. Dy. General Manager (ER), POWERGRID, Boring Road, Alankar Place, Patna - 800 001
29. DGM (Comml), OTPC, Core 4 & Central, 10th Floor, SCOPE Minar, Laxmi Nagar, Delhi – 110092
30. DGM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneswar-12
31. AGM (Comml.), NTPC, Bongaigaon Thermal Power Project, P.O Salakati, Kokrajhar-783369
32. Addl. General Manager, Comml & Sys.Opn., TSECL, Banamalipur, Agartala.-799001.
33. Ex. Engr., SLDC, Deptt. of Power, Itanagar, Ar. Pradesh – 791 111
34. CEO, NVVN Ltd., 7th Floor, Scope Complex, Lodhi Road, N.Delhi- 110 003
35. Power Trading Corpn. of India Ltd., 2nd Floor, NBCC Tower, 15-Bhikaji Cama Place, New Delhi – 66.
36. Member Secretary, NRPC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016.
37. Member Secretary, ERPC, 14, Golf Club Road, Kolkata- 700 033.
38. Member Secretary, WRPC, Plot No F-3, MIDC Area, Opp Seepz, Marol, Andheri (E), Mumbai-400 093.
39. Member Secretary, SRPC, 29, Race Course Road, Bangalore- 560009.


(वी. एन. मुंचा/V. N. Muncha)
निदेशक/ Director

NORTH EASTERN REGIONAL POWER COMMITTEE

Ramp Performance of Thermal Power Stations upto Month										Apr-26
Number of months in computation (M):										1
Station	Total no. of Time Blocks (TM).	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(T_d)$	T_d/T_m	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E).	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in ROE
BGTPP	2706	2683	0.990	34	24	27	1	0.71	0.79	0

Ramp Performance of Thermal Power Stations upto Month										May-26
Number of months in computation (M):										2
Station	Total no. of Time Blocks (TM).	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(T_d)$	T_d/T_m	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E).	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in ROE
BGTPP	5559	5536	1.000	84	62	68	1	0.74	0.81	0

Ramp Performance of Thermal Power Stations upto Month										Jun-26
Number of months in computation (M):										3
Station	Total no. of Time Blocks (TM).	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(Td)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E).	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in ROE
BGTPP	8380	8357	1.000	137	103	111	1.01	0.75	0.81	0

Ramp Performance of Thermal Power Stations upto Month										Jul-26
Number of months in computation (M):										4
Station	Total no. of Time Blocks (TM).	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(Td)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E).	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in ROE
BGTPP	11265	11242	1.000	198	148	160	1.02	0.75	0.81	0

Ramp Performance of Thermal Power Stations upto Month										Aug-26
Number of months in computation (M):										5
Station	Total no. of Time Blocks (TM).	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(Td)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E).	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in ROE
BGTPP	14167	14143	1.000	257	190	206	1.02	0.74	0.80	0